



Houston Elementary School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-014300	9/26/2023	9/26/2024	1	Combo Faucet	In room 100 pre-school classroom	WF-09262023-014300	1/11/2024	FT-FY24-11272023-014300-A	2.0	FT-FY24-11272023-014300-B	<1	
WS-014301	4/24/2023	4/24/2024	1	Combo Fountain	In room 100 pre-school classroom	WF-04242023-014301	1/11/2024	FT-FY24-11272023-014301-A	<1	FT-FY24-11272023-014301-B	<1	
WS-014305	4/24/2023	4/24/2024	1	Combo Fountain	In room 101 pre-school classroom	WF-04242023-014305	1/11/2024	FT-FY24-11272023-014305-A	<1	FT-FY24-11272023-014305-B	<1	
WS-014306	9/26/2023	9/26/2024	1	Combo Faucet	In room 102 pre-k classroom	WF-09262023-014306	1/11/2024	FT-FY24-11272023-014306-A	1.9	FT-FY24-11272023-014306-B	<1	
WS-014307	4/24/2023	4/24/2024	1	Combo Fountain	In room 102 pre-k classroom	WF-04242023-014307	1/11/2024	FT-FY24-11272023-014307-A	<1	FT-FY24-11272023-014307-B	<1	
WS-014310	9/26/2023	9/26/2024	1	Combo Faucet	In room 103 pre-school classroom	WF-09262023-014310	1/11/2024	FT-FY24-11272023-014310-A	1.3	FT-FY24-11272023-014310-B	<1	
WS-014311	4/24/2023	4/24/2024	1	Combo Fountain	In room 103 pre-school classroom	WF-04242023-014311	1/11/2024	FT-FY24-11272023-014311-A	<1	FT-FY24-11272023-014311-B	<1	
WS-014312	4/24/2023	4/24/2024	1	Break Room	In room 108 teacher collaboration	WF-04242023-014312	1/11/2024	FT-FY24-11272023-014312-A	<1	FT-FY24-11272023-014312-B	<1	
WS-014313	9/26/2023	9/26/2024	1	Combo Faucet	In room 109 pre-k classroom	WF-09262023-014313	1/11/2024	FT-FY24-11272023-014313-A	1.1	FT-FY24-11272023-014313-B	<1	
WS-014314	4/24/2023	4/24/2024	1	Combo Fountain	In room 109 pre-k classroom	WF-04242023-014314	1/11/2024	FT-FY24-11272023-014314-A	<1	FT-FY24-11272023-014314-B	<1	
WS-014317	9/26/2023	9/26/2024	1	Combo Faucet	In room 110 kindergarten classroom	WF-09262023-014317	1/11/2024	FT-FY24-11272023-014317-A	<1	FT-FY24-11272023-014317-B	<1	
WS-014318	4/24/2023	4/24/2024	1	Combo Fountain	In room 110 kindergarten classroom	WF-04242023-014318	1/11/2024	FT-FY24-11272023-014318-A	<1	FT-FY24-11272023-014318-B	<1	
WS-014319	9/26/2023	9/26/2024	1	Combo Faucet	In room 111 kindergarten classroom	WF-09262023-014319	1/11/2024	FT-FY24-11272023-014319-A	<1	FT-FY24-11272023-014319-B	<1	
WS-014320	4/24/2023	4/24/2024	1	Combo Fountain	In room 111 kindergarten classroom	WF-04242023-014320	1/11/2024	FT-FY24-11272023-014320-A	<1	FT-FY24-11272023-014320-B	<1	
WS-014324	4/24/2023	4/24/2024	1	Combo Fountain	In room 112 kindergarten classroom	WF-04242023-014324	1/11/2024	FT-FY24-11272023-014324-A	<1	FT-FY24-11272023-014324-B	<1	
WS-014326	4/24/2023	4/24/2024	1	Combo Fountain	In room 113 Makerspace	WF-04242023-014326	1/11/2024	FT-FY24-11272023-014326-A	1.2	FT-FY24-11272023-014326-B	<1	
WS-014327	4/24/2023	4/24/2024	1	Bottle Filler	In hallway adjacent to 113 makerspace	WF-04242023-014327	1/11/2024	FT-FY24-11272023-014327-A	<1	FT-FY24-11272023-014327-B	<1	
WS-014328	4/24/2023	4/24/2024	1	Cooler	In hallway adjacent to 113 makerspace	High Left	WF-04242023-014328	1/11/2024	FT-FY24-11272023-014328-A	<1	FT-FY24-11272023-014328-B	<1
WS-014329	4/24/2023	4/24/2024	1	Cooler	In hallway adjacent to 113 makerspace	Low Right	WF-04242023-014329	1/11/2024	FT-FY24-11272023-014329-A	<1	FT-FY24-11272023-014329-B	<1
WS-014332	4/24/2023	4/24/2024	1	Combo Fountain	In room 117 1st grade classroom	WF-04242023-014332	1/11/2024	FT-FY24-11272023-014332-A	<1	FT-FY24-11272023-014332-B	<1	
WS-014334	4/24/2023	4/24/2024	1	Combo Fountain	In room 118 speech classroom	WF-04242023-014334	1/11/2024	FT-FY24-11272023-014334-A	<1	FT-FY24-11272023-014334-B	<1	
WS-014336	4/24/2023	4/24/2024	1	Combo Fountain	In room 119 1st grade classroom	WF-04242023-014336	1/11/2024	FT-FY24-11272023-014336-A	<1	FT-FY24-11272023-014336-B	<1	
WS-014338	4/24/2023	4/24/2024	1	Combo Fountain	In room 120 special education	WF-04242023-014338	1/11/2024	FT-FY24-11272023-014338-A	<1	FT-FY24-11272023-014338-B	<1	
WS-014340	4/24/2023	4/24/2024	1	Combo Fountain	In room 121 resource room	WF-04242023-014340	1/11/2024	FT-FY24-11272023-014340-A	<1	FT-FY24-11272023-014340-B	<1	
WS-014342	4/24/2023	4/24/2024	1	Combo Fountain	In room 123 special education	WF-04242023-014342	1/11/2024	FT-FY24-11272023-014342-A	<1	FT-FY24-11272023-014342-B	<1	
WS-014344	4/24/2023	4/24/2024	1	Combo Fountain	In room 124 special education	WF-04242023-014344	1/11/2024	FT-FY24-11272023-014344-A	<1	FT-FY24-11272023-014344-B	<1	
WS-014346	4/24/2023	4/24/2024	1	Combo Fountain	In room 129 special education	WF-04242023-014346	1/11/2024	FT-FY24-11272023-014346-A	<1	FT-FY24-11272023-014346-B	<1	
WS-014349	4/24/2023	4/24/2024	1	Combo Fountain	In room 130 project science	WF-04242023-014349	1/11/2024	FT-FY24-11272023-014349-A	<1	FT-FY24-11272023-014349-B	<1	
WS-014350	4/24/2023	4/24/2024	1	Bottle Filler	In hallway adjacent to 130 project science	WF-04242023-014350	1/11/2024	FT-FY24-11272023-014350-A	<1	FT-FY24-11272023-014350-B	<1	
WS-014351	4/24/2023	4/24/2024	1	Cooler	In hallway adjacent to 130 project science	High Left	WF-04242023-014351	1/11/2024	FT-FY24-11272023-014351-A	<1	FT-FY24-11272023-014351-B	<1
WS-014352	4/24/2023	4/24/2024	1	Cooler	In hallway adjacent to 130 project science	Low Right	WF-04242023-014352	1/11/2024	FT-FY24-11272023-014352-A	<1	FT-FY24-11272023-014352-B	<1
WS-014355	4/24/2023	4/24/2024	2	Break Room	In room 201 staff lounge	WF-04242023-014355	1/11/2024	FT-FY24-11272023-014355-A	<1	FT-FY24-11272023-014355-B	<1	
WS-014359	4/24/2023	4/24/2024	2	Bottle Filler	In hallway adjacent to 205 3rd grade classroom	WF-04242023-014359	1/11/2024	FT-FY24-11272023-014359-A	<1	FT-FY24-11272023-014359-B	<1	
WS-014360	4/24/2023	4/24/2024	2	Cooler	In hallway adjacent to 205 3rd grade classroom	High Left	WF-04242023-014360	1/11/2024	FT-FY24-11272023-014360-A	<1	FT-FY24-11272023-014360-B	<1
WS-014361	4/24/2023	4/24/2024	2	Cooler	In hallway adjacent to 205 3rd grade classroom	Low Right	WF-04242023-014361	1/11/2024	FT-FY24-11272023-014361-A	<1	FT-FY24-11272023-014361-B	<1

WS-014363	4/24/2023	4/24/2024	2	Combo Fountain	In room 210 3rd grade classroom		WF-04242023-014363	1/11/2024	FT-FY24-11272023-014363-A	<1	FT-FY24-11272023-014363-B	<1
WS-014365	4/24/2023	4/24/2024	2	Combo Fountain	In room 211 4th grade classroom		WF-04242023-014365	1/11/2024	FT-FY24-11272023-014365-A	<1	FT-FY24-11272023-014365-B	<1
WS-014367	4/24/2023	4/24/2024	2	Combo Fountain	In room 217 4th grade classroom		WF-04242023-014367	1/11/2024	FT-FY24-11272023-014367-A	<1	FT-FY24-11272023-014367-B	<1
WS-014369	4/24/2023	4/24/2024	2	Combo Fountain	In room 218 5th grade classroom		WF-04242023-014369	1/11/2024	FT-FY24-11272023-014369-A	<1	FT-FY24-11272023-014369-B	<1
WS-014371	4/24/2023	4/24/2024	2	Combo Fountain	In room 223 5th grade classroom		WF-04242023-014371	1/11/2024	FT-FY24-11272023-014371-A	<1	FT-FY24-11272023-014371-B	<1
WS-014373	4/24/2023	4/24/2024	2	Combo Fountain	In room 224 library		WF-04242023-014373	1/11/2024	FT-FY24-11272023-014373-A	<1	FT-FY24-11272023-014373-B	<1
WS-014375	4/24/2023	4/24/2024	2	Bottle Filler	In hallway adjacent to C201 storage corridor		WF-04242023-014375	1/11/2024	FT-FY24-11272023-014375-A	<1	FT-FY24-11272023-014375-B	<1
WS-014376	4/24/2023	4/24/2024	2	Cooler	In hallway adjacent to C201 storage corridor	High Left	WF-04242023-014376	1/11/2024	FT-FY24-11272023-014376-A	<1	FT-FY24-11272023-014376-B	<1
WS-014377	4/24/2023	4/24/2024	2	Cooler	In hallway adjacent to C201 storage corridor	Low Right	WF-04242023-014377	1/11/2024	FT-FY24-11272023-014377-A	<1	FT-FY24-11272023-014377-B	<1
WS-014379	4/24/2023	4/24/2024	2	Combo Fountain	In room 226 special education		WF-04242023-014379	1/11/2024	FT-FY24-11272023-014379-A	<1	FT-FY24-11272023-014379-B	<1
WS-014381	4/24/2023	4/24/2024	1	Break Room	In workroom 134		WF-04242023-014381	1/11/2024	FT-FY24-11272023-014381-A	<1	FT-FY24-11272023-014381-B	<1
WS-014383	4/24/2023	4/24/2024	1	Break Room	In parent resource 144		WF-04242023-014383	1/11/2024	FT-FY24-11272023-014383-A	2.0	FT-FY24-11272023-014383-B	<1
WS-014384	4/24/2023	4/24/2024	1	Health Suite	In health suite in treatment room 150E		WF-04242023-014384	1/11/2024	FT-FY24-11272023-014384-A	<1	FT-FY24-11272023-014384-B	<1
WS-014386	4/24/2023	4/24/2024	1	Cooler	In hallway between restrooms 145 and 146	High Left	WF-04242023-014386	1/11/2024	FT-FY24-11272023-014386-A	<1	FT-FY24-11272023-014386-B	<1
WS-014387	4/24/2023	4/24/2024	1	Cooler	In hallway between restrooms 145 and 146	Low Right	WF-04242023-014387	1/11/2024	FT-FY24-11272023-014387-A	<1	FT-FY24-11272023-014387-B	<1
WS-014388	4/24/2023	4/24/2024	1	Bottle Filler	In cafeteria		WF-04242023-014388	1/11/2024	FT-FY24-11272023-014388-A	<1	FT-FY24-11272023-014388-B	<1
WS-014389	4/24/2023	4/24/2024	1	Cooler	In cafeteria	High Left	WF-04242023-014389	1/11/2024	FT-FY24-11272023-014389-A	<1	FT-FY24-11272023-014389-B	<1
WS-014390	4/24/2023	4/24/2024	1	Cooler	In cafeteria	Low Right	WF-04242023-014390	1/11/2024	FT-FY24-11272023-014390-A	<1	FT-FY24-11272023-014390-B	<1
WS-014402	4/24/2023	4/24/2024	2	Combo Fountain	In classroom 231		WF-04242023-014402	1/11/2024	FT-FY24-11272023-014402-A	<1	FT-FY24-11272023-014402-B	<1
WS-014404	4/24/2023	4/24/2024	2	Combo Fountain	In classroom 232		WF-04242023-014404	1/11/2024	FT-FY24-11272023-014404-A	1.2	FT-FY24-11272023-014404-B	<1
WS-014407	4/24/2023	4/24/2024	2	Combo Fountain	In classroom 234		WF-04242023-014407	1/11/2024	FT-FY24-11272023-014407-A	<1	FT-FY24-11272023-014407-B	<1
WS-014409	4/24/2023	4/24/2024	2	Combo Fountain	In classroom 235		WF-04242023-014409	1/11/2024	FT-FY24-11272023-014409-A	1.2	FT-FY24-11272023-014409-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014397	1/23/2023	1/23/2024	1	Food Prep Sink	In kitchen second clockwise from entry	WF-01232023-014397	1/11/2024	FT-FY24-11272023-014397-A	<1	FT-FY24-11272023-014397-B	<1