



Houston Elementary School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-014300	10/4/2022	10/4/2023	1	Combo Faucet	In room 100 pre-school classroom	WF-10042022-014300	11/15/2022	FT-FY23-10102022-014300-A	<1	FT-FY23-10102022-014300-B	<1	
WS-014301	5/2/2022	5/2/2023	1	Combo Fountain	In room 100 pre-school classroom	WF-05022022-014301	11/15/2022	FT-FY23-10102022-014301-A	<1	FT-FY23-10102022-014301-B	<1	
WS-014304	10/4/2022	10/4/2023	1	Combo Faucet	In room 101 pre-school classroom	WF-10042022-014304	11/15/2022	FT-FY23-10102022-014304-A	<1	FT-FY23-10102022-014304-B	<1	
WS-014305	5/2/2022	5/2/2023	1	Combo Fountain	In room 101 pre-school classroom	WF-05022022-014305	11/15/2022	FT-FY23-10102022-014305-A	<1	FT-FY23-10102022-014305-B	<1	
WS-014306	10/4/2022	10/4/2023	1	Combo Faucet	In room 102 pre-k classroom	WF-10042022-014306	11/15/2022	FT-FY23-10102022-014306-A	<1	FT-FY23-10102022-014306-B	<1	
WS-014307	5/2/2022	5/2/2023	1	Combo Fountain	In room 102 pre-k classroom	WF-05022022-014307	11/15/2022	FT-FY23-10102022-014307-A	<1	FT-FY23-10102022-014307-B	<1	
WS-014310	10/4/2022	10/4/2023	1	Combo Faucet	In room 103 pre-school classroom	WF-10042022-014310	11/15/2022	FT-FY23-10102022-014310-A	<1	FT-FY23-10102022-014310-B	<1	
WS-014311	5/2/2022	5/2/2023	1	Combo Fountain	In room 103 pre-school classroom	WF-05022022-014311	11/15/2022	FT-FY23-10102022-014311-A	<1	FT-FY23-10102022-014311-B	<1	
WS-014312	5/2/2022	5/2/2023	1	Break Room	In room 108 teacher collaboration	WF-05022022-014312	11/15/2022	FT-FY23-10102022-014312-A	<1	FT-FY23-10102022-014312-B	<1	
WS-014313	10/4/2022	10/4/2023	1	Combo Faucet	In room 109 pre-k classroom	WF-10042022-014313	11/15/2022	FT-FY23-10102022-014313-A	<1	FT-FY23-10102022-014313-B	<1	
WS-014314	5/2/2022	5/2/2023	1	Combo Fountain	In room 109 pre-k classroom	WF-05022022-014314	11/15/2022	FT-FY23-10102022-014314-A	<1	FT-FY23-10102022-014314-B	<1	
WS-014317	10/4/2022	10/4/2023	1	Combo Faucet	In room 110 kindergarten classroom	WF-10042022-014317	11/15/2022	FT-FY23-10102022-014317-A	<1	FT-FY23-10102022-014317-B	<1	
WS-014318	5/2/2022	5/2/2023	1	Combo Fountain	In room 110 kindergarten classroom	WF-05022022-014318	11/15/2022	FT-FY23-10102022-014318-A	<1	FT-FY23-10102022-014318-B	<1	
WS-014319	10/4/2022	10/4/2023	1	Combo Faucet	In room 111 kindergarten classroom	WF-10042022-014319	11/15/2022	FT-FY23-10102022-014319-A	<1	FT-FY23-10102022-014319-B	<1	
WS-014320	5/2/2022	5/2/2023	1	Combo Fountain	In room 111 kindergarten classroom	WF-05022022-014320	11/15/2022	FT-FY23-10102022-014320-A	<1	FT-FY23-10102022-014320-B	<1	
WS-014324	5/2/2022	5/2/2023	1	Combo Fountain	In room 112 kindergarten classroom	WF-05022022-014324	11/15/2022	FT-FY23-10102022-014324-A	<1	FT-FY23-10102022-014324-B	<1	
WS-014326	5/2/2022	5/2/2023	1	Combo Fountain	In room 113 Makerspace	WF-05022022-014326	11/15/2022	FT-FY23-10102022-014326-A	<1	FT-FY23-10102022-014326-B	<1	
WS-014327	5/2/2022	5/2/2023	1	Bottle Filler	In hallway adjacent to 113 makerspace	WF-05022022-014327	11/15/2022	FT-FY23-10102022-014327-A	<1	FT-FY23-10102022-014327-B	<1	
WS-014328	5/2/2022	5/2/2023	1	Cooler	In hallway adjacent to 113 makerspace	High Left	WF-05022022-014328	11/15/2022	FT-FY23-10102022-014328-A	<1	FT-FY23-10102022-014328-B	<1
WS-014329	5/2/2022	5/2/2023	1	Cooler	In hallway adjacent to 113 makerspace	Low Right	WF-05022022-014329	11/15/2022	FT-FY23-10102022-014329-A	<1	FT-FY23-10102022-014329-B	<1
WS-014332	5/2/2022	5/2/2023	1	Combo Fountain	In room 117 1st grade classroom	WF-05022022-014332	11/15/2022	FT-FY23-10102022-014332-A	<1	FT-FY23-10102022-014332-B	<1	
WS-014334	5/2/2022	5/2/2023	1	Combo Fountain	In room 118 speech classroom	WF-05022022-014334	11/15/2022	FT-FY23-10102022-014334-A	<1	FT-FY23-10102022-014334-B	<1	
WS-014336	5/2/2022	5/2/2023	1	Combo Fountain	In room 119 1st grade classroom	WF-05022022-014336	11/15/2022	FT-FY23-10102022-014336-A	<1	FT-FY23-10102022-014336-B	<1	
WS-014338	5/2/2022	5/2/2023	1	Combo Fountain	In room 120 special education	WF-05022022-014338	11/15/2022	FT-FY23-10102022-014338-A	<1	FT-FY23-10102022-014338-B	<1	
WS-014340	5/2/2022	5/2/2023	1	Combo Fountain	In room 121 resource room	WF-05022022-014340	11/15/2022	FT-FY23-10102022-014340-A	<1	FT-FY23-10102022-014340-B	<1	
WS-014342	5/2/2022	5/2/2023	1	Combo Fountain	In room 123 special education	WF-05022022-014342	11/15/2022	FT-FY23-10102022-014342-A	<1	FT-FY23-10102022-014342-B	<1	
WS-014344	5/2/2022	5/2/2023	1	Combo Fountain	In room 124 special education	WF-05022022-014344	11/15/2022	FT-FY23-10102022-014344-A	<1	FT-FY23-10102022-014344-B	<1	
WS-014346	5/2/2022	5/2/2023	1	Combo Fountain	In room 129 special education	WF-05022022-014346	11/15/2022	FT-FY23-10102022-014346-A	<1	FT-FY23-10102022-014346-B	<1	
WS-014349	5/2/2022	5/2/2023	1	Combo Fountain	In room 130 project science	WF-05022022-014349	11/15/2022	FT-FY23-10102022-014349-A	<1	FT-FY23-10102022-014349-B	<1	
WS-014350	5/2/2022	5/2/2023	1	Bottle Filler	In hallway adjacent to 130 project science	WF-05022022-014350	11/15/2022	FT-FY23-10102022-014350-A	<1	FT-FY23-10102022-014350-B	<1	
WS-014351	5/2/2022	5/2/2023	1	Cooler	In hallway adjacent to 130 project science	High Left	WF-05022022-014351	11/15/2022	FT-FY23-10102022-014351-A	<1	FT-FY23-10102022-014351-B	<1
WS-014352	5/2/2022	5/2/2023	1	Cooler	In hallway adjacent to 130 project science	Low Right	WF-05022022-014352	11/15/2022	FT-FY23-10102022-014352-A	<1	FT-FY23-10102022-014352-B	<1
WS-014355	5/2/2022	5/2/2023	2	Break Room	In room 201 staff lounge	WF-05022022-014355	11/15/2022	FT-FY23-10102022-014355-A	<1	FT-FY23-10102022-014355-B	<1	
WS-014356	5/2/2022	5/2/2023	2	Break Room	In room 203 teacher collaboration	WF-05022022-014356	11/15/2022	FT-FY23-10102022-014356-A	<1	FT-FY23-10102022-014356-B	<1	
WS-014358	5/2/2022	5/2/2023	2	Combo Fountain	In room 205 3rd grade classroom	WF-05022022-014358	11/15/2022	FT-FY23-10102022-014358-A	<1	FT-FY23-10102022-014358-B	<1	

WS-014359	5/2/2022	5/2/2023	2	Bottle Filler	In hallway adjacent to 205 3rd grade classroom		WF-05022022-014359	11/15/2022	FT-FY23-10102022-014359-A	<1	FT-FY23-10102022-014359-B	<1
WS-014360	5/2/2022	5/2/2023	2	Cooler	In hallway adjacent to 205 3rd grade classroom	High Left	WF-05022022-014360	11/15/2022	FT-FY23-10102022-014360-A	<1	FT-FY23-10102022-014360-B	<1
WS-014361	5/2/2022	5/2/2023	2	Cooler	In hallway adjacent to 205 3rd grade classroom	Low Right	WF-05022022-014361	11/15/2022	FT-FY23-10102022-014361-A	<1	FT-FY23-10102022-014361-B	<1
WS-014363	5/2/2022	5/2/2023	2	Combo Fountain	In room 210 3rd grade classroom		WF-05022022-014363	11/15/2022	FT-FY23-10102022-014363-A	<1	FT-FY23-10102022-014363-B	<1
WS-014365	5/2/2022	5/2/2023	2	Combo Fountain	In room 211 4th grade classroom		WF-05022022-014365	11/15/2022	FT-FY23-10102022-014365-A	<1	FT-FY23-10102022-014365-B	<1
WS-014367	5/2/2022	5/2/2023	2	Combo Fountain	In room 217 4th grade classroom		WF-05022022-014367	11/15/2022	FT-FY23-10102022-014367-A	<1	FT-FY23-10102022-014367-B	<1
WS-014369	5/2/2022	5/2/2023	2	Combo Fountain	In room 218 5th grade classroom		WF-05022022-014369	11/15/2022	FT-FY23-10102022-014369-A	<1	FT-FY23-10102022-014369-B	<1
WS-014371	5/2/2022	5/2/2023	2	Combo Fountain	In room 223 5th grade classroom		WF-05022022-014371	11/15/2022	FT-FY23-10102022-014371-A	<1	FT-FY23-10102022-014371-B	<1
WS-014373	5/2/2022	5/2/2023	2	Combo Fountain	In room 224 library		WF-05022022-014373	11/15/2022	FT-FY23-10102022-014373-A	<1	FT-FY23-10102022-014373-B	<1
WS-014375	5/2/2022	5/2/2023	2	Bottle Filler	In hallway adjacent to C201 storage corridor		WF-05022022-014375	11/15/2022	FT-FY23-10102022-014375-A	<1	FT-FY23-10102022-014375-B	<1
WS-014376	5/2/2022	5/2/2023	2	Cooler	In hallway adjacent to C201 storage corridor	High Left	WF-05022022-014376	11/15/2022	FT-FY23-10102022-014376-A	<1	FT-FY23-10102022-014376-B	<1
WS-014377	5/2/2022	5/2/2023	2	Cooler	In hallway adjacent to C201 storage corridor	Low Right	WF-05022022-014377	11/15/2022	FT-FY23-10102022-014377-A	<1	FT-FY23-10102022-014377-B	<1
WS-014379	5/2/2022	5/2/2023	2	Combo Fountain	In room 226 special education		WF-05022022-014379	11/15/2022	FT-FY23-10102022-014379-A	<1	FT-FY23-10102022-014379-B	<1
WS-014381	5/2/2022	5/2/2023	1	Break Room	In workroom 134		WF-05022022-014381	11/15/2022	FT-FY23-10102022-014381-A	<1	FT-FY23-10102022-014381-B	<1
WS-014383	5/2/2022	5/2/2023	1	Break Room	In parent resource 144		WF-05022022-014383	11/15/2022	FT-FY23-10102022-014383-A	4.1	FT-FY23-10102022-014383-B	<1
WS-014384	5/2/2022	5/2/2023	1	Health Suite	In health suite in treatment room 150E		WF-05022022-014384	11/15/2022	FT-FY23-10102022-014384-A	<1	FT-FY23-10102022-014384-B	<1
WS-014386	5/2/2022	5/2/2023	1	Cooler	In hallway between restrooms 145 and 146	High Left	WF-05022022-014386	11/15/2022	FT-FY23-10102022-014386-A	<1	FT-FY23-10102022-014386-B	<1
WS-014387	5/2/2022	5/2/2023	1	Cooler	In hallway between restrooms 145 and 146	Low Right	WF-05022022-014387	11/15/2022	FT-FY23-10102022-014387-A	<1	FT-FY23-10102022-014387-B	<1
WS-014388	5/2/2022	5/2/2023	1	Bottle Filler	In cafeteria		WF-05022022-014388	11/15/2022	FT-FY23-10102022-014388-A	<1	FT-FY23-10102022-014388-B	<1
WS-014389	5/2/2022	5/2/2023	1	Cooler	In cafeteria	High Left	WF-05022022-014389	11/15/2022	FT-FY23-10102022-014389-A	<1	FT-FY23-10102022-014389-B	<1
WS-014390	5/2/2022	5/2/2023	1	Cooler	In cafeteria	Low Right	WF-05022022-014390	11/15/2022	FT-FY23-10102022-014390-A	<1	FT-FY23-10102022-014390-B	<1
WS-014402	5/2/2022	5/2/2023	2	Combo Fountain	In classroom 231		WF-05022022-014402	11/15/2022	FT-FY23-10102022-014402-A	<1	FT-FY23-10102022-014402-B	<1
WS-014404	5/2/2022	5/2/2023	2	Combo Fountain	In classroom 232		WF-05022022-014404	11/15/2022	FT-FY23-10102022-014404-A	<1	FT-FY23-10102022-014404-B	<1
WS-014407	5/2/2022	5/2/2023	2	Combo Fountain	In classroom 234		WF-05022022-014407	11/15/2022	FT-FY23-10102022-014407-A	<1	FT-FY23-10102022-014407-B	<1
WS-014409	5/2/2022	5/2/2023	2	Combo Fountain	In classroom 235		WF-05022022-014409	11/15/2022	FT-FY23-10102022-014409-A	<1	FT-FY23-10102022-014409-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014397	2/15/2022	2/15/2023	1	Food Prep Sink	In kitchen second clockwise from entry	WF-02152022-014397	11/15/2022	FT-FY23-10102022-014397-A	<1	FT-FY23-10102022-014397-B	<1