



# Houston Elementary School Lead in Water Test Results

## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-014300	10/20/2020	10/20/2021	1	Combo Faucet	In room 100 pre-school classroom	WF-10202020-014300	3/2/2021	FT-FY21-022021-014300-A	<1	FT-FY21-022021-014300-B	<1	
WS-014301	6/9/2020	6/9/2021	1	Combo Fountain	In room 100 pre-school classroom	WF-06092020-014301	3/2/2021	FT-FY21-022021-014301-A	<1	FT-FY21-022021-014301-B	<1	
WS-014304	10/20/2020	10/20/2021	1	Combo Faucet	In room 101 pre-school classroom	WF-10202020-014304	3/2/2021	FT-FY21-022021-014304-A	<1	FT-FY21-022021-014304-B	<1	
WS-014305	6/9/2020	6/9/2021	1	Combo Fountain	In room 101 pre-school classroom	WF-06092020-014305	3/2/2021	FT-FY21-022021-014305-A	<1	FT-FY21-022021-014305-B	<1	
WS-014306	10/20/2020	10/20/2021	1	Combo Faucet	In room 102 pre-k classroom	WF-10202020-014306	3/2/2021	FT-FY21-022021-014306-A	<1	FT-FY21-022021-014306-B	<1	
WS-014307	6/9/2020	6/9/2021	1	Combo Fountain	In room 102 pre-k classroom	WF-06092020-014307	3/2/2021	FT-FY21-022021-014307-A	<1	FT-FY21-022021-014307-B	<1	
WS-014310	10/20/2020	10/20/2021	1	Combo Faucet	In room 103 pre-school classroom	WF-10202020-014310	3/2/2021	FT-FY21-022021-014310-A	1.1	FT-FY21-022021-014310-B	<1	
WS-014311	6/9/2020	6/9/2021	1	Combo Fountain	In room 103 pre-school classroom	WF-06092020-014311	3/2/2021	FT-FY21-022021-014311-A	<1	FT-FY21-022021-014311-B	<1	
WS-014312	6/9/2020	6/9/2021	1	Break Room	In room 108 teacher collaboration	WF-06092020-014312	3/2/2021	FT-FY21-022021-014312-A	<1	FT-FY21-022021-014312-B	<1	
WS-014313	10/20/2020	10/20/2021	1	Combo Faucet	In room 109 pre-k classroom	WF-10202020-014313	3/2/2021	FT-FY21-022021-014313-A	<1	FT-FY21-022021-014313-B	<1	
WS-014314	6/9/2020	6/9/2021	1	Combo Fountain	In room 109 pre-k classroom	WF-06092020-014314	3/2/2021	FT-FY21-022021-014314-A	<1	FT-FY21-022021-014314-B	<1	
WS-014317	10/20/2020	10/20/2021	1	Combo Faucet	In room 110 kindergarten classroom	WF-10202020-014317	3/2/2021	FT-FY21-022021-014317-A	<1	FT-FY21-022021-014317-B	<1	
WS-014318	6/9/2020	6/9/2021	1	Combo Fountain	In room 110 kindergarten classroom	WF-06092020-014318	3/2/2021	FT-FY21-022021-014318-A	<1	FT-FY21-022021-014318-B	<1	
WS-014319	10/20/2020	10/20/2021	1	Combo Faucet	In room 111 kindergarten classroom	WF-10202020-014319	3/2/2021	FT-FY21-022021-014319-A	<1	FT-FY21-022021-014319-B	<1	
WS-014320	6/9/2020	6/9/2021	1	Combo Fountain	In room 111 kindergarten classroom	WF-06092020-014320	3/2/2021	FT-FY21-022021-014320-A	<1	FT-FY21-022021-014320-B	<1	
WS-014323	10/20/2020	10/20/2021	1	Combo Faucet	In room 112 kindergarten classroom	WF-10202020-014323	3/2/2021	FT-FY21-022021-014323-A	<1	FT-FY21-022021-014323-B	<1	
WS-014324	6/9/2020	6/9/2021	1	Combo Fountain	In room 112 kindergarten classroom	WF-06092020-014324	3/2/2021	FT-FY21-022021-014324-A	<1	FT-FY21-022021-014324-B	<1	
WS-014326	6/9/2020	6/9/2021	1	Combo Fountain	In room 113 Makerspace	WF-06092020-014326	3/2/2021	FT-FY21-022021-014326-A	<1	FT-FY21-022021-014326-B	<1	
WS-014327	6/9/2020	6/9/2021	1	Bottle Filler	In hallway adjacent to 113 makerspace	WF-06092020-014327	3/2/2021	FT-FY21-022021-014327-A	<1	FT-FY21-022021-014327-B	<1	
WS-014328	6/9/2020	6/9/2021	1	Cooler	In hallway adjacent to 113 makerspace	High Left	WF-06092020-014328	3/2/2021	FT-FY21-022021-014328-A	<1	FT-FY21-022021-014328-B	<1
WS-014329	6/9/2020	6/9/2021	1	Cooler	In hallway adjacent to 113 makerspace	Low Right	WF-06092020-014329	3/2/2021	FT-FY21-022021-014329-A	<1	FT-FY21-022021-014329-B	<1
WS-014332	6/9/2020	6/9/2021	1	Combo Fountain	In room 117 1st grade classroom	WF-06092020-014332	3/2/2021	FT-FY21-022021-014332-A	<1	FT-FY21-022021-014332-B	<1	
WS-014334	6/9/2020	6/9/2021	1	Combo Fountain	In room 118 speech classroom	WF-06092020-014334	3/2/2021	FT-FY21-022021-014334-A	<1	FT-FY21-022021-014334-B	<1	
WS-014336	6/9/2020	6/9/2021	1	Combo Fountain	In room 119 1st grade classroom	WF-06092020-014336	3/2/2021	FT-FY21-022021-014336-A	<1	FT-FY21-022021-014336-B	<1	
WS-014338	6/9/2020	6/9/2021	1	Combo Fountain	In room 120 special education	WF-06092020-014338	3/2/2021	FT-FY21-022021-014338-A	<1	FT-FY21-022021-014338-B	<1	
WS-014340	6/9/2020	6/9/2021	1	Combo Fountain	In room 121 resource room	WF-06092020-014340	3/2/2021	FT-FY21-022021-014340-A	<1	FT-FY21-022021-014340-B	<1	
WS-014342	6/9/2020	6/9/2021	1	Combo Fountain	In room 123 special education	WF-06092020-014342	3/2/2021	FT-FY21-022021-014342-A	<1	FT-FY21-022021-014342-B	<1	
WS-014344	6/9/2020	6/9/2021	1	Combo Fountain	In room 124 special education	WF-06092020-014344	3/2/2021	FT-FY21-022021-014344-A	<1	FT-FY21-022021-014344-B	<1	
WS-014346	6/9/2020	6/9/2021	1	Combo Fountain	In room 129 special education	WF-06092020-014346	3/2/2021	FT-FY21-022021-014346-A	<1	FT-FY21-022021-014346-B	<1	
WS-014349	6/9/2020	6/9/2021	1	Combo Fountain	In room 130 project science	WF-06092020-014349	3/2/2021	FT-FY21-022021-014349-A	<1	FT-FY21-022021-014349-B	<1	
WS-014350	7/8/2020	7/8/2021	1	Bottle Filler	In hallway adjacent to 130 project science	WF-07082020-014350	3/2/2021	FT-FY21-022021-014350-A	<1	FT-FY21-022021-014350-B	<1	
WS-014351	7/8/2020	7/8/2021	1	Cooler	In hallway adjacent to 130 project science	High Left	WF-07082020-014351	3/2/2021	FT-FY21-022021-014351-A	<1	FT-FY21-022021-014351-B	<1

WS-014352	7/8/2020	7/8/2021	1	Cooler	In hallway adjacent to 130 project science	Low	Right	WF-07082020-014352	3/2/2021	FT-FY21-022021-014352-A	<1	FT-FY21-022021-014352-B	<1
WS-014355	6/9/2020	6/9/2021	2	Break Room	In room 201 staff lounge			WF-06092020-014355	3/2/2021	FT-FY21-022021-014355-A	<1	FT-FY21-022021-014355-B	<1
WS-014356	6/9/2020	6/9/2021	2	Break Room	In room 203 teacher collaboration			WF-06092020-014356	3/2/2021	FT-FY21-022021-014356-A	<1	FT-FY21-022021-014356-B	<1
WS-014358	6/9/2020	6/9/2021	2	Combo Fountain	In room 205 3rd grade classroom			WF-06092020-014358	3/2/2021	FT-FY21-022021-014358-A	<1	FT-FY21-022021-014358-B	<1
WS-014359	6/9/2020	6/9/2021	2	Bottle Filler	In hallway adjacent to 205 3rd grade classroom			WF-06092020-014359	3/2/2021	FT-FY21-022021-014359-A	<1	FT-FY21-022021-014359-B	<1
WS-014360	6/9/2020	6/9/2021	2	Cooler	In hallway adjacent to 205 3rd grade classroom	High	Left	WF-06092020-014360	3/2/2021	FT-FY21-022021-014360-A	<1	FT-FY21-022021-014360-B	<1
WS-014361	6/9/2020	6/9/2021	2	Cooler	In hallway adjacent to 205 3rd grade classroom	Low	Right	WF-06092020-014361	3/2/2021	FT-FY21-022021-014361-A	<1	FT-FY21-022021-014361-B	<1
WS-014363	6/9/2020	6/9/2021	2	Combo Fountain	In room 210 3rd grade classroom			WF-06092020-014363	3/2/2021	FT-FY21-022021-014363-A	<1	FT-FY21-022021-014363-B	<1
WS-014365	6/9/2020	6/9/2021	2	Combo Fountain	In room 211 4th grade classroom			WF-06092020-014365	3/2/2021	FT-FY21-022021-014365-A	<1	FT-FY21-022021-014365-B	<1
WS-014367	6/9/2020	6/9/2021	2	Combo Fountain	In room 217 4th grade classroom			WF-06092020-014367	3/2/2021	FT-FY21-022021-014367-A	<1	FT-FY21-022021-014367-B	<1
WS-014369	6/9/2020	6/9/2021	2	Combo Fountain	In room 218 5th grade classroom			WF-06092020-014369	3/2/2021	FT-FY21-022021-014369-A	<1	FT-FY21-022021-014369-B	<1
WS-014371	6/9/2020	6/9/2021	2	Combo Fountain	In room 223 5th grade classroom			WF-06092020-014371	3/2/2021	FT-FY21-022021-014371-A	<1	FT-FY21-022021-014371-B	<1
WS-014373	6/9/2020	6/9/2021	2	Combo Fountain	In room 224 library			WF-06092020-014373	3/2/2021	FT-FY21-022021-014373-A	<1	FT-FY21-022021-014373-B	<1
WS-014375	6/9/2020	6/9/2021	2	Bottle Filler	In hallway adjacent to C201 storage corridor			WF-06092020-014375	3/2/2021	FT-FY21-022021-014375-A	<1	FT-FY21-022021-014375-B	<1
WS-014376	6/9/2020	6/9/2021	2	Cooler	In hallway adjacent to C201 storage corridor	High	Left	WF-06092020-014376	3/2/2021	FT-FY21-022021-014376-A	<1	FT-FY21-022021-014376-B	<1
WS-014377	6/9/2020	6/9/2021	2	Cooler	In hallway adjacent to C201 storage corridor	Low	Right	WF-06092020-014377	3/2/2021	FT-FY21-022021-014377-A	<1	FT-FY21-022021-014377-B	<1
WS-014379	6/9/2020	6/9/2021	2	Combo Fountain	In room 226 special education			WF-06092020-014379	3/2/2021	FT-FY21-022021-014379-A	<1	FT-FY21-022021-014379-B	<1
WS-014381	8/11/2020	8/11/2021	1	Break Room	In workroom 134			WF-08112020-014381	3/2/2021	FT-FY21-022021-014381-A	<1	FT-FY21-022021-014381-B	<1
WS-014383	8/11/2020	8/11/2021	1	Break Room	In parent resource 144			WF-08112020-014383	3/2/2021	FT-FY21-022021-014383-A	2.5	FT-FY21-022021-014383-B	1.4
WS-014384	8/11/2020	8/11/2021	1	Health Suite	In health suite in treatment room 150E			WF-08112020-014384	3/2/2021	FT-FY21-022021-014384-A	<1	FT-FY21-022021-014384-B	<1
WS-014386	8/11/2020	8/11/2021	1	Cooler	In hallway between restrooms 145 and 146	High	Left	WF-08112020-014386	3/2/2021	FT-FY21-022021-014386-A	<1	FT-FY21-022021-014386-B	<1
WS-014387	8/11/2020	8/11/2021	1	Cooler	In hallway between restrooms 145 and 146	Low	Right	WF-08112020-014387	3/2/2021	FT-FY21-022021-014387-A	<1	FT-FY21-022021-014387-B	<1
WS-014388	8/13/2020	8/13/2021	1	Bottle Filler	In cafeteria			WF-08132020-014388	3/2/2021	FT-FY21-022021-014388-A	<1	FT-FY21-022021-014388-B	<1
WS-014389	8/13/2020	8/13/2021	1	Cooler	In cafeteria	High	Left	WF-08132020-014389	3/2/2021	FT-FY21-022021-014389-A	<1	FT-FY21-022021-014389-B	<1
WS-014390	8/13/2020	8/13/2021	1	Cooler	In cafeteria	Low	Right	WF-08132020-014390	3/2/2021	FT-FY21-022021-014390-A	<1	FT-FY21-022021-014390-B	<1
WS-014402	8/11/2020	8/11/2021	2	Combo Fountain	In classroom 231			WF-08112020-014402	3/2/2021	FT-FY21-022021-014402-A	<1	FT-FY21-022021-014402-B	<1
WS-014404	8/11/2020	8/11/2021	2	Combo Fountain	In classroom 232			WF-08112020-014404	3/2/2021	FT-FY21-022021-014404-A	<1	FT-FY21-022021-014404-B	<1
WS-014407	8/11/2020	8/11/2021	2	Combo Fountain	In classroom 234			WF-08112020-014407	3/2/2021	FT-FY21-022021-014407-A	<1	FT-FY21-022021-014407-B	<1
WS-014409	8/11/2020	8/11/2021	2	Combo Fountain	In classroom 235			WF-08112020-014409	3/2/2021	FT-FY21-022021-014409-A	<1	FT-FY21-022021-014409-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-014397	8/11/2020	8/11/2021	1	Food Prep Sink	In kitchen second clockwise from entry	WF-08112020-014397	3/2/2021	FT-FY21-022021-014397-A	<1	FT-FY21-022021-014397-B	<1	

### FY21 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014354	7/8/2020	7/8/2021	1	Combo Fountain	In room 131 music room	WF-07082020-014354	3/2/2021	FT-FY21-022021-014354-A	5.0	FT-FY21-022021-014354-B	<1

### FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014354	3/5/2021	3/5/2021	1	Combo Fountain	In room 131 music room	WF-03052021-014354	3/18/2021	FT-FY21-032021-014354-A	<1	FT-FY21-032021-014354-B	<1