



Hyde @ Meyer ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-010547	9/10/2018	9/10/2019	Ground Floor	Classroom Faucet	In classroom G-13	WF-09102018-010547	11/6/2018	FT-FY19-102018-010547-A	< 1	FT-FY19-102018-010547-B	< 1
WS-012047	9/10/2018	9/10/2019	Ground Floor	Classroom Faucet	In classroom G-26	WF-09102018-012047	11/6/2018	FT-FY19-102018-012047-A	< 1	FT-FY19-102018-012047-B	< 1
WS-012048	6/15/2018	6/15/2019	Ground Floor	Cooler	In hallway across from room G15	WF-06152018-012048	11/6/2018	FT-FY19-102018-012048-A	< 1	FT-FY19-102018-012048-B	< 1
WS-012049	6/15/2018	6/15/2019	Ground Floor	Cooler	In hallway adjacent to the restroom	WF-06152018-012049	11/6/2018	FT-FY19-102018-012049-A	< 1	FT-FY19-102018-012049-B	< 1
WS-012066	6/15/2018	6/15/2019	1	Cooler	In hallway adjacent to room 143	WF-06152018-012066	11/6/2018	FT-FY19-102018-012066-A	< 1	FT-FY19-102018-012066-B	< 1
WS-012068	6/15/2018	6/15/2019	1	Cooler	In health suite	WF-06152018-012068	11/6/2018	FT-FY19-102018-012068-A	< 1	FT-FY19-102018-012068-B	< 1
WS-012069	9/10/2018	9/10/2019	Ground Floor	Classroom Faucet	In classroom G19	WF-09102018-012069	11/6/2018	FT-FY19-102018-012069-A	< 1	FT-FY19-102018-012069-B	< 1
WS-012070	6/15/2018	6/15/2019	1	Break Room	In staff lounge	WF-06152018-012070	11/6/2018	FT-FY19-102018-012070-A	< 1	FT-FY19-102018-012070-B	< 1
WS-012071	6/15/2018	6/15/2019	1	Cooler	In hallway adjacent to restroom	WF-06152018-012071	11/6/2018	FT-FY19-102018-012071-A	< 1	FT-FY19-102018-012071-B	< 1
WS-012072	10/23/2018	10/23/2019	1	Food Prep Sink	In kitchen Left	WF-10232018-012072	11/6/2018	FT-FY19-102018-012072-A	< 1	FT-FY19-102018-012072-B	< 1
WS-012074	6/15/2018	6/15/2019	1	Cooler	In hallway adjacent to room 115	WF-06152018-012074	11/6/2018	FT-FY19-102018-012074-A	< 1	FT-FY19-102018-012074-B	< 1
WS-012075	6/15/2018	6/15/2019	2	Cooler	In hallway adjacent to room 215	WF-06152018-012075	11/6/2018	FT-FY19-102018-012075-A	< 1	FT-FY19-102018-012075-B	< 1
WS-012077	6/15/2018	6/15/2019	2	Cooler	In hallway adjacent to restroom	WF-06152018-012077	11/6/2018	FT-FY19-102018-012077-A	< 1	FT-FY19-102018-012077-B	< 1
WS-012078	6/15/2018	6/15/2019	2	Cooler	In hallway across from room 202	WF-06152018-012078	11/6/2018	FT-FY19-102018-012078-A	< 1	FT-FY19-102018-012078-B	< 1
WS-012138	6/28/2018	6/28/2019	Ground Floor	Cooler	In classroom G13	WF-06282018-012138	11/6/2018	FT-FY19-102018-012138-A	< 1	FT-FY19-102018-012138-B	< 1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-012072	1	Food Prep Sink	In kitchen Left	11/6/2018	FT-FY19-102018-012072-A	< 1	FT-FY19-102018-012072-B	< 1