



# Hyde-Addison Elementary School Lead in Water Test Results



## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014761	6/29/2020	6/29/2021	Basement	Bottle Filler	In mezzanine over looking the gym adjacent to 015 mechanical room	WF-06292020-014761	1/15/2021	FT-FY21-012021-014761-A	<1	FT-FY21-012021-014761-B	<1
WS-014764	6/29/2020	6/29/2021	1	Health Suite	In room 112 health suite	WF-06292020-014764	1/15/2021	FT-FY21-012021-014764-A	<1	FT-FY21-012021-014764-B	<1
WS-014766	6/29/2020	6/29/2021	Basement	Combo Fountain	In room H-008 instruction coach	WF-06292020-014766	1/15/2021	FT-FY21-012021-014766-A	<1	FT-FY21-012021-014766-B	<1
WS-014767	10/19/2020	10/19/2021	Basement	Combo Faucet	In room H-005 classroom	WF-10192020-014767	1/15/2021	FT-FY21-012021-014767-A	2.4	FT-FY21-012021-014767-B	<1
WS-014768	6/29/2020	6/29/2021	Basement	Combo Fountain	In room H-005 classroom	WF-06292020-014768	1/15/2021	FT-FY21-012021-014768-A	1.5	FT-FY21-012021-014768-B	<1
WS-014773	10/19/2020	10/19/2021	1	Combo Faucet	In room H-106 classroom	WF-10192020-014773	1/15/2021	FT-FY21-012021-014773-A	<1	FT-FY21-012021-014773-B	<1
WS-014774	6/29/2020	6/29/2021	1	Combo Fountain	In room H-106 classroom	WF-06292020-014774	1/15/2021	FT-FY21-012021-014774-A	<1	FT-FY21-012021-014774-B	<1
WS-014775	10/19/2020	10/19/2021	1	Combo Fountain	In room H-100 classroom	WF-10192020-014775	1/15/2021	FT-FY21-012021-014775-A	<1	FT-FY21-012021-014775-B	<1
WS-014776	10/19/2020	10/19/2021	1	Combo Faucet	In room H-102 classroom	WF-10192020-014776	1/15/2021	FT-FY21-012021-014776-A	1.5	FT-FY21-012021-014776-B	<1
WS-014777	6/29/2020	6/29/2021	1	Combo Fountain	In room H-102 classroom	WF-06292020-014777	1/15/2021	FT-FY21-012021-014777-A	<1	FT-FY21-012021-014777-B	<1
WS-014778	10/19/2020	10/19/2021	1	Combo Faucet	In room H-104 classroom	WF-10192020-014778	1/15/2021	FT-FY21-012021-014778-A	<1	FT-FY21-012021-014778-B	<1
WS-014779	6/29/2020	6/29/2021	1	Combo Fountain	In room H-104 classroom	WF-06292020-014779	1/15/2021	FT-FY21-012021-014779-A	<1	FT-FY21-012021-014779-B	<1
WS-014781	6/29/2020	6/29/2021	2	Combo Fountain	In room H-207 classroom	WF-06292020-014781	1/15/2021	FT-FY21-012021-014781-A	<1	FT-FY21-012021-014781-B	1.4
WS-014783	6/29/2020	6/29/2021	2	Combo Fountain	In room H-200 classroom	WF-06292020-014783	1/15/2021	FT-FY21-012021-014783-A	<1	FT-FY21-012021-014783-B	<1
WS-014784	10/19/2020	10/19/2021	2	Combo Faucet	In room H-202 classroom	WF-10192020-014784	1/15/2021	FT-FY21-012021-014784-A	<1	FT-FY21-012021-014784-B	<1
WS-014785	6/29/2020	6/29/2021	2	Combo Fountain	In room H-202 classroom	WF-06292020-014785	1/15/2021	FT-FY21-012021-014785-A	<1	FT-FY21-012021-014785-B	<1
WS-014787	6/29/2020	6/29/2021	2	Combo Fountain	In room H-205 classroom	WF-06292020-014787	1/15/2021	FT-FY21-012021-014787-A	<1	FT-FY21-012021-014787-B	<1
WS-014788	6/29/2020	6/29/2021	1	Bottle Filler	In lobby adjacent to 111 welcome center	WF-06292020-014788	1/15/2021	FT-FY21-012021-014788-A	<1	FT-FY21-012021-014788-B	<1
WS-014791	6/29/2020	6/29/2021	1	Break Room	In room A-129 staff lounge	WF-06292020-014791	1/15/2021	FT-FY21-012021-014791-A	<1	FT-FY21-012021-014791-B	<1
WS-014793	6/29/2020	6/29/2021	1	Bottle Filler	In room A-125 music room	WF-06292020-014793	1/15/2021	FT-FY21-012021-014793-A	<1	FT-FY21-012021-014793-B	<1
WS-014798	6/29/2020	6/29/2021	2	Cooler	In hallway adjacent to room A-218 High Left	WF-06292020-014798	1/15/2021	FT-FY21-012021-014798-A	<1	FT-FY21-012021-014798-B	<1
WS-014799	6/29/2020	6/29/2021	2	Cooler	In hallway adjacent to room A-218 Low Right	WF-06292020-014799	1/15/2021	FT-FY21-012021-014799-A	<1	FT-FY21-012021-014799-B	<1
WS-014802	6/29/2020	6/29/2021	3	Bottle Filler	In hallway adjacent to room A-308	WF-06292020-014802	1/15/2021	FT-FY21-012021-014802-A	<1	FT-FY21-012021-014802-B	<1
WS-014809	6/29/2020	6/29/2021	2	Cooler	In hallway across from elevator and room 216 High Left	WF-06292020-014809	1/15/2021	FT-FY21-012021-014809-A	<1	FT-FY21-012021-014809-B	<1
WS-014810	6/29/2020	6/29/2021	2	Cooler	In hallway across from elevator and room 216 Low Right	WF-06292020-014810	1/15/2021	FT-FY21-012021-014810-A	<1	FT-FY21-012021-014810-B	<1
WS-014815	6/29/2020	6/29/2021	2	Break Room	In room H-203	WF-06292020-014815	1/15/2021	FT-FY21-012021-014815-A	1.1	FT-FY21-012021-014815-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014754	1/8/2021	1/8/2022	Basement	Food Prep Sink	In kitchen second clockwise from entry	WF-01082021-014754	1/15/2021	FT-FY21-012021-014754-A	<1	FT-FY21-012021-014754-B	<1