



Hyde-Addison Elementary School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014750	5/16/2023	5/16/2024	Basement	Bottle Filler	In room 001 gym/cafeteria	WF-05162023-014750	11/4/2023	FT-FY24-10102023-014750-A	<1	FT-FY24-10102023-014750-B	<1
WS-014751	5/16/2023	5/16/2024	Basement	Cooler	In room 001 gym/cafeteria High Left	WF-05162023-014751	11/4/2023	FT-FY24-10102023-014751-A	<1	FT-FY24-10102023-014751-B	<1
WS-014752	5/16/2023	5/16/2024	Basement	Cooler	In room 001 gym/cafeteria Low Right	WF-05162023-014752	11/4/2023	FT-FY24-10102023-014752-A	<1	FT-FY24-10102023-014752-B	<1
WS-014761	5/16/2023	5/16/2024	Basement	Bottle Filler	In mezzanine over looking the gym adjacent to 015 mechanical room	WF-05162023-014761	11/4/2023	FT-FY24-10102023-014761-A	<1	FT-FY24-10102023-014761-B	<1
WS-014762	5/16/2023	5/16/2024	Basement	Cooler	In mezzanine over looking the gym adjacent to 015 mechanical room High Left	WF-05162023-014762	11/4/2023	FT-FY24-10102023-014762-A	<1	FT-FY24-10102023-014762-B	<1
WS-014763	5/16/2023	5/16/2024	Basement	Cooler	In mezzanine over looking the gym adjacent to 015 mechanical room Low Right	WF-05162023-014763	11/4/2023	FT-FY24-10102023-014763-A	<1	FT-FY24-10102023-014763-B	<1
WS-014764	5/16/2023	5/16/2024	1	Health Suite	In room 112 health suite	WF-05162023-014764	11/4/2023	FT-FY24-10102023-014764-A	<1	FT-FY24-10102023-014764-B	<1
WS-014766	5/16/2023	5/16/2024	Basement	Combo Fountain	In room H-008 instruction coach	WF-05162023-014766	11/4/2023	FT-FY24-10102023-014766-A	<1	FT-FY24-10102023-014766-B	<1
WS-014767	9/26/2023	9/26/2024	Basement	Combo Faucet	In room H-005 classroom	WF-09262023-014767	11/4/2023	FT-FY24-10102023-014767-A	1.4	FT-FY24-10102023-014767-B	<1
WS-014768	5/16/2023	5/16/2024	Basement	Combo Fountain	In room H-005 classroom	WF-05162023-014768	11/4/2023	FT-FY24-10102023-014768-A	1.1	FT-FY24-10102023-014768-B	<1
WS-014773	9/26/2023	9/26/2024	1	Combo Faucet	In room H-106 classroom	WF-09262023-014773	11/4/2023	FT-FY24-10102023-014773-A	1.1	FT-FY24-10102023-014773-B	<1
WS-014774	5/16/2023	5/16/2024	1	Combo Fountain	In room H-106 classroom	WF-05162023-014774	11/4/2023	FT-FY24-10102023-014774-A	<1	FT-FY24-10102023-014774-B	<1
WS-014775	9/26/2023	9/26/2024	1	Combo Fountain	In room H-100 classroom	WF-09262023-014775	11/4/2023	FT-FY24-10102023-014775-A	1.3	FT-FY24-10102023-014775-B	<1
WS-014776	9/26/2023	9/26/2024	1	Combo Faucet	In room H-102 classroom	WF-09262023-014776	11/4/2023	FT-FY24-10102023-014776-A	3.1	FT-FY24-10102023-014776-B	<1
WS-014777	5/16/2023	5/16/2024	1	Combo Fountain	In room H-102 classroom	WF-05162023-014777	11/4/2023	FT-FY24-10102023-014777-A	1.1	FT-FY24-10102023-014777-B	<1
WS-014778	9/26/2023	9/26/2024	1	Combo Faucet	In room H-104 classroom	WF-09262023-014778	11/4/2023	FT-FY24-10102023-014778-A	<1	FT-FY24-10102023-014778-B	<1
WS-014779	5/16/2023	5/16/2024	1	Combo Fountain	In room H-104 classroom	WF-05162023-014779	11/4/2023	FT-FY24-10102023-014779-A	<1	FT-FY24-10102023-014779-B	<1
WS-014781	5/16/2023	5/16/2024	2	Combo Fountain	In room H-207 classroom	WF-05162023-014781	11/4/2023	FT-FY24-10102023-014781-A	<1	FT-FY24-10102023-014781-B	<1
WS-014783	5/16/2023	5/16/2024	2	Combo Fountain	In room H-200 classroom	WF-05162023-014783	11/4/2023	FT-FY24-10102023-014783-A	<1	FT-FY24-10102023-014783-B	<1
WS-014784	9/26/2023	9/26/2024	2	Combo Faucet	In room H-202 classroom	WF-09262023-014784	11/4/2023	FT-FY24-10102023-014784-A	4.3	FT-FY24-10102023-014784-B	<1
WS-014785	5/16/2023	5/16/2024	2	Combo Fountain	In room H-202 classroom	WF-05162023-014785	11/4/2023	FT-FY24-10102023-014785-A	<1	FT-FY24-10102023-014785-B	<1
WS-014787	5/16/2023	5/16/2024	2	Combo Fountain	In room H-205 classroom	WF-05162023-014787	11/4/2023	FT-FY24-10102023-014787-A	<1	FT-FY24-10102023-014787-B	<1
WS-014788	5/16/2023	5/16/2024	1	Bottle Filler	In lobby adjacent to 111 welcome center	WF-05162023-014788	11/4/2023	FT-FY24-10102023-014788-A	<1	FT-FY24-10102023-014788-B	<1
WS-014789	5/16/2023	5/16/2024	1	Cooler	In lobby adjacent to 111 welcome center High Left	WF-05162023-014789	11/4/2023	FT-FY24-10102023-014789-A	<1	FT-FY24-10102023-014789-B	<1
WS-014790	5/16/2023	5/16/2024	1	Cooler	In lobby adjacent to 111 welcome center Low Right	WF-05162023-014790	11/4/2023	FT-FY24-10102023-014790-A	<1	FT-FY24-10102023-014790-B	<1
WS-014791	5/16/2023	5/16/2024	1	Break Room	In room A-129 staff lounge	WF-05162023-014791	11/4/2023	FT-FY24-10102023-014791-A	<1	FT-FY24-10102023-014791-B	<1
WS-014793	5/16/2023	5/16/2024	1	Bottle Filler	In room A-125 music room	WF-05162023-014793	11/4/2023	FT-FY24-10102023-014793-A	<1	FT-FY24-10102023-014793-B	<1
WS-014798	5/16/2023	5/16/2024	2	Cooler	In hallway adjacent to room A-218 High Left	WF-05162023-014798	11/4/2023	FT-FY24-10102023-014798-A	<1	FT-FY24-10102023-014798-B	<1
WS-014799	5/16/2023	5/16/2024	2	Cooler	In hallway adjacent to room A-218 Low Right	WF-05162023-014799	11/4/2023	FT-FY24-10102023-014799-A	<1	FT-FY24-10102023-014799-B	<1
WS-014802	5/16/2023	5/16/2024	3	Bottle Filler	In hallway adjacent to room A-308	WF-05162023-014802	11/4/2023	FT-FY24-10102023-014802-A	<1	FT-FY24-10102023-014802-B	<1
WS-014803	5/16/2023	5/16/2024	3	Cooler	In hallway adjacent to room A-308 High Left	WF-05162023-014803	11/4/2023	FT-FY24-10102023-014803-A	<1	FT-FY24-10102023-014803-B	<1
WS-014804	5/16/2023	5/16/2024	3	Cooler	In hallway adjacent to room A-308 Low Right	WF-05162023-014804	11/4/2023	FT-FY24-10102023-014804-A	<1	FT-FY24-10102023-014804-B	<1
WS-014809	5/16/2023	5/16/2024	2	Cooler	In hallway across from elevator and room 216 High Left	WF-05162023-014809	11/4/2023	FT-FY24-10102023-014809-A	<1	FT-FY24-10102023-014809-B	<1
WS-014810	5/16/2023	5/16/2024	2	Cooler	In hallway across from elevator and room 216 Low Right	WF-05162023-014810	11/4/2023	FT-FY24-10102023-014810-A	<1	FT-FY24-10102023-014810-B	<1
WS-014815	5/16/2023	5/16/2024	2	Break Room	In room H-203	WF-05162023-014815	11/4/2023	FT-FY24-10102023-014815-A	<1	FT-FY24-10102023-014815-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014754	12/21/2022	12/21/2023	Basement	Food Prep Sink	In kitchen second clockwise from entry	WF-12212022-014754	11/4/2023	FT-FY24-10102023-014754-A	1.7	FT-FY24-10102023-014754-B	<1