Hyde-Addison ES Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014730	9/16/2025	9/16/2026	1	Combo Faucet	In room H-100 classroom	WF-09162025-014730	11/10/2025	FT-FY26-09302025-014730-A	<2	FT-FY26-09302025-014730-B	<2
WS-014750	4/28/2025	4/28/2026	Basement	Bottle Filler	In room 001 gym/cafeteria	WF-04282025-014750	11/10/2025	FT-FY26-09302025-014750-A	<2	FT-FY26-09302025-014750-B	<2
WS-014751	4/28/2025	4/28/2026	Basement	Cooler	In room 001 gym/cafeteria High Left	WF-04282025-014751	11/10/2025	FT-FY26-09302025-014751-A	<2	FT-FY26-09302025-014751-B	<2
WS-014752	4/28/2025	4/28/2026	Basement	Cooler	In room 001 gym/cafeteria Low Right	WF-04282025-014752	11/10/2025	FT-FY26-09302025-014752-A	<2	FT-FY26-09302025-014752-B	<2
WS-014761	4/28/2025	4/28/2026	Basement	Bottle Filler	In mezzanine over looking the gym adjacent to 015	WF-04282025-014761	11/10/2025	FT-FY26-09302025-014761-A	<2	FT-FY26-09302025-014761-B	<2
WS-014762	4/28/2025	4/28/2026	Basement	Cooler	In mezzanine over looking the gym adjacent to 015 High Left	WF-04282025-014762	11/10/2025	FT-FY26-09302025-014762-A	<2	FT-FY26-09302025-014762-B	<2
WS-014763	4/28/2025	4/28/2026	Basement	Cooler	In mezzanine over looking the gym adjacent to 015 Low Right	WF-04282025-014763	11/10/2025	FT-FY26-09302025-014763-A	<2	FT-FY26-09302025-014763-B	<2
WS-014764	4/28/2025	4/28/2026	1	Health Suite	In room 112 health suite	WF-04282025-014764	11/10/2025	FT-FY26-09302025-014764-A	<2	FT-FY26-09302025-014764-B	<2
WS-014766	4/28/2025	4/28/2026	Basement	Combo Fountain	In room H-008 instruction coach	WF-04282025-014766	11/10/2025	FT-FY26-09302025-014766-A	<2	FT-FY26-09302025-014766-B	<2
WS-014767	9/16/2025	9/16/2026	Basement	Combo Faucet	In room H-005 classroom	WF-09162025-014767	11/10/2025	FT-FY26-09302025-014767-A	<2	FT-FY26-09302025-014767-B	<2
WS-014768	4/28/2025	4/28/2026	Basement	Combo Fountain	In room H-005 classroom	WF-04282025-014768	11/10/2025	FT-FY26-09302025-014768-A	<2	FT-FY26-09302025-014768-B	<2
WS-014773	9/16/2025	9/16/2026	1	Combo Faucet	In room H-106 classroom	WF-09162025-014773	11/10/2025	FT-FY26-09302025-014773-A	<2	FT-FY26-09302025-014773-B	<2
WS-014774	4/28/2025	4/28/2026	1	Combo Fountain	In room H-106 classroom	WF-04282025-014774	11/10/2025	FT-FY26-09302025-014774-A	<2	FT-FY26-09302025-014774-B	<2
WS-014775	4/28/2025	4/28/2026	1	Combo Fountain	In room H-100 classroom	WF-04282025-014775	11/10/2025	FT-FY26-09302025-014775-A	<2	FT-FY26-09302025-014775-B	<2
WS-014776	9/16/2025	9/16/2026	1	Combo Faucet	In room H-102 classroom	WF-09162025-014776	11/10/2025	FT-FY26-09302025-014776-A	<2	FT-FY26-09302025-014776-B	<2
WS-014777	4/28/2025	4/28/2026	1	Combo Fountain	In room H-102 classroom	WF-04282025-014777	11/10/2025	FT-FY26-09302025-014777-A	<2	FT-FY26-09302025-014777-B	<2
WS-014778	9/16/2025	9/16/2026	1	Combo Faucet	In room H-104 classroom	WF-09162025-014778	11/10/2025	FT-FY26-09302025-014778-A	<2	FT-FY26-09302025-014778-B	<2
WS-014779	4/28/2025	4/28/2026	1	Combo Fountain	In room H-104 classroom	WF-04282025-014779	11/10/2025	FT-FY26-09302025-014779-A	<2	FT-FY26-09302025-014779-B	<2
WS-014781	4/28/2025	4/28/2026	2	Combo Fountain	In room H-207 classroom	WF-04282025-014781	11/10/2025	FT-FY26-09302025-014781-A	<2	FT-FY26-09302025-014781-B	<2
WS-014783	4/28/2025	4/28/2026	2	Combo Fountain	In room H-200 classroom	WF-04282025-014783	11/10/2025	FT-FY26-09302025-014783-A	<2	FT-FY26-09302025-014783-B	<2
WS-014784	9/16/2025	9/16/2026	2	Combo Faucet	In room H-202 classroom	WF-09162025-014784	11/10/2025	FT-FY26-09302025-014784-A	<2	FT-FY26-09302025-014784-B	<2
WS-014785	4/28/2025	4/28/2026	2	Combo Fountain	In room H-202 classroom	WF-04282025-014785	11/10/2025	FT-FY26-09302025-014785-A	<2	FT-FY26-09302025-014785-B	<2
WS-014787	4/28/2025	4/28/2026	2	Combo Fountain	In room H-205 classroom	WF-04282025-014787	11/10/2025	FT-FY26-09302025-014787-A	<2	FT-FY26-09302025-014787-B	<2
WS-014788	4/28/2025	4/28/2026	1	Bottle Filler	In lobby adjacent to 111 welcome center	WF-04282025-014788	11/10/2025	FT-FY26-09302025-014788-A	<2	FT-FY26-09302025-014788-B	<2
WS-014789	4/28/2025	4/28/2026	1	Cooler	In lobby adjacent to 111 welcome center High Left	WF-04282025-014789	11/10/2025	FT-FY26-09302025-014789-A	<2	FT-FY26-09302025-014789-B	<2
WS-014790	4/28/2025	4/28/2026	1	Cooler	In lobby adjacent to 111 welcome center Low Right	WF-04282025-014790	11/10/2025	FT-FY26-09302025-014790-A	<2	FT-FY26-09302025-014790-B	<2
WS-014791	4/28/2025	4/28/2026	1	Break Room	In room A-129 staff lounge	WF-04282025-014791	11/10/2025	FT-FY26-09302025-014791-A	<2	FT-FY26-09302025-014791-B	<2
WS-014793	4/28/2025	4/28/2026	1	Bottle Filler	In room A-125 music room	WF-04282025-014793	11/10/2025	FT-FY26-09302025-014793-A	<2	FT-FY26-09302025-014793-B	<2
WS-014794	4/28/2025	4/28/2026	1	Cooler	In room A-125 music room High Left	WF-04282025-014794	11/10/2025	FT-FY26-09302025-014794-A	<2	FT-FY26-09302025-014794-B	<2
WS-014795	4/28/2025	4/28/2026	1	Cooler	In room A-125 music room Low Right	WF-04282025-014795	11/10/2025	FT-FY26-09302025-014795-A	<2	FT-FY26-09302025-014795-B	<2
WS-014798	4/28/2025	4/28/2026	2	Cooler	In hallway adjacent to room A-218 High Left	WF-04282025-014798	11/10/2025	FT-FY26-09302025-014798-A	<2	FT-FY26-09302025-014798-B	<2
WS-014799	4/28/2025	4/28/2026	2	Cooler	In hallway adjacent to room A-218 Low Right	WF-04282025-014799	11/10/2025	FT-FY26-09302025-014799-A	<2	FT-FY26-09302025-014799-B	<2
WS-014802	4/28/2025	4/28/2026	3	Bottle Filler	In hallway adjacent to room A-308	WF-04282025-014802	11/10/2025	FT-FY26-09302025-014802-A	<2	FT-FY26-09302025-014802-B	<2
WS-014803	4/28/2025	4/28/2026	3	Cooler	In hallway adjacent to room A-308 High Left	WF-04282025-014803	11/10/2025	FT-FY26-09302025-014803-A	<2	FT-FY26-09302025-014803-B	<2

WS-014804	4/28/2025	4/28/2026	3	Cooler	In hallway adjacent to room A-308	Low	Right	WF-04282025-014804	11/10/2025	FT-FY26-09302025-014804-A	<2	FT-FY26-09302025-014804-B	<2
WS-014809	4/28/2025	4/28/2026	2	Cooler	In hallway across from elevator and room 216	High	Left	WF-04282025-014809	11/10/2025	FT-FY26-09302025-014809-A	<2	FT-FY26-09302025-014809-B	<2
WS-014810	4/28/2025	4/28/2026	2	Cooler	In hallway across from elevator and room 216	Low	Right	WF-04282025-014810	11/10/2025	FT-FY26-09302025-014810-A	<2	FT-FY26-09302025-014810-B	<2
WS-014815	4/28/2025	4/28/2026	2	Break Room	In room H-203			WF-04282025-014815	11/10/2025	FT-FY26-09302025-014815-A	<2	FT-FY26-09302025-014815-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	**Filter Installed Date**	**Filter Expiration Date**	**Floor**	**Device Type**	**Device Location**	**Water Filter's Name**	**Date Analyzed**	**1st Draw - Sample ID**	**FT Final Result - 1st Draw (ppb)**	**2nd Draw - Sample ID**	**FT Final Result - 2nd Draw (ppb)**
WS-014754	11/26/2024	11/26/2025	Basement	Food Prep Sink	In kitchen second clockwise from entry	WF-11262024-014754	11/10/2025	FT-FY26-09302025-014754-A	<2	FT-FY26-09302025-014754-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.