



Hyde-Addison ES Lead Water Test Results



FY20 Filter Test

| Less than 5ppb - Devices requiring no remediation | | | | | | | | | | | |
|---|-----------------------|------------------------|----------|----------------|---|---------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
| WS-014750 | 8/9/2019 | 8/9/2020 | Basement | Bottle Filler | In room 001 gym/cafeteria | WF-08092019-014750 | 8/20/2019 | FT-FY20-082019-014750-A | <1 | FT-FY20-082019-014750-B | <1 |
| WS-014751 | 8/9/2019 | 8/9/2020 | Basement | Cooler | In room 001 gym/cafeteria High Left | WF-08092019-014751 | 8/20/2019 | FT-FY20-082019-014751-A | <1 | FT-FY20-082019-014751-B | <1 |
| WS-014752 | 8/9/2019 | 8/9/2020 | Basement | Cooler | In room 001 gym/cafeteria Low Right | WF-08092019-014752 | 8/20/2019 | FT-FY20-082019-014752-A | <1 | FT-FY20-082019-014752-B | <1 |
| WS-014761 | 8/9/2019 | 8/9/2020 | Basement | Bottle Filler | In mezzanine over looking the gym adjacent to 015 mechanical room | WF-08092019-014761 | 8/20/2019 | FT-FY20-082019-014761-A | <1 | FT-FY20-082019-014761-B | <1 |
| WS-014762 | 8/9/2019 | 8/9/2020 | Basement | Cooler | In mezzanine over looking the gym adjacent to 015 mechanical room High Left | WF-08092019-014762 | 8/20/2019 | FT-FY20-082019-014762-A | <1 | FT-FY20-082019-014762-B | <1 |
| WS-014763 | 8/9/2019 | 8/9/2020 | Basement | Cooler | In mezzanine over looking the gym adjacent to 015 mechanical room Low Right | WF-08092019-014763 | 8/20/2019 | FT-FY20-082019-014763-A | <1 | FT-FY20-082019-014763-B | <1 |
| WS-014764 | 8/9/2019 | 8/9/2020 | 1 | Health Suite | In room 112 health suite | WF-08092019-014764 | 8/20/2019 | FT-FY20-082019-014764-A | <1 | FT-FY20-082019-014764-B | <1 |
| WS-014766 | 8/9/2019 | 8/9/2020 | Basement | Combo Fountain | In room H-008 instruction coach | WF-08092019-014766 | 8/20/2019 | FT-FY20-082019-014766-A | <1 | FT-FY20-082019-014766-B | <1 |
| WS-014767 | 8/9/2019 | 8/9/2020 | Basement | Combo Faucet | In room H-005 classroom | WF-08092019-014767 | 8/20/2019 | FT-FY20-082019-014767-A | <1 | FT-FY20-082019-014767-B | <1 |
| WS-014768 | 8/9/2019 | 8/9/2020 | Basement | Combo Fountain | In room H-005 classroom | WF-08092019-014768 | 8/20/2019 | FT-FY20-082019-014768-A | <1 | FT-FY20-082019-014768-B | <1 |
| WS-014773 | 8/9/2019 | 8/9/2020 | 1 | Combo Faucet | In room H-106 classroom | WF-08092019-014773 | 8/20/2019 | FT-FY20-082019-014773-A | <1 | FT-FY20-082019-014773-B | <1 |
| WS-014774 | 8/9/2019 | 8/9/2020 | 1 | Combo Fountain | In room H-106 classroom | WF-08092019-014774 | 8/20/2019 | FT-FY20-082019-014774-A | <1 | FT-FY20-082019-014774-B | <1 |
| WS-014775 | 8/9/2019 | 8/9/2020 | 1 | Bathroom | In room H-100 classroom in bathroom | WF-08092019-014775 | 8/20/2019 | FT-FY20-082019-014775-A | <1 | FT-FY20-082019-014775-B | <1 |
| WS-014776 | 8/9/2019 | 8/9/2020 | 1 | Combo Faucet | In room H-102 classroom | WF-08092019-014776 | 8/20/2019 | FT-FY20-082019-014776-A | <1 | FT-FY20-082019-014776-B | <1 |
| WS-014777 | 8/9/2019 | 8/9/2020 | 1 | Combo Fountain | In room H-102 classroom | WF-08092019-014777 | 8/20/2019 | FT-FY20-082019-014777-A | <1 | FT-FY20-082019-014777-B | <1 |
| WS-014778 | 8/9/2019 | 8/9/2020 | 1 | Combo Faucet | In room H-104 classroom | WF-08092019-014778 | 8/20/2019 | FT-FY20-082019-014778-A | <1 | FT-FY20-082019-014778-B | <1 |
| WS-014779 | 8/9/2019 | 8/9/2020 | 1 | Combo Fountain | In room H-104 classroom | WF-08092019-014779 | 8/20/2019 | FT-FY20-082019-014779-A | <1 | FT-FY20-082019-014779-B | <1 |
| WS-014783 | 8/9/2019 | 8/9/2020 | 2 | Combo Fountain | In room H-200 classroom | WF-08092019-014783 | 8/20/2019 | FT-FY20-082019-014783-A | <1 | FT-FY20-082019-014783-B | <1 |
| WS-014784 | 8/9/2019 | 8/9/2020 | 2 | Combo Faucet | In room H-202 classroom | WF-08092019-014784 | 8/20/2019 | FT-FY20-082019-014784-A | 4.2 | FT-FY20-082019-014784-B | <1 |
| WS-014785 | 8/9/2019 | 8/9/2020 | 2 | Combo Fountain | In room H-202 classroom | WF-08092019-014785 | 8/20/2019 | FT-FY20-082019-014785-A | <1 | FT-FY20-082019-014785-B | <1 |
| WS-014787 | 8/9/2019 | 8/9/2020 | 2 | Combo Fountain | In room H-205 classroom | WF-08092019-014787 | 8/20/2019 | FT-FY20-082019-014787-A | <1 | FT-FY20-082019-014787-B | <1 |
| WS-014788 | 8/9/2019 | 8/9/2020 | 1 | Bottle Filler | In lobby adjacent to 111 welcome center | WF-08092019-014788 | 8/20/2019 | FT-FY20-082019-014788-A | <1 | FT-FY20-082019-014788-B | <1 |
| WS-014789 | 8/9/2019 | 8/9/2020 | 1 | Cooler | In lobby adjacent to 111 welcome center High Left | WF-08092019-014789 | 8/20/2019 | FT-FY20-082019-014789-A | <1 | FT-FY20-082019-014789-B | <1 |
| WS-014790 | 8/9/2019 | 8/9/2020 | 1 | Cooler | In lobby adjacent to 111 welcome center Low Right | WF-08092019-014790 | 8/20/2019 | FT-FY20-082019-014790-A | <1 | FT-FY20-082019-014790-B | <1 |
| WS-014791 | 8/9/2019 | 8/9/2020 | 1 | Break Room | In room A-129 staff lounge | WF-08092019-014791 | 8/20/2019 | FT-FY20-082019-014791-A | <1 | FT-FY20-082019-014791-B | <1 |
| WS-014794 | 8/9/2019 | 8/9/2020 | 1 | Cooler | In room A-125 music room High Left | WF-08092019-014794 | 8/20/2019 | FT-FY20-082019-014794-A | <1 | FT-FY20-082019-014794-B | <1 |
| WS-014795 | 8/9/2019 | 8/9/2020 | 1 | Cooler | In room A-125 music room Low Right | WF-08092019-014795 | 8/20/2019 | FT-FY20-082019-014795-A | <1 | FT-FY20-082019-014795-B | <1 |
| WS-014798 | 8/9/2019 | 8/9/2020 | 2 | Cooler | In hallway adjacent to room A-218 High Left | WF-08092019-014798 | 8/20/2019 | FT-FY20-082019-014798-A | <1 | FT-FY20-082019-014798-B | <1 |
| WS-014799 | 8/9/2019 | 8/9/2020 | 2 | Cooler | In hallway adjacent to room A-218 Low Right | WF-08092019-014799 | 8/20/2019 | FT-FY20-082019-014799-A | <1 | FT-FY20-082019-014799-B | <1 |
| WS-014802 | 8/9/2019 | 8/9/2020 | 3 | Bottle Filler | In hallway adjacent to room A-308 | WF-08092019-014802 | 8/20/2019 | FT-FY20-082019-014802-A | <1 | FT-FY20-082019-014802-B | <1 |
| WS-014803 | 8/9/2019 | 8/9/2020 | 3 | Cooler | In hallway adjacent to room A-308 High Left | WF-08092019-014803 | 8/20/2019 | FT-FY20-082019-014803-A | <1 | FT-FY20-082019-014803-B | <1 |
| WS-014804 | 8/9/2019 | 8/9/2020 | 3 | Cooler | In hallway adjacent to room A-308 Low Right | WF-08092019-014804 | 8/20/2019 | FT-FY20-082019-014804-A | <1 | FT-FY20-082019-014804-B | <1 |
| WS-014809 | 8/9/2019 | 8/9/2020 | 2 | Cooler | In hallway across from elevator and room 216 High Left | WF-08092019-014809 | 8/20/2019 | FT-FY20-082019-014809-A | <1 | FT-FY20-082019-014809-B | <1 |
| WS-014810 | 8/9/2019 | 8/9/2020 | 2 | Cooler | In hallway across from elevator and room 216 Low Right | WF-08092019-014810 | 8/20/2019 | FT-FY20-082019-014810-A | <1 | FT-FY20-082019-014810-B | <1 |

Food Prep Sink

| Less than 5ppb - Devices requiring no remediation | | | | | | | | | | | |
|---|-----------------------|------------------------|-------|-------------|-----------------|---------------------|---------------|----------------------|----------------------------------|----------------------|----------------------------------|
| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |

| | | | | | | | | | | | |
|-----------|----------|----------|----------|----------------|--|--------------------|-----------|-------------------------|----|-------------------------|----|
| WS-014754 | 8/9/2019 | 8/9/2020 | Basement | Food Prep Sink | In kitchen second clockwise from entry | WF-08092019-014754 | 8/20/2019 | FT-FY20-082019-014754-A | <1 | FT-FY20-082019-014754-B | <1 |
|-----------|----------|----------|----------|----------------|--|--------------------|-----------|-------------------------|----|-------------------------|----|