



Ida B. Wells Middle School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015155	4/21/2021	4/21/2022	1	Cooler	In hallway adjacent to 139K restroom High Left	WF-04212021-015155	2/28/2022	FT-FY22-02032022-015155-A	<1	FT-FY22-02032022-015155-B	<1
WS-015156	4/21/2021	4/21/2022	1	Cooler	In hallway adjacent to 139K restroom Low Right	WF-04212021-015156	2/28/2022	FT-FY22-02032022-015156-A	<1	FT-FY22-02032022-015156-B	<1
WS-015157	4/21/2021	4/21/2022	1	Cooler	In hallway adjacent to 138 dining (south side) High Left	WF-04212021-015157	2/28/2022	FT-FY22-02032022-015157-A	<1	FT-FY22-02032022-015157-B	<1
WS-015158	4/21/2021	4/21/2022	1	Cooler	In hallway adjacent to 138 dining (south side) Low Right	WF-04212021-015158	2/28/2022	FT-FY22-02032022-015158-A	<1	FT-FY22-02032022-015158-B	<1
WS-015160	4/21/2021	4/21/2022	1	Health Suite	In room 147A	WF-04212021-015160	2/28/2022	FT-FY22-02032022-015160-A	<1	FT-FY22-02032022-015160-B	<1
WS-015226	4/21/2021	4/21/2022	2	Cooler	In hallway adjacent 241 High Left	WF-04212021-015226	2/28/2022	FT-FY22-02032022-015226-A	<1	FT-FY22-02032022-015226-B	<1
WS-015227	4/21/2021	4/21/2022	2	Cooler	In hallway adjacent 241 Low Right	WF-04212021-015227	2/28/2022	FT-FY22-02032022-015227-A	<1	FT-FY22-02032022-015227-B	<1
WS-015236	4/21/2021	4/21/2022	2	Break Room	In room 257	WF-04212021-015236	2/28/2022	FT-FY22-02032022-015236-A	<1	FT-FY22-02032022-015236-B	<1
WS-015266	4/21/2021	4/21/2022	3	Cooler	In room 343	WF-04212021-015266	2/28/2022	FT-FY22-02032022-015266-A	<1	FT-FY22-02032022-015266-B	<1
WS-015267	4/21/2021	4/21/2022	3	Cooler	In hallway adjacent to 345 High Left	WF-04212021-015267	2/28/2022	FT-FY22-02032022-015267-A	<1	FT-FY22-02032022-015267-B	<1
WS-015268	4/21/2021	4/21/2022	3	Cooler	In hallway adjacent to 345 Low Right	WF-04212021-015268	2/28/2022	FT-FY22-02032022-015268-A	<1	FT-FY22-02032022-015268-B	<1
WS-015277	4/21/2021	4/21/2022	3	Break Room	In room 363	WF-04212021-015277	2/28/2022	FT-FY22-02032022-015277-A	<1	FT-FY22-02032022-015277-B	<1
WS-015288	4/21/2021	4/21/2022	4	Cooler	In hallway adjacent to 443 High Left	WF-04212021-015288	2/28/2022	FT-FY22-02032022-015288-A	<1	FT-FY22-02032022-015288-B	<1
WS-015289	4/21/2021	4/21/2022	4	Cooler	In hallway adjacent to 443 Low Right	WF-04212021-015289	2/28/2022	FT-FY22-02032022-015289-A	<1	FT-FY22-02032022-015289-B	<1
WS-015290	4/21/2021	4/21/2022	4	Break Room	In room 461	WF-04212021-015290	2/28/2022	FT-FY22-02032022-015290-A	<1	FT-FY22-02032022-015290-B	<1