



# Ida B Wells Middle School Lead in Water Test Results

## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015155	5/19/2020	5/19/2021	1	Cooler	In hallway adjacent to 139K restroom High Left	WF-05192020-015155	4/5/2021	FT-FY21-032021-015155-A	<1	FT-FY21-032021-015155-B	<1
WS-015156	5/19/2020	5/19/2021	1	Cooler	In hallway adjacent to 139K restroom Low Right	WF-05192020-015156	4/5/2021	FT-FY21-032021-015156-A	<1	FT-FY21-032021-015156-B	<1
WS-015157	5/19/2020	5/19/2021	1	Cooler	In hallway adjacent to 138 dining (south side) High Left	WF-05192020-015157	4/5/2021	FT-FY21-032021-015157-A	<1	FT-FY21-032021-015157-B	<1
WS-015158	5/19/2020	5/19/2021	1	Cooler	In hallway adjacent to 138 dining (south side) Low Right	WF-05192020-015158	4/5/2021	FT-FY21-032021-015158-A	<1	FT-FY21-032021-015158-B	<1
WS-015160	5/19/2020	5/19/2021	1	Health Suite	In room 147A	WF-05192020-015160	4/5/2021	FT-FY21-032021-015160-A	<1	FT-FY21-032021-015160-B	<1
WS-015226	5/19/2020	5/19/2021	2	Cooler	In hallway adjacent 241 High Left	WF-05192020-015226	4/5/2021	FT-FY21-032021-015226-A	<1	FT-FY21-032021-015226-B	<1
WS-015227	5/19/2020	5/19/2021	2	Cooler	In hallway adjacent 241 Low Right	WF-05192020-015227	4/5/2021	FT-FY21-032021-015227-A	<1	FT-FY21-032021-015227-B	<1
WS-015236	7/14/2020	7/14/2021	2	Break Room	In room 257	WF-07142020-015236	4/5/2021	FT-FY21-032021-015236-A	<1	FT-FY21-032021-015236-B	<1
WS-015266	5/19/2020	5/19/2021	3	Cooler	In room 343	WF-05192020-015266	4/5/2021	FT-FY21-032021-015266-A	<1	FT-FY21-032021-015266-B	<1
WS-015267	5/19/2020	5/19/2021	3	Cooler	In hallway adjacent to 345 High Left	WF-05192020-015267	4/5/2021	FT-FY21-032021-015267-A	<1	FT-FY21-032021-015267-B	<1
WS-015268	5/19/2020	5/19/2021	3	Cooler	In hallway adjacent to 345 Low Right	WF-05192020-015268	4/5/2021	FT-FY21-032021-015268-A	<1	FT-FY21-032021-015268-B	<1
WS-015277	5/19/2020	5/19/2021	3	Break Room	In room 363	WF-05192020-015277	4/5/2021	FT-FY21-032021-015277-A	<1	FT-FY21-032021-015277-B	<1
WS-015288	5/19/2020	5/19/2021	4	Cooler	In hallway adjacent to 443 High Left	WF-05192020-015288	4/5/2021	FT-FY21-032021-015288-A	<1	FT-FY21-032021-015288-B	<1
WS-015289	5/19/2020	5/19/2021	4	Cooler	In hallway adjacent to 443 Low Right	WF-05192020-015289	4/5/2021	FT-FY21-032021-015289-A	<1	FT-FY21-032021-015289-B	<1
WS-015290	5/19/2020	5/19/2021	4	Break Room	In room 461	WF-05192020-015290	4/5/2021	FT-FY21-032021-015290-A	1.3	FT-FY21-032021-015290-B	<1