



INCARCERATED YOUTH LEAD WATER TEST RESULTS



| | Building Location: Building Name | RECORD ID | Date Analyzed | Floor | Device Type | Device Location | 1st Draw - Sample ID | Final Result - 1st Draw (ug/L) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ug/L) |
|---|----------------------------------|------------|---------------|--------------|-------------|-----------------------------------------|----------------------|--------------------------------|----------------------|--------------------------------|
| 1 | Incarcerated Youth Program | WS- 005498 | 8/17/2016 | Ground Floor | Cooler | In day room across from cell C4-223 | FT-82016-005498-A | < 1 | FT-82016-005498-B | < 1 |
| 2 | Incarcerated Youth Program | WS- 005500 | 8/17/2016 | 2 | Cooler | In hallway adjacent to restroom C4A-135 | FT-82016-005500-A | < 1 | FT-82016-005500-B | < 1 |