



Incarcerated Youth Program Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005498	1/29/2019	1/29/2020	Ground Floor	Cooler	In day room across from cell C4-223	WF-01292019-005498	2/4/2019	FT-FY19-012019-005498-A	<1	FT-FY19-012019-005498-B	<1
WS- 005500	1/29/2019	1/29/2020	2	Cooler	In hallway adjacent to restroom C4A-135	WF-01292019-005500	2/4/2019	FT-FY19-012019-005500-A	<1	FT-FY19-012019-005500-B	<1