





OUC Radio Sites UPS Battery Replacement Project PR-009853 (PASS RK234426)

Site Name	Service Address	UPS System	Battery Type	Manufacturer	Replacement Quantity	Description of Battery to be replaced	Battery Installation Date	Certification Requirement	Notes
UDC	4200 Connecticut Av, NW, Bldg 41	(1) Mitsubishi 1100A with 24 batteries per cabinet	Model 12HX300-FR	Enersys	24	 <p>Enersys Model 12HX300-FR</p>	2016	Mitsubishi UPS certified	Individual Batteries installed in large UPS cabinets. Scope also requires removal & proper disposal of old batteries.
Rhode Island	1700 Rhode Island Av, NW	(1) Mitsubishi 1100A with 24 batteries per cabinet	Model 12HX300-FR	Enersys	24	 <p>Enersys Model 12HX300-FR</p>	2016	Mitsubishi UPS certified	Individual Batteries installed in large UPS cabinets. Scope also requires removal & proper disposal of old batteries.
GWU Hospital	22nd & I Street, NW	(1) Mitsubishi 1100A with 24 batteries per cabinet	Model 12HX300-FR	Enersys	24	 <p>Enersys Model 12HX300-FR</p>	2016	Mitsubishi UPS certified	Individual Batteries installed in large UPS cabinets. Scope also requires removal & proper disposal of old batteries.
Fletcher Johnson	4650 Benning Rd, SE	(1) Mitsubishi 1100A with 24 batteries per cabinet	Model 12HX300-FR	Enersys	24	 <p>Enersys Model 12HX300-FR</p>	2016	Mitsubishi UPS certified	Individual Batteries installed in large UPS cabinets. Scope also requires removal & proper disposal of old batteries.