## DOES EQUIPMENT AND INVENTORY LIST

	Building Plumbing Information			
Domestic Service	4" Diameter			
Fire Service	8" Diameter			
	Building HVAC Information			
Cooling Towers	CT-1 560 gpm, CT-2 560 gpm, CT-3 450 gpm			
Heat Exchangers	HT-1 @ 1110 gpm, HT-2 g 375 gpm			
Fuel Oil Tank	500 gallons above ground tank - PI Parking Garage level			
Centrifugal Chillers	CH-1 and CH-2 @ 260 tons each			
Packaged AC Units	PAC-1 & PAC-2 @ 20 tons each			
Heat Recovery Unit (HRU)				
	Ruilding Flactrical Information			
Incoming Service 4,000 amp and 3,000 amp dual service				
medining Service	(4) 5" Dia. Conduit Ductbank — 2 active, 2 spare			
Generator	500 KW			
Ochei atoi	500 KVA			
	Fuel - #2 fuel oil (500 Gallon Tank, Located on PI Garage Level)			
	Building Elevator Information			
Electrical Geared Traction	Elevator #1 — Capacity 3500 lbs.			
Electrical Geared Traction	Elevator #1 — Capacity 3500 lbs.  Elevator #2 — Capacity 3500 lbs.			
	Elevator #3 — Capacity 3500 lbs.  Elevator #3 — Capacity 3500 lbs.			
	Elevator #4 — Capacity 3500 lbs.			
	Elevator #5 — Capacity 3500 lbs.			
	Elevator #6 — Capacity 3500 lbs.			
Hydraulic	Elevator #7 — Garage to 1 <sup>st</sup> Floor — Capacity 3500 lbs.			
Automotic Dielen	Building Life Safety Information (202) 727-9256			
Automatic Dialer				
	Building Parking Information			
WMATA Parking	107 Spaces			
P2 Parking Garage	11 Spaces			
P1 Parking Garage	78 Spaces			
<b>Building Specialty Items Information</b>				
Green Roof	24,000 sq. ft., Plant Material: Sedum			
District Key Cabinet	Security Office or DRES Building Manager's Office			
Main Foyer Ceiling	For re-lamping purposes the main foyer ceiling is approximately 25 feet			
-	in height.			
Building Area Calculations Information				
P2 Parking Garage	5720 square feet, 11 Spaces			
P1 Parking Garage	46448 square feet, 89 Spaces			
Floor 1, Office and Retail	43567 square feet			
Floor 2, Office	43960 square feet			
Floor 3, Office	46391 square feet			
Floor 4, Office	46502 square feet			

## **Warranty Agreements Information**

In addition to requirements written in Section C.5, the Contractor shall avoid actions, which would invalidate a warranty, unless it was brought to the attention of the COTR, and written direction to proceed irrespective of the warranty consequences was provided by the COTR. The Facility being newly constructed, most equipment and systems are covered under manufacture warranties. The Offeror shall review the information below and take this information into consideration when preparing and submitting their Proposal. Therefore, the systems and equipment covered under warranty may negate the need(s) for maintenance and repair services and will require a deduction in the contract price for the specific subcontractor fees for maintenance or repair of the following equipment and or systems:

<b>Specification/ Section</b>	Description	Warranty Period	Spare
			Parts
02240	Dewartering	N/A	N/A
06400	Architechtural Woodwork		N/A
07130	Sheet Membrane Waterproofing		N/A
07165	Cementitious Waterproofing	Not less than 10 years from	N/A
		acceptance	
07166	Crystalline Waterproofing	Minimum of 2 years	N/A
07620	Sheet Metal Flashing and Trim		N/A
07840	Firestopping		N/A
10100	Visual Display Boards		N/A
10650	Folding Panel Partitions	2 years	N/A
11450	Residential Appliances		N/A
12481	Foot Grilles	2 years	N/A
15170	Variable Speed Pumping	24 months after shipment or	N/A
	System	18 months after start-up	
15365	Fire Detection and FM-2	No less than 1 year	N/A
15780	Unitary Air Conditioning	5-year compressor parts	
16200	Emergency Generator Set	5-years for 1,500 hours of	Avail.
16423	Switchboards	5-year for authorized repair	
16721	Fire Alarm System	Controls equipment — 3-	
		years, materials, installation	
16770	Public Address System		N/A

However, the Contractor shall have primary responsibility for warranty management. The Contractor may assume compliance with warranties for purposes of assessing the Contractor's costs and risks under this Contract, assuming the Contractor is diligent in managing warranties and reporting nonperformance to the COTR.