

Department of Motor Vehicles Equipment/Inventory List
REVISED

Project Name/Address: DC Dept. of Motor Vehicles Southwest Service Center, 95 M St., SW, Washington, DC 20024						
Mechanical Equipment List						
Equipment Type/ Use	Model Name/No.	Serial No.	Manufacturer Name	Capacity/Rating	Installation Date	Comments
Chiller	30HXA096RYE661KA	2808Q16153	Carrier	96 Ton	2009	R-134a refrigerant
Chiller	30HXA096RYE661KA	2808Q16154	Carrier	96 Ton	2009	R-134a refrigerant
Air cooled condenser	09DK-094-601	2808Q26197	Carrier	90 Ton	2009	Rooftop
Air cooled condenser	09DK-094-601	3008Q26271	Carrier	90 Ton	2009	Rooftop
Air handler Unit #1	39AC C91922	66090802	Carrier	9 Ton	Assumed 1968	2n floor, 3rd floor halls
Air handler Unit #2	39MN10C010FW012XGS	2908U20174	Carrier	10 Ton	2009	1st floor Customer Service Area
Air handler Unit #3	39W7 769	66110267 VL	Carrier	7 Ton	Assumed 1968	1st Floor
Air handler Unit #4	39AC5 029TH1	66090256	Carrier	5 Ton	Assumed 1968	2nd, 3rd floor
Air handler Unit #5	39MN06C010FW122XGS	2908U20177	Carrier	6 Ton	2009	Mail room
Air handler Unit #6	39MN08C010FW212XGS	2908U20178	Carrier	8 Ton	2009	Training room
Rooftop Unit	TSC048A3R0A27D	637100245L	Trane	4 Ton	2006	R-22 Refrigerant; Electric heat
Boiler	28HE-8	28HE-8-116108	Smith	Input 2403 MBH Output 1985 MBH	2011	Natural Gas Fired
BAS	I/Net Seven	7530	Schneider Electric	N/A	2012	
Return Air Fan	402	DB510P3	Peerless	16,600 CFM	Assumed 1968	
Split System Condenser	N/A	N/A	Mitsubishi	N/A	N/A	2nd floor, East side
Unit Heaters	Style 400	T06A01483	Trane	N/A		Vertical cabinet
Fire Alarm Control Panel	MS-9600	N/A	Fire-Lite Alarms, Inc.	N/A	Assumed 2005	Addressable
Hydraulic Elevator Pump	RP180D40	25313	Dover	40 HP	Assumed 1968	
Hydraulic Elevator	N/A	N/A	Otis	2,500 LB, 100 FPM	Assumed 1968	Four stop, refurbished in 2010
Self-Contained	VS028ADA0E1656A	C09J8E0316	Liebert	8 Ton	2009	IT server room, 3rd floor
Condensing Unit	TCDV205-A	0943C24091	Liebert	205,000 BTU's	2009	Rooftop
Heat Pump	C-12-234	2.24429E+14	Comfort Star	230V, 1PH	N/A	Room301
Heat Pump	C-18-234	7.10282E+13	Comfort Star	230V, 1PH	N/A	Room 302
Heat Pump	CHP009CA-2B	2.28378E+14	Comfort Star	115V, 1PH 9,000/10,000 Btu/h	N/A	Room 201
Air Handling Unit	BCE3M36C00NA1P-1	6013G228727	N/A	36,000 Btu/h	2013	Room206
Main Service Disconnect Switch	N/A	N/A	Cutler-Hammer	800A; 480V; 3PH, 4W	Assumed 1968	
Main Dist. Panel - A	CDP23-4L800	AH-8L6878	Cutler-Hammer	800A; 277/480V, 3PH, 4W	Assumed 1968	
Main Dist. Panel - B	CDP25-4L800	AH-8L6880	Cutler-Hammer	800A; 120/208V; 3PH, 4W	Assumed 1968	
Dry-Type Transformer	H	X48164	Sorgel Electric Co.	200 kVA; 480 to 208Y/120 V	Assumed 1968	Three phase insulated
Dry-Type Transformer	H-115	X47470-9	Sorgel Electric Co.	15 kVA; 480 to 208Y/120 V	Assumed 1968	Three phase insulated