



# J.O. WILSON ES LEAD WATER TEST RESULTS



## Initial Filter Test After Installation

Greater than 1 ppb - Devices Shut Off and Corrective Action Taken											
	Building Location: Building Name	Water Source ID	Date Analyzed	Floor	Device Type	Device Location		1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	J.O. WILSON ELEMENTARY SCHOOL	WS- 001906	1/11/2017	1	Combo Faucet	In classroom 108	Right	FT-112016-001906-A	4.7	FT-112016-001906-B	< 1
2	J.O. WILSON ELEMENTARY SCHOOL	WS- 001910	1/11/2017	1	Combo Faucet	In classroom 112	Right	FT-112016-001910-A	7	FT-112016-001910-B	< 1
3	J.O. WILSON ELEMENTARY SCHOOL	WS- 001912	1/11/2017	1	Combo Faucet	In classroom 111	Right	FT-112016-001912-A	6.4	FT-112016-001912-B	< 1
4	J.O. WILSON ELEMENTARY SCHOOL	WS- 001914	1/11/2017	1	Combo Faucet	In classroom 110	Right	FT-112016-001914-A	5.5	FT-112016-001914-B	< 1
5	J.O. WILSON ELEMENTARY SCHOOL	WS- 001919	1/11/2017	1	Classroom Faucet	In classroom 121 in left wing	Left	FT-112016-001919-A	2.9	FT-112016-001919-B	< 1
6	J.O. WILSON ELEMENTARY SCHOOL	WS- 001921	1/11/2017	1	Combo Faucet	In classroom 121 in left wing	Right	FT-112016-001921-A	3	FT-112016-001921-B	< 1
7	J.O. WILSON ELEMENTARY SCHOOL	WS- 001922	1/11/2017	1	Classroom Faucet	In classroom 121 in right wing	Right	FT-112016-001922-A	4.6	FT-112016-001922-B	< 1
8	J.O. WILSON ELEMENTARY SCHOOL	WS- 001923	1/11/2017	1	Combo Faucet	In classroom 121 in right wing	Left	FT-112016-001923-A	9.6	FT-112016-001923-B	< 1
9	J.O. WILSON ELEMENTARY SCHOOL	WS- 001928	1/11/2017	2	Classroom Faucet	In classroom 222	Left	FT-112016-001928-A	2.3	FT-112016-001928-B	< 1
10	J.O. WILSON ELEMENTARY SCHOOL	WS- 001929	1/11/2017	2	Combo Faucet	In classroom 222	Right	FT-112016-001929-A	3.6	FT-112016-001929-B	< 1
11	J.O. WILSON ELEMENTARY SCHOOL	WS- 001933	1/11/2017	2	Classroom Faucet	In classroom 221		FT-112016-001933-A	2.2	FT-112016-001933-B	< 1
12	J.O. WILSON ELEMENTARY SCHOOL	WS- 001935	1/11/2017	2	Combo Faucet	In classroom 221	Right	FT-112016-001935-A	3.7	FT-112016-001935-B	< 1
13	J.O. WILSON ELEMENTARY SCHOOL	WS- 001936	1/11/2017	2	Combo Faucet	In classroom 220	Right	FT-112016-001936-A	3.2	FT-112016-001936-B	< 1
14	J.O. WILSON ELEMENTARY SCHOOL	WS- 001937	1/11/2017	2	Classroom Faucet	In classroom 220	Left	FT-112016-001937-A	5.7	FT-112016-001937-B	< 1
15	J.O. WILSON ELEMENTARY SCHOOL	WS- 001950	1/11/2017	1	Combo Faucet	In classroom 109	Right	FT-112016-001950-A	4.4	FT-112016-001950-B	< 1

## First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

Less than 1 ppb - Device Returned to Service											
1	J.O. WILSON ELEMENTARY SCHOOL	WS- 001923	2/8/2017	1	Combo Faucet	In classroom 121 in right wing	Left	FT-112016-001923-A	< 1	FT-112016-001923-B	< 1

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation											
1	J.O. WILSON ELEMENTARY SCHOOL	WS- 001906	2/8/2017	1	Combo Faucet	In classroom 108	Right	FT-112016-001906-A	3.3	FT-112016-001906-B	< 1
2	J.O. WILSON ELEMENTARY SCHOOL	WS- 001910	2/8/2017	1	Combo Faucet	In classroom 112	Right	FT-112016-001910-A	7.5	FT-112016-001910-B	< 1
3	J.O. WILSON ELEMENTARY SCHOOL	WS- 001912	2/8/2017	1	Combo Faucet	In classroom 111	Right	FT-112016-001912-A	7	FT-112016-001912-B	< 1
4	J.O. WILSON ELEMENTARY SCHOOL	WS- 001914	2/8/2017	1	Combo Faucet	In classroom 110	Right	FT-112016-001914-A	7.3	FT-112016-001914-B	< 1
5	J.O. WILSON ELEMENTARY SCHOOL	WS- 001919	2/8/2017	1	Classroom Faucet	In classroom 121 in left wing	Left	FT-112016-001919-A	2.9	FT-112016-001919-B	< 1
6	J.O. WILSON ELEMENTARY SCHOOL	WS- 001921	2/8/2017	1	Combo Faucet	In classroom 121 in left wing	Right	FT-112016-001921-A	7	FT-112016-001921-B	< 1
7	J.O. WILSON ELEMENTARY SCHOOL	WS- 001922	2/8/2017	1	Classroom Faucet	In classroom 121 in right wing	Right	FT-112016-001922-A	2.7	FT-112016-001922-B	< 1
8	J.O. WILSON ELEMENTARY SCHOOL	WS- 001928	2/8/2017	2	Classroom Faucet	In classroom 222	Left	FT-112016-001928-A	4.8	FT-112016-001928-B	< 1
9	J.O. WILSON ELEMENTARY SCHOOL	WS- 001929	2/8/2017	2	Combo Faucet	In classroom 222	Right	FT-112016-001929-A	3.8	FT-112016-001929-B	< 1
10	J.O. WILSON ELEMENTARY SCHOOL	WS- 001933	2/8/2017	2	Classroom Faucet	In classroom 221		FT-112016-001933-A	2.5	FT-112016-001933-B	< 1
11	J.O. WILSON ELEMENTARY SCHOOL	WS- 001935	2/8/2017	2	Combo Faucet	In classroom 221	Right	FT-112016-001935-A	3.9	FT-112016-001935-B	< 1
12	J.O. WILSON ELEMENTARY SCHOOL	WS- 001936	2/8/2017	2	Combo Faucet	In classroom 220	Right	FT-112016-001936-A	3.3	FT-112016-001936-B	< 1
13	J.O. WILSON ELEMENTARY SCHOOL	WS- 001937	2/8/2017	2	Classroom Faucet	In classroom 220	Left	FT-112016-001937-A	4.1	FT-112016-001937-B	< 1
14	J.O. WILSON ELEMENTARY SCHOOL	WS- 001950	2/8/2017	1	Combo Faucet	In classroom 109	Right	FT-112016-001950-A	5.2	FT-112016-001950-B	< 1

## Second Filter Re-Test (After Device Replacement)

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation											
1	J.O. WILSON ELEMENTARY SCHOOL	WS- 001906	3/8/2017	1	Combo Faucet	In classroom 108	Right	FT-112016-001906-A	4.8	FT-112016-001906-B	< 1
2	J.O. WILSON ELEMENTARY SCHOOL	WS- 001910	3/8/2017	1	Combo Faucet	In classroom 112	Right	FT-112016-001910-A	4.7	FT-112016-001910-B	< 1
3	J.O. WILSON ELEMENTARY SCHOOL	WS- 001912	3/8/2017	1	Combo Faucet	In classroom 111	Right	FT-112016-001912-A	4.4	FT-112016-001912-B	< 1
4	J.O. WILSON ELEMENTARY SCHOOL	WS- 001914	3/8/2017	1	Combo Faucet	In classroom 110	Right	FT-112016-001914-A	2.2	FT-112016-001914-B	< 1
5	J.O. WILSON ELEMENTARY SCHOOL	WS- 001919	3/8/2017	1	Classroom Faucet	In classroom 121 in left wing	Left	FT-112016-001919-A	3.3	FT-112016-001919-B	< 1
6	J.O. WILSON ELEMENTARY SCHOOL	WS- 001921	3/8/2017	1	Combo Faucet	In classroom 121 in left wing	Right	FT-112016-001921-A	9.9	FT-112016-001921-B	< 1
7	J.O. WILSON ELEMENTARY SCHOOL	WS- 001922	3/8/2017	1	Classroom Faucet	In classroom 121 in right wing	Right	FT-112016-001922-A	12	FT-112016-001922-B	< 1
8	J.O. WILSON ELEMENTARY SCHOOL	WS- 001928	3/8/2017	2	Classroom Faucet	In classroom 222	Left	FT-112016-001928-A	150	FT-112016-001928-B	< 1
9	J.O. WILSON ELEMENTARY SCHOOL	WS- 001929	3/8/2017	2	Combo Faucet	In classroom 222	Right	FT-112016-001929-A	11	FT-112016-001929-B	< 1
10	J.O. WILSON ELEMENTARY SCHOOL	WS- 001933	3/8/2017	2	Classroom Faucet	In classroom 221		FT-112016-001933-A	11	FT-112016-001933-B	< 1
11	J.O. WILSON ELEMENTARY SCHOOL	WS- 001935	3/8/2017	2	Combo Faucet	In classroom 221	Right	FT-112016-001935-A	22	FT-112016-001935-B	< 1
12	J.O. WILSON ELEMENTARY SCHOOL	WS- 001936	3/8/2017	2	Combo Faucet	In classroom 220	Right	FT-112016-001936-A	5.2	FT-112016-001936-B	< 1
13	J.O. WILSON ELEMENTARY SCHOOL	WS- 001937	3/8/2017	2	Classroom Faucet	In classroom 220	Left	FT-112016-001937-A	17	FT-112016-001937-B	< 1
14	J.O. WILSON ELEMENTARY SCHOOL	WS- 001950	3/8/2017	1	Combo Faucet	In classroom 109	Right	FT-112016-001950-A	1.9	FT-112016-001950-B	< 1

## Filter Re-Test (Post Consultation; After Dual Supply Faucet Installation)

Less than 5 ppb - Devices Returned to Service											
1	J.O. WILSON ELEMENTARY SCHOOL	WS- 001906	5/18/2017	1	Combo Faucet	In classroom 108	Right	FT-112016-001906-A	< 1	FT-112016-001906-B	< 1
2	J.O. WILSON ELEMENTARY SCHOOL	WS- 001910	4/27/2017	1	Combo Faucet	In classroom 112	Right	FT-112016-001910-A	< 1	FT-112016-001910-B	< 1
3	J.O. WILSON ELEMENTARY SCHOOL	WS- 001912	5/18/2017	1	Combo Faucet	In classroom 111	Right	FT-112016-001912-A	< 1	FT-112016-001912-B	< 1
4	J.O. WILSON ELEMENTARY SCHOOL	WS- 001914	5/18/2017	1	Combo Faucet	In classroom 110	Right	FT-112016-001914-A	< 1	FT-112016-001914-B	< 1
5	J.O. WILSON ELEMENTARY SCHOOL	WS- 001919	7/17/2017	1	Classroom Faucet	In classroom 121 in left wing	Left	FT-112016-001919-A	1	FT-112016-001919-B	< 1
6	J.O. WILSON ELEMENTARY SCHOOL	WS- 001921	7/17/2017	1	Combo Faucet	In classroom 121 in left wing	Right	FT-112016-001921-A	< 1	FT-112016-001921-B	< 1
7	J.O. WILSON ELEMENTARY SCHOOL	WS- 001922	7/17/2017	1	Classroom Faucet	In classroom 121 in right wing	Right	FT-112016-001922-A	< 1	FT-112016-001922-B	< 1
8	J.O. WILSON ELEMENTARY SCHOOL	WS- 001928	5/18/2017	2	Classroom Faucet	In classroom 222	Left	FT-112016-001928-A	< 1	FT-112016-001928-B	< 1
9	J.O. WILSON ELEMENTARY SCHOOL	WS- 001929	5/18/2017	2	Combo Faucet	In classroom 222	Right	FT-112016-001929-A	< 1	FT-112016-001929-B	< 1
10	J.O. WILSON ELEMENTARY SCHOOL	WS- 001933	5/18/2017	2	Classroom Faucet	In classroom 221		FT-112016-001933-A	< 1	FT-112016-001933-B	< 1
11	J.O. WILSON ELEMENTARY SCHOOL	WS- 001935	5/18/2017	2	Combo Faucet	In classroom 221	Right	FT-112016-001935-A	< 1	FT-112016-001935-B	< 1
12	J.O. WILSON ELEMENTARY SCHOOL	WS- 001936	5/18/2017	2	Combo Faucet	In classroom 220	Right	FT-112016-001936-A	< 1	FT-112016-001936-B	< 1
13	J.O. WILSON ELEMENTARY SCHOOL	WS- 001937	5/18/2017	2	Classroom Faucet	In classroom 220	Left	FT-112016-001937-A	< 1	FT-112016-001937-B	< 1
14	J.O. WILSON ELEMENTARY SCHOOL	WS- 001950	5/18/2017	1	Combo Faucet	In classroom 109	Right	FT-112016-001950-A	< 1	FT-112016-001950-B	< 1