



J.O. Wilson Elementary School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-001903	2/16/2023	2/16/2024	1	Cooler	In multi-purpose room	WF-02162023-001903	12/20/2023	FT-FY24-11012023-001903-A	<1	FT-FY24-11012023-001903-B	<1	
WS-001905	2/16/2023	2/16/2024	1	Health Suite	In health suite 118	WF-02162023-001905	12/20/2023	FT-FY24-11012023-001905-A	<1	FT-FY24-11012023-001905-B	<1	
WS-001906	8/9/2023	8/9/2024	1	Combo Faucet	In classroom 108	Right	WF-08092023-001906	12/20/2023	FT-FY24-11012023-001906-A	<1	FT-FY24-11012023-001906-B	<1
WS-001907	2/16/2023	2/16/2024	1	Combo Fountain	In classroom 108	Left	WF-02162023-001907	12/20/2023	FT-FY24-11012023-001907-A	<1	FT-FY24-11012023-001907-B	<1
WS-001908	2/16/2023	2/16/2024	1	Cooler	In hallway adjacent to room 114	WF-02162023-001908	12/20/2023	FT-FY24-11012023-001908-A	<1	FT-FY24-11012023-001908-B	<1	
WS-001909	2/16/2023	2/16/2024	1	Combo Fountain	In classroom 112	Left	WF-02162023-001909	12/20/2023	FT-FY24-11012023-001909-A	<1	FT-FY24-11012023-001909-B	<1
WS-001910	8/9/2023	8/9/2024	1	Combo Faucet	In classroom 112	Right	WF-08092023-001910	12/20/2023	FT-FY24-11012023-001910-A	<1	FT-FY24-11012023-001910-B	<1
WS-001911	2/16/2023	2/16/2024	1	Combo Fountain	In classroom 111	Left	WF-02162023-001911	12/20/2023	FT-FY24-11012023-001911-A	<1	FT-FY24-11012023-001911-B	<1
WS-001912	8/9/2023	8/9/2024	1	Combo Faucet	In classroom 111	Right	WF-08092023-001912	12/20/2023	FT-FY24-11012023-001912-A	<1	FT-FY24-11012023-001912-B	<1
WS-001913	2/16/2023	2/16/2024	1	Combo Fountain	In classroom 110	Left	WF-02162023-001913	12/20/2023	FT-FY24-11012023-001913-A	<1	FT-FY24-11012023-001913-B	<1
WS-001914	8/9/2023	8/9/2024	1	Combo Faucet	In classroom 110	Right	WF-08092023-001914	12/20/2023	FT-FY24-11012023-001914-A	<1	FT-FY24-11012023-001914-B	<1
WS-001915	2/16/2023	2/16/2024	1	Cooler	In hallway adjacent to south stairwell	WF-02162023-001915	12/20/2023	FT-FY24-11012023-001915-A	<1	FT-FY24-11012023-001915-B	<1	
WS-001916	2/16/2023	2/16/2024	1	Cooler	In hallway adjacent to custodian's office	WF-02162023-001916	12/20/2023	FT-FY24-11012023-001916-A	<1	FT-FY24-11012023-001916-B	<1	
WS-001917	2/16/2023	2/16/2024	2	Cooler	In hallway adjacent to north stairwell	WF-02162023-001917	12/20/2023	FT-FY24-11012023-001917-A	<1	FT-FY24-11012023-001917-B	<1	
WS-001918	2/16/2023	2/16/2024	1	Cooler	In hallway adjacent to room 121	WF-02162023-001918	12/20/2023	FT-FY24-11012023-001918-A	<1	FT-FY24-11012023-001918-B	<1	
WS-001919	8/9/2023	8/9/2024	1	Classroom Faucet	In classroom 121 in left wing	Left	WF-08092023-001919	12/20/2023	FT-FY24-11012023-001919-A	<1	FT-FY24-11012023-001919-B	<1
WS-001920	2/16/2023	2/16/2024	1	Combo Fountain	In classroom 121 in left wing	WF-02162023-001920	12/20/2023	FT-FY24-11012023-001920-A	<1	FT-FY24-11012023-001920-B	<1	
WS-001921	8/9/2023	8/9/2024	1	Combo Faucet	In classroom 121 in left wing	Right	WF-08092023-001921	12/20/2023	FT-FY24-11012023-001921-A	<1	FT-FY24-11012023-001921-B	<1
WS-001922	8/9/2023	8/9/2024	1	Classroom Faucet	In classroom 121 in right wing	Right	WF-08092023-001922	12/20/2023	FT-FY24-11012023-001922-A	<1	FT-FY24-11012023-001922-B	<1
WS-001923	8/9/2023	8/9/2024	1	Combo Faucet	In classroom 121 in right wing	Left	WF-08092023-001923	12/20/2023	FT-FY24-11012023-001923-A	<1	FT-FY24-11012023-001923-B	<1
WS-001924	2/16/2023	2/16/2024	1	Combo Fountain	In classroom 121 in right wing	WF-02162023-001924	12/20/2023	FT-FY24-11012023-001924-A	<1	FT-FY24-11012023-001924-B	<1	
WS-001926	8/9/2023	8/9/2024	2	Cooler	In hallway adjacent to server room	WF-08092023-001926	12/20/2023	FT-FY24-11012023-001926-A	<1	FT-FY24-11012023-001926-B	<1	
WS-001927	2/16/2023	2/16/2024	2	Cooler	In hallway adjacent to room 220	WF-02162023-001927	12/20/2023	FT-FY24-11012023-001927-A	<1	FT-FY24-11012023-001927-B	<1	
WS-001929	8/9/2023	8/9/2024	2	Combo Faucet	In classroom 222	Right	WF-08092023-001929	12/20/2023	FT-FY24-11012023-001929-A	<1	FT-FY24-11012023-001929-B	<1
WS-001930	2/16/2023	2/16/2024	2	Combo Fountain	In classroom 222	WF-02162023-001930	12/20/2023	FT-FY24-11012023-001930-A	<1	FT-FY24-11012023-001930-B	<1	
WS-001933	8/9/2023	8/9/2024	2	Classroom Faucet	In classroom 221	WF-08092023-001933	12/20/2023	FT-FY24-11012023-001933-A	<1	FT-FY24-11012023-001933-B	<1	
WS-001934	2/16/2023	2/16/2024	2	Combo Fountain	In classroom 221	Left	WF-02162023-001934	12/20/2023	FT-FY24-11012023-001934-A	<1	FT-FY24-11012023-001934-B	<1
WS-001935	8/9/2023	8/9/2024	2	Combo Faucet	In classroom 221	Right	WF-08092023-001935	12/20/2023	FT-FY24-11012023-001935-A	<1	FT-FY24-11012023-001935-B	<1
WS-001936	8/9/2023	8/9/2024	2	Combo Faucet	In classroom 220	Right	WF-08092023-001936	12/20/2023	FT-FY24-11012023-001936-A	<1	FT-FY24-11012023-001936-B	<1
WS-001937	8/9/2023	8/9/2024	2	Classroom Faucet	In classroom 220	Left	WF-08092023-001937	12/20/2023	FT-FY24-11012023-001937-A	<1	FT-FY24-11012023-001937-B	<1
WS-001938	2/16/2023	2/16/2024	2	Combo Fountain	In classroom 220	WF-02162023-001938	12/20/2023	FT-FY24-11012023-001938-A	<1	FT-FY24-11012023-001938-B	<1	
WS-001939	2/16/2023	2/16/2024	2	Cooler	In hallway adjacent to room 214	WF-02162023-001939	12/20/2023	FT-FY24-11012023-001939-A	<1	FT-FY24-11012023-001939-B	<1	
WS-001940	2/16/2023	2/16/2024	2	Cooler	In hallway adjacent to south stairwell	WF-02162023-001940	12/20/2023	FT-FY24-11012023-001940-A	<1	FT-FY24-11012023-001940-B	<1	
WS-001942	2/16/2023	2/16/2024	3	Cooler	In hallway adjacent to room 312	WF-02162023-001942	12/20/2023	FT-FY24-11012023-001942-A	<1	FT-FY24-11012023-001942-B	<1	
WS-001943	2/16/2023	2/16/2024	3	Cooler	In hallway adjacent to north stairwell	WF-02162023-001943	12/20/2023	FT-FY24-11012023-001943-A	<1	FT-FY24-11012023-001943-B	<1	

WS- 001944	2/16/2023	2/16/2024	3	Cooler	In hallway adjacent to room 329		WF-02162023-001944	12/20/2023	FT-FY24-11012023-001944-A	<1	FT-FY24-11012023-001944-B	<1
WS- 001947	2/16/2023	2/16/2024	3	Cooler	In hallway adjacent to room 328		WF-02162023-001947	12/20/2023	FT-FY24-11012023-001947-A	<1	FT-FY24-11012023-001947-B	<1
WS- 001948	2/16/2023	2/16/2024	3	Cooler	In classroom 322		WF-02162023-001948	12/20/2023	FT-FY24-11012023-001948-A	<1	FT-FY24-11012023-001948-B	<1
WS- 001949	2/16/2023	2/16/2024	1	Combo Fountain	In classroom 109	Left	WF-02162023-001949	12/20/2023	FT-FY24-11012023-001949-A	<1	FT-FY24-11012023-001949-B	<1
WS- 001950	8/9/2023	8/9/2024	1	Combo Faucet	In classroom 109	Right	WF-08092023-001950	12/20/2023	FT-FY24-11012023-001950-A	<1	FT-FY24-11012023-001950-B	<1
WS- 007182	2/16/2023	2/16/2024	1	Bottle Filler	In hallway adjacent to main lobby		WF-02162023-007182	12/20/2023	FT-FY24-11012023-007182-A	<1	FT-FY24-11012023-007182-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001901	1/17/2023	1/17/2024	1	Food Prep Sink	In kitchen second clockwise from entry door	Right	WF-01172023-001901	12/20/2023	FT-FY24-11012023-001901-A	<1	FT-FY24-11012023-001901-B	<1