



J.O. Wilson Elementary School Lead in Water Test Results



FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001903	3/10/2020	3/10/2021	1	Cooler	In multi-purpose room	WF-03102020-001903	1/29/2021	FT-FY21-012021-001903-A	<1	FT-FY21-012021-001903-B	<1
WS- 001904	3/10/2020	3/10/2021	1	Cooler	In hallway adjacent to main lobby	WF-03102020-001904	1/29/2021	FT-FY21-012021-001904-A	<1	FT-FY21-012021-001904-B	<1
WS- 001905	3/10/2020	3/10/2021	1	Health Suite	In health suite 118	WF-03102020-001905	1/29/2021	FT-FY21-012021-001905-A	<1	FT-FY21-012021-001905-B	<1
WS- 001906	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 108	WF-09012020-001906	1/29/2021	FT-FY21-012021-001906-A	<1	FT-FY21-012021-001906-B	<1
WS- 001907	3/10/2020	3/10/2021	1	Combo Fountain	In classroom 108	WF-03102020-001907	1/29/2021	FT-FY21-012021-001907-A	<1	FT-FY21-012021-001907-B	<1
WS- 001908	3/10/2020	3/10/2021	1	Cooler	In hallway adjacent to room 114	WF-03102020-001908	1/29/2021	FT-FY21-012021-001908-A	<1	FT-FY21-012021-001908-B	<1
WS- 001909	3/10/2020	3/10/2021	1	Combo Fountain	In classroom 112	WF-03102020-001909	1/29/2021	FT-FY21-012021-001909-A	<1	FT-FY21-012021-001909-B	<1
WS- 001910	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 112	WF-09012020-001910	1/29/2021	FT-FY21-012021-001910-A	<1	FT-FY21-012021-001910-B	<1
WS- 001911	3/10/2020	3/10/2021	1	Combo Fountain	In classroom 111	WF-03102020-001911	1/29/2021	FT-FY21-012021-001911-A	<1	FT-FY21-012021-001911-B	<1
WS- 001912	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 111	WF-09012020-001912	1/29/2021	FT-FY21-012021-001912-A	<1	FT-FY21-012021-001912-B	<1
WS- 001913	3/10/2020	3/10/2021	1	Combo Fountain	In classroom 110	WF-03102020-001913	1/29/2021	FT-FY21-012021-001913-A	1.5	FT-FY21-012021-001913-B	<1
WS- 001914	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 110	WF-09012020-001914	1/29/2021	FT-FY21-012021-001914-A	<1	FT-FY21-012021-001914-B	<1
WS- 001915	3/10/2020	3/10/2021	1	Cooler	In hallway adjacent to south stairwell	WF-03102020-001915	1/29/2021	FT-FY21-012021-001915-A	<1	FT-FY21-012021-001915-B	<1
WS- 001916	3/10/2020	3/10/2021	1	Cooler	In hallway adjacent to custodian's office	WF-03102020-001916	1/29/2021	FT-FY21-012021-001916-A	<1	FT-FY21-012021-001916-B	<1
WS- 001917	3/10/2020	3/10/2021	2	Cooler	In hallway adjacent to north stairwell	WF-03102020-001917	1/29/2021	FT-FY21-012021-001917-A	<1	FT-FY21-012021-001917-B	<1
WS- 001918	3/10/2020	3/10/2021	1	Cooler	In hallway adjacent to room 121	WF-03102020-001918	1/29/2021	FT-FY21-012021-001918-A	<1	FT-FY21-012021-001918-B	<1
WS- 001919	9/1/2020	9/1/2021	1	Classroom Faucet	In classroom 121 in left wing	WF-09012020-001919	1/29/2021	FT-FY21-012021-001919-A	<1	FT-FY21-012021-001919-B	<1
WS- 001920	3/10/2020	3/10/2021	1	Combo Fountain	In classroom 121 in left wing	WF-03102020-001920	1/29/2021	FT-FY21-012021-001920-A	<1	FT-FY21-012021-001920-B	<1
WS- 001921	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 121 in left wing	WF-09012020-001921	1/29/2021	FT-FY21-012021-001921-A	<1	FT-FY21-012021-001921-B	<1
WS- 001922	9/1/2020	9/1/2021	1	Classroom Faucet	In classroom 121 in right wing	WF-09012020-001922	1/29/2021	FT-FY21-012021-001922-A	<1	FT-FY21-012021-001922-B	<1
WS- 001923	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 121 in right wing	WF-09012020-001923	1/29/2021	FT-FY21-012021-001923-A	<1	FT-FY21-012021-001923-B	<1
WS- 001924	3/10/2020	3/10/2021	1	Combo Fountain	In classroom 121 in right wing	WF-03102020-001924	1/29/2021	FT-FY21-012021-001924-A	<1	FT-FY21-012021-001924-B	<1
WS- 001926	3/10/2020	3/10/2021	2	Cooler	In hallway adjacent to server room	WF-03102020-001926	1/29/2021	FT-FY21-012021-001926-A	<1	FT-FY21-012021-001926-B	<1
WS- 001927	3/10/2020	3/10/2021	2	Cooler	In hallway adjacent to room 220	WF-03102020-001927	1/29/2021	FT-FY21-012021-001927-A	<1	FT-FY21-012021-001927-B	<1
WS- 001928	9/1/2020	9/1/2021	2	Classroom Faucet	In classroom 222	WF-09012020-001928	1/29/2021	FT-FY21-012021-001928-A	<1	FT-FY21-012021-001928-B	<1
WS- 001929	9/1/2020	9/1/2021	2	Combo Faucet	In classroom 222	WF-09012020-001929	1/29/2021	FT-FY21-012021-001929-A	<1	FT-FY21-012021-001929-B	<1
WS- 001930	3/10/2020	3/10/2021	2	Combo Fountain	In classroom 222	WF-03102020-001930	1/29/2021	FT-FY21-012021-001930-A	<1	FT-FY21-012021-001930-B	<1
WS- 001931	3/10/2020	3/10/2021	2	Cooler	In classroom 222	WF-03102020-001931	1/29/2021	FT-FY21-012021-001931-A	<1	FT-FY21-012021-001931-B	<1
WS- 001932	3/10/2020	3/10/2021	2	Cooler	In classroom 221	WF-03102020-001932	1/29/2021	FT-FY21-012021-001932-A	<1	FT-FY21-012021-001932-B	<1
WS- 001933	9/1/2020	9/1/2021	2	Classroom Faucet	In classroom 221	WF-09012020-001933	1/29/2021	FT-FY21-012021-001933-A	<1	FT-FY21-012021-001933-B	<1
WS- 001934	3/10/2020	3/10/2021	2	Combo Fountain	In classroom 221	WF-03102020-001934	1/29/2021	FT-FY21-012021-001934-A	<1	FT-FY21-012021-001934-B	<1
WS- 001935	9/1/2020	9/1/2021	2	Combo Faucet	In classroom 221	WF-09012020-001935	1/29/2021	FT-FY21-012021-001935-A	<1	FT-FY21-012021-001935-B	<1
WS- 001936	9/1/2020	9/1/2021	2	Combo Faucet	In classroom 220	WF-09012020-001936	1/29/2021	FT-FY21-012021-001936-A	<1	FT-FY21-012021-001936-B	<1

WS- 001937	9/1/2020	9/1/2021	2	Classroom Faucet	In classroom 220	Left	WF-09012020-001937	1/29/2021	FT-FY21-012021-001937-A	<1	FT-FY21-012021-001937-B	<1
WS- 001938	3/10/2020	3/10/2021	2	Combo Fountain	In classroom 220		WF-03102020-001938	1/29/2021	FT-FY21-012021-001938-A	<1	FT-FY21-012021-001938-B	<1
WS- 001939	3/10/2020	3/10/2021	2	Cooler	In hallway adjacent to room 214		WF-03102020-001939	1/29/2021	FT-FY21-012021-001939-A	<1	FT-FY21-012021-001939-B	<1
WS- 001940	3/10/2020	3/10/2021	2	Cooler	In hallway adjacent to south stairwell		WF-03102020-001940	1/29/2021	FT-FY21-012021-001940-A	<1	FT-FY21-012021-001940-B	<1
WS- 001941	3/10/2020	3/10/2021	3	Cooler	In hallway adjacent to south stairwell		WF-03102020-001941	1/29/2021	FT-FY21-012021-001941-A	<1	FT-FY21-012021-001941-B	<1
WS- 001942	3/10/2020	3/10/2021	3	Cooler	In hallway adjacent to room 312		WF-03102020-001942	1/29/2021	FT-FY21-012021-001942-A	<1	FT-FY21-012021-001942-B	<1
WS- 001943	3/10/2020	3/10/2021	3	Cooler	In hallway adjacent to north stairwell		WF-03102020-001943	1/29/2021	FT-FY21-012021-001943-A	<1	FT-FY21-012021-001943-B	<1
WS- 001944	3/10/2020	3/10/2021	3	Cooler	In hallway adjacent to room 329		WF-03102020-001944	1/29/2021	FT-FY21-012021-001944-A	<1	FT-FY21-012021-001944-B	<1
WS- 001945	3/10/2020	3/10/2021	3	Cooler	In hallway adjacent to staff restroom		WF-03102020-001945	1/29/2021	FT-FY21-012021-001945-A	<1	FT-FY21-012021-001945-B	<1
WS- 001947	3/10/2020	3/10/2021	3	Cooler	In hallway adjacent to room 328		WF-03102020-001947	1/29/2021	FT-FY21-012021-001947-A	<1	FT-FY21-012021-001947-B	<1
WS- 001948	3/10/2020	3/10/2021	3	Cooler	In classroom 322		WF-03102020-001948	1/29/2021	FT-FY21-012021-001948-A	<1	FT-FY21-012021-001948-B	<1
WS- 001949	3/10/2020	3/10/2021	1	Combo Fountain	In classroom 109	Left	WF-03102020-001949	1/29/2021	FT-FY21-012021-001949-A	<1	FT-FY21-012021-001949-B	<1
WS- 001950	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 109	Right	WF-09012020-001950	1/29/2021	FT-FY21-012021-001950-A	<1	FT-FY21-012021-001950-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001901	2/21/2020	2/21/2021	1	Food Prep Sink	In kitchen second clockwise from entry door	Right	WF-02212020-001901	1/29/2021	FT-FY21-012021-001901-A	<1	FT-FY21-012021-001901-B	<1