



J.O. Wilson Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 001903	2/20/2022	2/20/2023	1	Cooler	In multi-purpose room	WF-03022021-001903	3/3/2022	FT-FY22-12292021-001903-A	<1	FT-FY22-12292021-001903-B	<1	
WS- 001904	2/20/2022	2/20/2023	1	Cooler	In hallway adjacent to main lobby	WF-03022021-001904	3/3/2022	FT-FY22-12292021-001904-A	<1	FT-FY22-12292021-001904-B	<1	
WS- 001905	2/20/2022	2/20/2023	1	Health Suite	In health suite 118	WF-03022021-001905	3/3/2022	FT-FY22-12292021-001905-A	<1	FT-FY22-12292021-001905-B	<1	
WS- 001906	8/25/2021	8/25/2022	1	Combo Faucet	In classroom 108	Right	WF-08252021-001906	3/3/2022	FT-FY22-12292021-001906-A	<1	FT-FY22-12292021-001906-B	<1
WS- 001907	2/20/2022	2/20/2023	1	Combo Fountain	In classroom 108	Left	WF-03022021-001907	3/3/2022	FT-FY22-12292021-001907-A	<1	FT-FY22-12292021-001907-B	<1
WS- 001908	2/20/2022	2/20/2023	1	Cooler	In hallway adjacent to room 114	WF-03022021-001908	3/3/2022	FT-FY22-12292021-001908-A	<1	FT-FY22-12292021-001908-B	<1	
WS- 001909	2/20/2022	2/20/2023	1	Combo Fountain	In classroom 112	Left	WF-03022021-001909	3/3/2022	FT-FY22-12292021-001909-A	<1	FT-FY22-12292021-001909-B	<1
WS- 001910	8/25/2021	8/25/2022	1	Combo Faucet	In classroom 112	Right	WF-08252021-001910	3/3/2022	FT-FY22-12292021-001910-A	<1	FT-FY22-12292021-001910-B	<1
WS- 001911	7/26/2021	7/26/2022	1	Combo Fountain	In classroom 111	Left	WF-07262021-001911	3/3/2022	FT-FY22-12292021-001911-A	<1	FT-FY22-12292021-001911-B	<1
WS- 001912	8/25/2021	8/25/2022	1	Combo Faucet	In classroom 111	Right	WF-08252021-001912	3/3/2022	FT-FY22-12292021-001912-A	<1	FT-FY22-12292021-001912-B	<1
WS- 001913	2/20/2022	2/20/2023	1	Combo Fountain	In classroom 110	Left	WF-03022021-001913	3/3/2022	FT-FY22-12292021-001913-A	<1	FT-FY22-12292021-001913-B	<1
WS- 001914	8/25/2021	8/25/2022	1	Combo Faucet	In classroom 110	Right	WF-08252021-001914	3/3/2022	FT-FY22-12292021-001914-A	<1	FT-FY22-12292021-001914-B	<1
WS- 001915	2/20/2022	2/20/2023	1	Cooler	In hallway adjacent to south stairwell	WF-03022021-001915	3/3/2022	FT-FY22-12292021-001915-A	<1	FT-FY22-12292021-001915-B	<1	
WS- 001916	2/20/2022	2/20/2023	1	Cooler	In hallway adjacent to custodian's office	WF-03022021-001916	3/3/2022	FT-FY22-12292021-001916-A	<1	FT-FY22-12292021-001916-B	<1	
WS- 001917	2/20/2022	2/20/2023	2	Cooler	In hallway adjacent to north stairwell	WF-03022021-001917	3/3/2022	FT-FY22-12292021-001917-A	<1	FT-FY22-12292021-001917-B	<1	
WS- 001918	2/20/2022	2/20/2023	1	Cooler	In hallway adjacent to room 121	WF-03022021-001918	3/3/2022	FT-FY22-12292021-001918-A	<1	FT-FY22-12292021-001918-B	<1	
WS- 001919	8/25/2021	8/25/2022	1	Classroom Faucet	In classroom 121 in left wing	Left	WF-08252021-001919	3/3/2022	FT-FY22-12292021-001919-A	<1	FT-FY22-12292021-001919-B	<1
WS- 001920	2/20/2022	2/20/2023	1	Combo Fountain	In classroom 121 in left wing	WF-03022021-001920	3/3/2022	FT-FY22-12292021-001920-A	<1	FT-FY22-12292021-001920-B	<1	
WS- 001921	8/25/2021	8/25/2022	1	Combo Faucet	In classroom 121 in left wing	Right	WF-08252021-001921	3/3/2022	FT-FY22-12292021-001921-A	<1	FT-FY22-12292021-001921-B	<1
WS- 001922	8/25/2021	8/25/2022	1	Classroom Faucet	In classroom 121 in right wing	Right	WF-08252021-001922	3/3/2022	FT-FY22-12292021-001922-A	<1	FT-FY22-12292021-001922-B	<1
WS- 001923	8/25/2021	8/25/2022	1	Combo Faucet	In classroom 121 in right wing	Left	WF-08252021-001923	3/3/2022	FT-FY22-12292021-001923-A	<1	FT-FY22-12292021-001923-B	<1
WS- 001924	2/20/2022	2/20/2023	1	Combo Fountain	In classroom 121 in right wing	WF-03022021-001924	3/3/2022	FT-FY22-12292021-001924-A	<1	FT-FY22-12292021-001924-B	<1	
WS- 001926	2/20/2022	2/20/2023	2	Cooler	In hallway adjacent to server room	WF-03022021-001926	3/3/2022	FT-FY22-12292021-001926-A	<1	FT-FY22-12292021-001926-B	<1	
WS- 001927	2/20/2022	2/20/2023	2	Cooler	In hallway adjacent to room 220	WF-03022021-001927	3/3/2022	FT-FY22-12292021-001927-A	<1	FT-FY22-12292021-001927-B	<1	
WS- 001928	8/25/2021	8/25/2022	2	Classroom Faucet	In classroom 222	Left	WF-08252021-001928	3/3/2022	FT-FY22-12292021-001928-A	<1	FT-FY22-12292021-001928-B	<1
WS- 001929	8/25/2021	8/25/2022	2	Combo Faucet	In classroom 222	Right	WF-08252021-001929	3/3/2022	FT-FY22-12292021-001929-A	<1	FT-FY22-12292021-001929-B	<1
WS- 001930	2/20/2022	2/20/2023	2	Combo Fountain	In classroom 222	WF-03022021-001930	3/3/2022	FT-FY22-12292021-001930-A	<1	FT-FY22-12292021-001930-B	<1	
WS- 001931	2/20/2022	2/20/2023	2	Cooler	In classroom 222	WF-03022021-001931	3/3/2022	FT-FY22-12292021-001931-A	<1	FT-FY22-12292021-001931-B	<1	
WS- 001932	2/20/2022	2/20/2023	2	Cooler	In classroom 221	WF-03022021-001932	3/3/2022	FT-FY22-12292021-001932-A	<1	FT-FY22-12292021-001932-B	<1	
WS- 001933	8/25/2021	8/25/2022	2	Classroom Faucet	In classroom 221	WF-08252021-001933	3/3/2022	FT-FY22-12292021-001933-A	<1	FT-FY22-12292021-001933-B	<1	
WS- 001934	2/20/2022	2/20/2023	2	Combo Fountain	In classroom 221	Left	WF-03022021-001934	3/3/2022	FT-FY22-12292021-001934-A	<1	FT-FY22-12292021-001934-B	<1
WS- 001935	8/25/2021	8/25/2022	2	Combo Faucet	In classroom 221	Right	WF-08252021-001935	3/3/2022	FT-FY22-12292021-001935-A	<1	FT-FY22-12292021-001935-B	<1
WS- 001936	8/25/2021	8/25/2022	2	Combo Faucet	In classroom 220	Right	WF-08252021-001936	3/3/2022	FT-FY22-12292021-001936-A	1.2	FT-FY22-12292021-001936-B	1.0
WS- 001937	8/25/2021	8/25/2022	2	Classroom Faucet	In classroom 220	Left	WF-08252021-001937	3/3/2022	FT-FY22-12292021-001937-A	<1	FT-FY22-12292021-001937-B	<1

WS- 001938	2/20/2022	2/20/2023	2	Combo Fountain	In classroom 220		WF-03022021-001938	3/3/2022	FT-FY22-12292021-001938-A	<1	FT-FY22-12292021-001938-B	<1
WS- 001939	2/20/2022	2/20/2023	2	Cooler	In hallway adjacent to room 214		WF-03022021-001939	3/3/2022	FT-FY22-12292021-001939-A	<1	FT-FY22-12292021-001939-B	<1
WS- 001940	2/20/2022	2/20/2023	2	Cooler	In hallway adjacent to south stairwell		WF-03022021-001940	3/3/2022	FT-FY22-12292021-001940-A	<1	FT-FY22-12292021-001940-B	<1
WS- 001942	2/20/2022	2/20/2023	3	Cooler	In hallway adjacent to room 312		WF-03022021-001942	3/3/2022	FT-FY22-12292021-001942-A	<1	FT-FY22-12292021-001942-B	<1
WS- 001943	2/20/2022	2/20/2023	3	Cooler	In hallway adjacent to north stairwell		WF-03022021-001943	3/3/2022	FT-FY22-12292021-001943-A	<1	FT-FY22-12292021-001943-B	<1
WS- 001944	2/20/2022	2/20/2023	3	Cooler	In hallway adjacent to room 329		WF-03022021-001944	3/3/2022	FT-FY22-12292021-001944-A	<1	FT-FY22-12292021-001944-B	<1
WS- 001945	2/20/2022	2/20/2023	3	Cooler	In hallway adjacent to staff restroom		WF-03022021-001945	3/3/2022	FT-FY22-12292021-001945-A	<1	FT-FY22-12292021-001945-B	<1
WS- 001947	2/20/2022	2/20/2023	3	Cooler	In hallway adjacent to room 328		WF-03022021-001947	3/3/2022	FT-FY22-12292021-001947-A	<1	FT-FY22-12292021-001947-B	<1
WS- 001948	2/20/2022	2/20/2023	3	Cooler	In classroom 322		WF-03022021-001948	3/3/2022	FT-FY22-12292021-001948-A	<1	FT-FY22-12292021-001948-B	<1
WS- 001949	2/20/2022	2/20/2023	1	Combo Fountain	In classroom 109	Left	WF-03022021-001949	3/3/2022	FT-FY22-12292021-001949-A	<1	FT-FY22-12292021-001949-B	<1
WS- 001950	8/25/2021	8/25/2022	1	Combo Faucet	In classroom 109	Right	WF-08252021-001950	3/3/2022	FT-FY22-12292021-001950-A	<1	FT-FY22-12292021-001950-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001901	2/9/2022	2/9/2023	1	Food Prep Sink	In kitchen second clockwise from entry door	Right	WF-02192021-001901	3/3/2022	FT-FY22-12292021-001901-A	<1	FT-FY22-12292021-001901-B	<1