



J.O. Wilson Elementary School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 001903	2/20/2022	2/20/2023	1	Cooler	In multi-purpose room	WF-02202022-001903	12/6/2022	FT-FY23-11042022-001903-A	<1	FT-FY23-11042022-001903-B	<1	
WS- 001904	2/20/2022	2/20/2023	1	Cooler	In hallway adjacent to main lobby	WF-02202022-001904	12/6/2022	FT-FY23-11042022-001904-A	<1	FT-FY23-11042022-001904-B	<1	
WS- 001905	2/20/2022	2/20/2023	1	Health Suite	In health suite 118	WF-02202022-001905	12/6/2022	FT-FY23-11042022-001905-A	<1	FT-FY23-11042022-001905-B	1.1	
WS- 001906	8/18/2022	8/18/2023	1	Combo Faucet	In classroom 108	Right	WF-08182022-001906	12/6/2022	FT-FY23-11042022-001906-A	<1	FT-FY23-11042022-001906-B	<1
WS- 001907	2/20/2022	2/20/2023	1	Combo Fountain	In classroom 108	Left	WF-02202022-001907	12/6/2022	FT-FY23-11042022-001907-A	1.5	FT-FY23-11042022-001907-B	<1
WS- 001908	2/20/2022	2/20/2023	1	Cooler	In hallway adjacent to room 114	WF-02202022-001908	12/6/2022	FT-FY23-11042022-001908-A	<1	FT-FY23-11042022-001908-B	<1	
WS- 001911	2/20/2022	2/20/2023	1	Combo Fountain	In classroom 111	Left	WF-02202022-001911	12/6/2022	FT-FY23-11042022-001911-A	<1	FT-FY23-11042022-001911-B	<1
WS- 001912	8/18/2022	8/18/2023	1	Combo Faucet	In classroom 111	Right	WF-08182022-001912	12/6/2022	FT-FY23-11042022-001912-A	<1	FT-FY23-11042022-001912-B	<1
WS- 001913	2/20/2022	2/20/2023	1	Combo Fountain	In classroom 110	Left	WF-02202022-001913	12/6/2022	FT-FY23-11042022-001913-A	1.5	FT-FY23-11042022-001913-B	<1
WS- 001914	8/18/2022	8/18/2023	1	Combo Faucet	In classroom 110	Right	WF-08182022-001914	12/6/2022	FT-FY23-11042022-001914-A	<1	FT-FY23-11042022-001914-B	<1
WS- 001915	2/20/2022	2/20/2023	1	Cooler	In hallway adjacent to south stairwell	WF-02202022-001915	12/6/2022	FT-FY23-11042022-001915-A	<1	FT-FY23-11042022-001915-B	<1	
WS- 001917	2/20/2022	2/20/2023	2	Cooler	In hallway adjacent to north stairwell	WF-02202022-001917	12/6/2022	FT-FY23-11042022-001917-A	<1	FT-FY23-11042022-001917-B	<1	
WS- 001918	2/20/2022	2/20/2023	1	Cooler	In hallway adjacent to room 121	WF-02202022-001918	12/6/2022	FT-FY23-11042022-001918-A	<1	FT-FY23-11042022-001918-B	<1	
WS- 001919	8/18/2022	8/18/2023	1	Classroom Faucet	In classroom 121 in left wing	Left	WF-08182022-001919	12/6/2022	FT-FY23-11042022-001919-A	<1	FT-FY23-11042022-001919-B	<1
WS- 001920	2/20/2022	2/20/2023	1	Combo Fountain	In classroom 121 in left wing	WF-02202022-001920	12/6/2022	FT-FY23-11042022-001920-A	<1	FT-FY23-11042022-001920-B	1.2	
WS- 001921	8/18/2022	8/18/2023	1	Combo Faucet	In classroom 121 in left wing	Right	WF-08182022-001921	12/6/2022	FT-FY23-11042022-001921-A	<1	FT-FY23-11042022-001921-B	<1
WS- 001922	8/18/2022	8/18/2023	1	Classroom Faucet	In classroom 121 in right wing	Right	WF-08182022-001922	12/6/2022	FT-FY23-11042022-001922-A	<1	FT-FY23-11042022-001922-B	<1
WS- 001923	8/18/2022	8/18/2023	1	Combo Faucet	In classroom 121 in right wing	Left	WF-08182022-001923	12/6/2022	FT-FY23-11042022-001923-A	2.7	FT-FY23-11042022-001923-B	<1
WS- 001924	2/20/2022	2/20/2023	1	Combo Fountain	In classroom 121 in right wing	WF-02202022-001924	12/6/2022	FT-FY23-11042022-001924-A	<1	FT-FY23-11042022-001924-B	<1	
WS- 001926	2/20/2022	2/20/2023	2	Cooler	In hallway adjacent to server room	WF-02202022-001926	12/6/2022	FT-FY23-11042022-001926-A	<1	FT-FY23-11042022-001926-B	<1	
WS- 001927	2/20/2022	2/20/2023	2	Cooler	In hallway adjacent to room 220	WF-02202022-001927	12/6/2022	FT-FY23-11042022-001927-A	<1	FT-FY23-11042022-001927-B	<1	
WS- 001928	8/18/2022	8/18/2023	2	Classroom Faucet	In classroom 222	Left	WF-08182022-001928	12/6/2022	FT-FY23-11042022-001928-A	1.1	FT-FY23-11042022-001928-B	<1
WS- 001929	8/18/2022	8/18/2023	2	Combo Faucet	In classroom 222	Right	WF-08182022-001929	12/6/2022	FT-FY23-11042022-001929-A	<1	FT-FY23-11042022-001929-B	<1
WS- 001930	2/20/2022	2/20/2023	2	Combo Fountain	In classroom 222	WF-02202022-001930	12/6/2022	FT-FY23-11042022-001930-A	<1	FT-FY23-11042022-001930-B	<1	
WS- 001931	2/20/2022	2/20/2023	2	Cooler	In classroom 222	WF-02202022-001931	12/6/2022	FT-FY23-11042022-001931-A	<1	FT-FY23-11042022-001931-B	<1	
WS- 001933	8/18/2022	8/18/2023	2	Classroom Faucet	In classroom 221	WF-08182022-001933	12/6/2022	FT-FY23-11042022-001933-A	<1	FT-FY23-11042022-001933-B	<1	
WS- 001934	2/20/2022	2/20/2023	2	Combo Fountain	In classroom 221	Left	WF-02202022-001934	12/6/2022	FT-FY23-11042022-001934-A	<1	FT-FY23-11042022-001934-B	<1
WS- 001935	8/18/2022	8/18/2023	2	Combo Faucet	In classroom 221	Right	WF-08182022-001935	12/6/2022	FT-FY23-11042022-001935-A	2.5	FT-FY23-11042022-001935-B	<1
WS- 001937	8/18/2022	8/18/2023	2	Classroom Faucet	In classroom 220	Left	WF-08182022-001937	12/6/2022	FT-FY23-11042022-001937-A	2.1	FT-FY23-11042022-001937-B	<1
WS- 001938	2/20/2022	2/20/2023	2	Combo Fountain	In classroom 220	WF-02202022-001938	12/6/2022	FT-FY23-11042022-001938-A	<1	FT-FY23-11042022-001938-B	<1	
WS- 001939	2/20/2022	2/20/2023	2	Cooler	In hallway adjacent to room 214	WF-02202022-001939	12/6/2022	FT-FY23-11042022-001939-A	<1	FT-FY23-11042022-001939-B	<1	
WS- 001940	2/20/2022	2/20/2023	2	Cooler	In hallway adjacent to south stairwell	WF-02202022-001940	12/6/2022	FT-FY23-11042022-001940-A	<1	FT-FY23-11042022-001940-B	<1	
WS- 001942	2/20/2022	2/20/2023	3	Cooler	In hallway adjacent to room 312	WF-02202022-001942	12/6/2022	FT-FY23-11042022-001942-A	<1	FT-FY23-11042022-001942-B	<1	
WS- 001943	2/20/2022	2/20/2023	3	Cooler	In hallway adjacent to north stairwell	WF-02202022-001943	12/6/2022	FT-FY23-11042022-001943-A	<1	FT-FY23-11042022-001943-B	<1	
WS- 001944	2/20/2022	2/20/2023	3	Cooler	In hallway adjacent to room 329	WF-02202022-001944	12/6/2022	FT-FY23-11042022-001944-A	<1	FT-FY23-11042022-001944-B	<1	

WS-001948	2/20/2022	2/20/2023	3	Cooler	In classroom 322		WF-02202022-001948	12/6/2022	FT-FY23-11042022-001948-A	<1	FT-FY23-11042022-001948-B	<1
WS-001949	2/20/2022	2/20/2023	1	Combo Fountain	In classroom 109	Left	WF-02202022-001949	12/6/2022	FT-FY23-11042022-001949-A	<1	FT-FY23-11042022-001949-B	<1
WS-001950	8/18/2022	8/18/2023	1	Combo Faucet	In classroom 109	Right	WF-08182022-001950	12/6/2022	FT-FY23-11042022-001950-A	<1	FT-FY23-11042022-001950-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001901	2/9/2022	2/9/2023	1	Food Prep Sink	In kitchen second clockwise from entry door	Right	WF-02092022-001901	12/6/2022	FT-FY23-11042022-001901-A	<1	FT-FY23-11042022-001901-B	<1

FY23 Filter Test

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001936	8/18/2022	8/18/2023	2	Combo Faucet	In classroom 220	Right	WF-08182022-001936	12/6/2022	FT-FY23-11042022-001936-A	5.0	FT-FY23-11042022-001936-B	<1

First Re-test (After Plumbing Check)

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001936	12/9/2022	12/9/2023	2	Combo Faucet	In classroom 220	Right	WF-12092022-001936	12/30/2022	FT-FY23-12122022-001936-A	<1	FT-FY23-12122022-001936-B	<1