



JO WILSON ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	J.O. WILSON ELEMENTARY SCHOOL	WS- 001900	8/18/2016	1	Food Prep Sink	In kitchen first clockwise from entry door Left	FT-72016-001900-A	< 1	FT-72016-001900-B	< 1
2	J.O. WILSON ELEMENTARY SCHOOL	WS- 001901	8/18/2016	1	Food Prep Sink	In kitchen second clockwise from entry door Right	FT-72016-001901-A	< 1	FT-72016-001901-B	< 1
3	J.O. WILSON ELEMENTARY SCHOOL	WS- 001903	8/18/2016	1	Cooler	In multi-purpose room	FT-82016-001903-A	< 1	FT-82016-001903-B	< 1
4	J.O. WILSON ELEMENTARY SCHOOL	WS- 001904	8/18/2016	1	Cooler	In hallway adjacent to main lobby	FT-82016-001904-A	< 1	FT-82016-001904-B	< 1
5	J.O. WILSON ELEMENTARY SCHOOL	WS- 001905	8/18/2016	1	Health Suite	In health suite room 118	FT-72016-001905-A	< 1	FT-72016-001905-B	< 1
6	J.O. WILSON ELEMENTARY SCHOOL	WS- 001906	8/18/2016	1	Classroom Faucet	In classroom 108 Right	FT-82016-001906-A	< 1	FT-82016-001906-B	< 1
7	J.O. WILSON ELEMENTARY SCHOOL	WS- 001907	8/18/2016	1	Fountain	In classroom 108 Left	FT-82016-001907-A	< 1	FT-82016-001907-B	< 1
8	J.O. WILSON ELEMENTARY SCHOOL	WS- 001908	8/18/2016	1	Cooler	In hallway adjacent to room 114	FT-82016-001908-A	< 1	FT-82016-001908-B	< 1
9	J.O. WILSON ELEMENTARY SCHOOL	WS- 001909	8/18/2016	1	Fountain	In classroom 112 Left	FT-82016-001909-A	< 1	FT-82016-001909-B	< 1
10	J.O. WILSON ELEMENTARY SCHOOL	WS- 001911	8/18/2016	1	Fountain	In classroom 111 Left	FT-82016-001911-A	< 1	FT-82016-001911-B	< 1
11	J.O. WILSON ELEMENTARY SCHOOL	WS- 001913	8/18/2016	1	Fountain	In classroom 110 Left	FT-82016-001913-A	< 1	FT-82016-001913-B	< 1
12	J.O. WILSON ELEMENTARY SCHOOL	WS- 001915	8/18/2016	1	Cooler	In hallway adjacent to south stairwell	FT-82016-001915-A	< 1	FT-82016-001915-B	< 1
13	J.O. WILSON ELEMENTARY SCHOOL	WS- 001916	8/18/2016	1	Cooler	In hallway adjacent to custodian's office	FT-82016-001916-A	< 1	FT-82016-001916-B	< 1
14	J.O. WILSON ELEMENTARY SCHOOL	WS- 001917	8/18/2016	2	Cooler	In hallway adjacent to north stairwell	FT-82016-001917-A	< 1	FT-82016-001917-B	< 1
15	J.O. WILSON ELEMENTARY SCHOOL	WS- 001918	8/18/2016	1	Cooler	In hallway adjacent to room 121	FT-82016-001918-A	< 1	FT-82016-001918-B	< 1
16	J.O. WILSON ELEMENTARY SCHOOL	WS- 001920	8/18/2016	1	Fountain	In classroom 121 in left wing	FT-82016-001920-A	< 1	FT-82016-001920-B	< 1
17	J.O. WILSON ELEMENTARY SCHOOL	WS- 001924	8/18/2016	1	Fountain	In classroom 121 in right wing	FT-82016-001924-A	< 1	FT-82016-001924-B	< 1
18	J.O. WILSON ELEMENTARY SCHOOL	WS- 001926	8/18/2016	2	Cooler	In hallway adjacent to server room	FT-82016-001926-A	< 1	FT-82016-001926-B	< 1
19	J.O. WILSON ELEMENTARY SCHOOL	WS- 001927	8/18/2016	2	Cooler	In hallway adjacent to room 220	FT-82016-001927-A	< 1	FT-82016-001927-B	< 1
20	J.O. WILSON ELEMENTARY SCHOOL	WS- 001930	8/18/2016	2	Fountain	In classroom 222	FT-82016-001930-A	< 1	FT-82016-001930-B	< 1
21	J.O. WILSON ELEMENTARY SCHOOL	WS- 001931	8/18/2016	2	Cooler	In classroom 222	FT-82016-001931-A	< 1	FT-82016-001931-B	< 1
22	J.O. WILSON ELEMENTARY SCHOOL	WS- 001932	8/18/2016	2	Cooler	In classroom 221	FT-82016-001932-A	< 1	FT-82016-001932-B	< 1
23	J.O. WILSON ELEMENTARY SCHOOL	WS- 001934	8/18/2016	2	Fountain	In classroom 221 Left	FT-82016-001934-A	< 1	FT-82016-001934-B	< 1
24	J.O. WILSON ELEMENTARY SCHOOL	WS- 001936	8/18/2016	2	Classroom Faucet	In classroom 220 Right	FT-72016-001936-A	< 1	FT-72016-001936-B	< 1
25	J.O. WILSON ELEMENTARY SCHOOL	WS- 001938	8/18/2016	2	Fountain	In classroom 220	FT-82016-001938-A	< 1	FT-82016-001938-B	< 1
26	J.O. WILSON ELEMENTARY SCHOOL	WS- 001939	8/18/2016	2	Cooler	In hallway adjacent to room 214	FT-82016-001939-A	< 1	FT-82016-001939-B	< 1
27	J.O. WILSON ELEMENTARY SCHOOL	WS- 001940	8/18/2016	2	Cooler	In hallway adjacent to south stairwell	FT-82016-001940-A	< 1	FT-82016-001940-B	< 1
28	J.O. WILSON ELEMENTARY SCHOOL	WS- 001941	8/18/2016	3	Cooler	In hallway adjacent to south stairwell	FT-82016-001941-A	< 1	FT-82016-001941-B	< 1
29	J.O. WILSON ELEMENTARY SCHOOL	WS- 001942	8/18/2016	3	Cooler	In hallway adjacent to room 312	FT-82016-001942-A	< 1	FT-82016-001942-B	< 1
30	J.O. WILSON ELEMENTARY SCHOOL	WS- 001943	8/18/2016	3	Cooler	In hallway adjacent to north stairwell	FT-82016-001943-A	< 1	FT-82016-001943-B	< 1
31	J.O. WILSON ELEMENTARY SCHOOL	WS- 001944	8/18/2016	3	Cooler	In hallway adjacent to room 329	FT-82016-001944-A	< 1	FT-82016-001944-B	< 1
32	J.O. WILSON ELEMENTARY SCHOOL	WS- 001945	8/18/2016	3	Cooler	In hallway adjacent to staff restroom	FT-82016-001945-A	< 1	FT-82016-001945-B	< 1
33	J.O. WILSON ELEMENTARY SCHOOL	WS- 001947	8/18/2016	3	Cooler	In hallway adjacent to room 328	FT-82016-001947-A	< 1	FT-82016-001947-B	< 1
34	J.O. WILSON ELEMENTARY SCHOOL	WS- 001948	8/18/2016	3	Cooler	In classroom 322	FT-82016-001948-A	< 1	FT-82016-001948-B	< 1
35	J.O. WILSON ELEMENTARY SCHOOL	WS- 001949	8/18/2016	1	Fountain	In classroom 109 Left	FT-82016-001949-A	< 1	FT-82016-001949-B	< 1