



J.O. WILSON LEAD WATER TEST RESULTS

May 15, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001951	Utility	1	In janitor's closet room 114	WT-042916-1968- A	< 1	WT-042916-1968- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001950	Classroom	1	In room 109 Right	WT-042916-1967- A	< 1	WT-042916-1967- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001949	Fountain	1	In room 109 Left	WT-042916-1966- A	< 1	WT-042916-1966- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001948	Cooler	3	In room 322	WT-042916-1965- A	< 1	WT-042916-1965- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001947	Cooler	3	In hallway adjacent to room 328	WT-042916-1964- A	< 1	WT-042916-1964- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001946	Classroom	3	In library	WT-042916-1963- A	4.57	WT-042916-1963- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001945	Cooler	3	In hallway adjacent to staff bathroom	WT-042916-1962- A	< 1	WT-042916-1962- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001944	Cooler	3	In hallway adjacent to staff bathroom	WT-042916-1961- A	< 1	WT-042916-1961- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001943	Cooler	3	In hallway adjacent to north stairwell	WT-042916-1960- A	< 1	WT-042916-1960- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001942	Cooler	3	In hallway adjacent to room 312	WT-042916-1959- A	< 1	WT-042916-1959- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001941	Cooler	3	In hallway adjacent to south stairwell	WT-042916-1958- A	< 1	WT-042916-1958- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001940	Cooler	2	In hallway adjacent to south stairwell	WT-042916-1957- A	< 1	WT-042916-1957- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001939	Cooler	3	In hallway adjacent to room 214	WT-042916-1956- A	< 1	WT-042916-1956- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001938	Fountain	2	Room 223 Left	WT-042916-1955- A	< 1	WT-042916-1955- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001937	Classroom	2	In room 220	WT-042916-1954- A	9.73	WT-042916-1954- B	2.36				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001936	Classroom	2	In room 220 Right	WT-042916-1953- A	16.3	WT-042916-1953- B	1.11	Filter will be installed and then retested			
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001935	Classroom	2	In room 221	WT-042916-1952- A	2.58	WT-042916-1952- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001934	Fountain	2	In room 221 Left	WT-042916-1951- A	< 1	WT-042916-1951- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001933	Classroom	2	In room 221	WT-042916-1950- A	1.7	WT-042916-1950- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001932	Cooler	2	In room 221 adjacent to fire exit	WT-042916-1949- A	< 1	WT-042916-1949- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001931	Cooler	2	In room 222 adjacent to fire exit	WT-042916-1948- A	< 1	WT-042916-1948- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001930	Fountain	2	Room 222 Left	WT-042916-1947- A	1.1	WT-042916-1947- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001929	Classroom	2	In room 222 Right	WT-042916-1946- A	< 1	WT-042916-1946- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001928	Classroom	2	In room 222	WT-042916-1945- A	6.6	WT-042916-1945- B	4.21				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001927	Cooler	2	In hallway adjacent to room 220	WT-042916-1944- A	< 1	WT-042916-1944- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001926	Cooler	2	In hallway adjacent to server room	WT-042916-1943- A	< 1	WT-042916-1943- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001925	Classroom	1	In art room	WT-042916-1942- A	< 1	WT-042916-1942- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001924	Fountain	1	In room 121 near hallway Left	WT-042916-1941- A	< 1	WT-042916-1941- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001923	Classroom	1	In room 121 near hallway Right	WT-042916-1940- A	1.91	WT-042916-1940- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001922	Classroom	1	In room 121 near hallway Right	WT-042916-1939- A	1.71	WT-042916-1939- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001921	Classroom	1	In room 121 on wall between bathroom and hallway Right	WT-042916-1938- A	2.04	WT-042916-1938- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001920	Fountain	1	In room 121 Left	WT-042916-1937- A	1.31	WT-042916-1937- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001919	Classroom	1	In room 121 Left	WT-042916-1936- A	1.04	WT-042916-1936- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001918	Cooler	1	Adjacent to room 121	WT-042916-1935- A	1.4	WT-042916-1935- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001917	Cooler	2	In hallway adjacent to north stairwell	WT-042916-1934- A	< 1	WT-042916-1934- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001916	Cooler	1	In west hallway	WT-042916-1933- A	< 1	WT-042916-1933- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001915	Cooler	1	In hallway adjacent to south stairwell	WT-042916-1932- A	< 1	WT-042916-1932- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001914	Classroom	1	In room 110 Right	WT-042916-1931- A	< 1	WT-042916-1931- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001913	Fountain	1	In room 110 Left	WT-042916-1930- A	< 1	WT-042916-1930- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001912	Classroom	1	In room 111 Right	WT-042916-1929- A	1.05	WT-042916-1929- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001911	Fountain	1	In room 111 Left	WT-042916-1928- A	< 1	WT-042916-1928- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001910	Classroom	1	In room 112 Right	WT-042916-1927- A	< 1	WT-042916-1927- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001909	Fountain	1	In room 112 Left	WT-042916-1926- A	< 1	WT-042916-1926- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001908	Cooler	1	In hallway adjacent to room 114	WT-042916-1925- A	< 1	WT-042916-1925- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001907	Fountain	1	In room 108 Left	WT-042916-1924- A	< 1	WT-042916-1924- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001906	Classroom	1	In room 108 Right	WT-042916-1923- A	1.9	WT-042916-1923- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001905	Health Suite	1	In hallway adjacent to health suite	WT-042916-1922- A	< 1	WT-042916-1922- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001904	Cooler	1	In hallway adjacent to main lobby	WT-042916-1921- A	< 1	WT-042916-1921- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001903	Cooler	1	In all-purpose room	WT-042916-1920- A	< 1	WT-042916-1920- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001902	Kitchen	1	In kitchen adjacent to staff restroom	WT-042916-1919- A	< 1	WT-042916-1919- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001901	Kitchen	1	In kitchen on north wall Right	WT-042916-1918- A	< 1	WT-042916-1918- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001900	Kitchen	1	In kitchen on north wall sink Left	WT-042916-1917- A	< 1	WT-042916-1917- B	< 1				
J.O. WILSON ELEMENTARY SCHOOL	5/3/2016	WS-001899	Utility	Basement	In boiler room (main water source)	WT-042916-1916- A	6.77	WT-042916-1916- B	< 1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.