



# Janney ES Lead in Water Test Results



## FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-002198	4/29/2019	4/29/2020	2	Combo Fountain	In office room 212A in room 212	WF-04292019-002198	12/15/2019	FT-FY20-112019-002198-A	<1	FT-FY20-112019-002198-B	<1	
WS-002200	4/29/2019	4/29/2020	Basement	Combo Fountain	In science lab room fourth clockwise from entry door	WF-04292019-002200	12/15/2019	FT-FY20-112019-002200-A	<1	FT-FY20-112019-002200-B	<1	
WS-002203	4/29/2019	4/29/2020	Basement	Combo Fountain	In science lab room third clockwise from entry door	WF-04292019-002203	12/15/2019	FT-FY20-112019-002203-A	<1	FT-FY20-112019-002203-B	<1	
WS-002205	4/29/2019	4/29/2020	Basement	Combo Fountain	In science lab room second clockwise from entry door	WF-04292019-002205	12/15/2019	FT-FY20-112019-002205-A	<1	FT-FY20-112019-002205-B	<1	
WS-002206	10/2/2019	10/2/2020	Basement	Combo Faucet	In classroom L11	WF-10022019-002206	12/15/2019	FT-FY20-112019-002206-A	<1	FT-FY20-112019-002206-B	<1	
WS-002207	4/29/2019	4/29/2020	Basement	Combo Fountain	In classroom L11	WF-04292019-002207	12/15/2019	FT-FY20-112019-002207-A	<1	FT-FY20-112019-002207-B	<1	
WS-002209	4/29/2019	4/29/2020	Basement	Cooler	In hallway adjacent to girls' restroom	WF-04292019-002209	12/15/2019	FT-FY20-112019-002209-A	<1	FT-FY20-112019-002209-B	<1	
WS-002210	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 117	Right	WF-04292019-002210	12/15/2019	FT-FY20-112019-002210-A	<1	FT-FY20-112019-002210-B	<1
WS-002211	4/29/2019	4/29/2020	Basement	Combo Fountain	In science lab room first clockwise from entry door	Left	WF-04292019-002211	12/15/2019	FT-FY20-112019-002211-A	<1	FT-FY20-112019-002211-B	<1
WS-002212	10/2/2019	10/2/2020	1	Combo Faucet	In classroom 117	Left	WF-10022019-002212	12/15/2019	FT-FY20-112019-002212-A	<1	FT-FY20-112019-002212-B	<1
WS-002215	4/29/2019	4/29/2020	1	Cooler	In hallway adjacent to room 113	Low Right	WF-04292019-002215	12/15/2019	FT-FY20-112019-002215-A	<1	FT-FY20-112019-002215-B	<1
WS-002216	4/29/2019	4/29/2020	1	Cooler	In hallway adjacent to room 113	High Left	WF-04292019-002216	12/15/2019	FT-FY20-112019-002216-A	<1	FT-FY20-112019-002216-B	<1
WS-002217	10/2/2019	10/2/2020	1	Combo Faucet	In classroom 113	Left	WF-10022019-002217	12/15/2019	FT-FY20-112019-002217-A	<1	FT-FY20-112019-002217-B	<1
WS-002218	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 113	Right	WF-04292019-002218	12/15/2019	FT-FY20-112019-002218-A	<1	FT-FY20-112019-002218-B	<1
WS-002219	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 110	Left	WF-04292019-002219	12/15/2019	FT-FY20-112019-002219-A	<1	FT-FY20-112019-002219-B	<1
WS-002221	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 112	Left	WF-04292019-002221	12/15/2019	FT-FY20-112019-002221-A	<1	FT-FY20-112019-002221-B	<1
WS-002222	10/2/2019	10/2/2020	1	Combo Faucet	In classroom 112	Right	WF-10022019-002222	12/15/2019	FT-FY20-112019-002222-A	<1	FT-FY20-112019-002222-B	<1
WS-002223	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 110	Right	WF-04292019-002223	12/15/2019	FT-FY20-112019-002223-A	<1	FT-FY20-112019-002223-B	<1
WS-002225	4/29/2019	4/29/2020	1	Cooler	In hallway adjacent to room 110		WF-04292019-002225	12/15/2019	FT-FY20-112019-002225-A	<1	FT-FY20-112019-002225-B	<1
WS-002226	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 108	Right	WF-04292019-002226	12/15/2019	FT-FY20-112019-002226-A	<1	FT-FY20-112019-002226-B	<1
WS-002227	10/2/2019	10/2/2020	1	Combo Faucet	In classroom 108	Left	WF-10022019-002227	12/15/2019	FT-FY20-112019-002227-A	<1	FT-FY20-112019-002227-B	<1
WS-002228	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 109	Right	WF-04292019-002228	12/15/2019	FT-FY20-112019-002228-A	<1	FT-FY20-112019-002228-B	<1
WS-002229	10/2/2019	10/2/2020	1	Combo Faucet	In classroom 109	Left	WF-10022019-002229	12/15/2019	FT-FY20-112019-002229-A	<1	FT-FY20-112019-002229-B	<1
WS-002230	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 106	Right	WF-04292019-002230	12/15/2019	FT-FY20-112019-002230-A	<1	FT-FY20-112019-002230-B	<1
WS-002231	10/2/2019	10/2/2020	1	Combo Faucet	In classroom 106	Left	WF-10022019-002231	12/15/2019	FT-FY20-112019-002231-A	<1	FT-FY20-112019-002231-B	<1
WS-002232	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 107	Right	WF-04292019-002232	12/15/2019	FT-FY20-112019-002232-A	<1	FT-FY20-112019-002232-B	<1
WS-002233	10/2/2019	10/2/2020	1	Combo Faucet	In classroom 107	Left	WF-10022019-002233	12/15/2019	FT-FY20-112019-002233-A	<1	FT-FY20-112019-002233-B	<1
WS-002234	4/29/2019	4/29/2020	1	Cooler	In hallway adjacent to room 107		WF-04292019-002234	12/15/2019	FT-FY20-112019-002234-A	<1	FT-FY20-112019-002234-B	<1
WS-002235	4/29/2019	4/29/2020	1	Health Suite	In health suite		WF-04292019-002235	12/15/2019	FT-FY20-112019-002235-A	<1	FT-FY20-112019-002235-B	<1
WS-002236	4/29/2019	4/29/2020	1	Health Suite	In health suite adjacent to restroom	Left	WF-04292019-002236	12/15/2019	FT-FY20-112019-002236-A	<1	FT-FY20-112019-002236-B	<1
WS-002237	4/29/2019	4/29/2020	1	Combo Fountain	In health suite adjacent to restroom	Right	WF-04292019-002237	12/15/2019	FT-FY20-112019-002237-A	<1	FT-FY20-112019-002237-B	<1
WS-002238	4/29/2019	4/29/2020	1	Cooler	In hallway adjacent to the health suite		WF-04292019-002238	12/15/2019	FT-FY20-112019-002238-A	<1	FT-FY20-112019-002238-B	<1

WS-002242	4/29/2019	4/29/2020	2	Combo Fountain	In classroom 200	Right	WF-04292019-002242	12/15/2019	FT-FY20-112019-002242-A	<1	FT-FY20-112019-002242-B	<1
WS-002243	4/29/2019	4/29/2020	2	Combo Fountain	In classroom 201	Right	WF-04292019-002243	12/15/2019	FT-FY20-112019-002243-A	<1	FT-FY20-112019-002243-B	<1
WS-002245	4/29/2019	4/29/2020	2	Cooler	In hallway adjacent to room 202		WF-04292019-002245	12/15/2019	FT-FY20-112019-002245-A	<1	FT-FY20-112019-002245-B	<1
WS-002247	4/29/2019	4/29/2020	2	Combo Fountain	In classroom 202	Right	WF-04292019-002247	12/15/2019	FT-FY20-112019-002247-A	<1	FT-FY20-112019-002247-B	<1
WS-002249	4/29/2019	4/29/2020	2	Combo Fountain	In classroom 203	Right	WF-04292019-002249	12/15/2019	FT-FY20-112019-002249-A	<1	FT-FY20-112019-002249-B	<1
WS-002250	4/29/2019	4/29/2020	2	Cooler	In hallway adjacent to room 207		WF-04292019-002250	12/15/2019	FT-FY20-112019-002250-A	<1	FT-FY20-112019-002250-B	<1
WS-002252	4/29/2019	4/29/2020	2	Combo Fountain	In classroom 206	Right	WF-04292019-002252	12/15/2019	FT-FY20-112019-002252-A	<1	FT-FY20-112019-002252-B	<1
WS-002254	4/29/2019	4/29/2020	2	Combo Fountain	In classroom 207	Right	WF-04292019-002254	12/15/2019	FT-FY20-112019-002254-A	<1	FT-FY20-112019-002254-B	<1
WS-002256	4/29/2019	4/29/2020	2	Combo Fountain	In classroom 208	Right	WF-04292019-002256	12/15/2019	FT-FY20-112019-002256-A	<1	FT-FY20-112019-002256-B	<1
WS-002258	4/29/2019	4/29/2020	2	Combo Fountain	In classroom 209	Right	WF-04292019-002258	12/15/2019	FT-FY20-112019-002258-A	<1	FT-FY20-112019-002258-B	<1
WS-002260	4/29/2019	4/29/2020	2	Combo Fountain	In classroom 210A	Left	WF-04292019-002260	12/15/2019	FT-FY20-112019-002260-A	<1	FT-FY20-112019-002260-B	<1
WS-002261	4/29/2019	4/29/2020	2	Cooler	In hallway adjacent to room 210		WF-04292019-002261	12/15/2019	FT-FY20-112019-002261-A	<1	FT-FY20-112019-002261-B	<1
WS-002262	4/29/2019	4/29/2020	2	Combo Fountain	In staff lounge 212	Left	WF-04292019-002262	12/15/2019	FT-FY20-112019-002262-A	<1	FT-FY20-112019-002262-B	<1
WS-002263	4/29/2019	4/29/2020	2	Break Room	In staff lounge 212	Right	WF-04292019-002263	12/15/2019	FT-FY20-112019-002263-A	<1	FT-FY20-112019-002263-B	<1
WS-002265	4/29/2019	4/29/2020	2	Combo Fountain	In classroom 213	Right	WF-04292019-002265	12/15/2019	FT-FY20-112019-002265-A	<1	FT-FY20-112019-002265-B	<1
WS-002266	4/29/2019	4/29/2020	2	Break Room	In office room 212A in room 212		WF-04292019-002266	12/15/2019	FT-FY20-112019-002266-A	<1	FT-FY20-112019-002266-B	<1
WS-002267	4/29/2019	4/29/2020	3	Cooler	In hallway adjacent to room 316	Low Right	WF-04292019-002267	12/15/2019	FT-FY20-112019-002267-A	<1	FT-FY20-112019-002267-B	<1
WS-002269	4/29/2019	4/29/2020	2	Combo Fountain	In classroom 215	Right	WF-04292019-002269	12/15/2019	FT-FY20-112019-002269-A	<1	FT-FY20-112019-002269-B	<1
WS-002270	4/29/2019	4/29/2020	2	Cooler	In hallway adjacent to room 215	High Left	WF-04292019-002270	12/15/2019	FT-FY20-112019-002270-A	<1	FT-FY20-112019-002270-B	<1
WS-002271	4/29/2019	4/29/2020	2	Cooler	In hallway adjacent to room 215	Low Right	WF-04292019-002271	12/15/2019	FT-FY20-112019-002271-A	<1	FT-FY20-112019-002271-B	<1
WS-002272	4/29/2019	4/29/2020	3	Cooler	In hallway adjacent to room 316	High Left	WF-04292019-002272	12/15/2019	FT-FY20-112019-002272-A	<1	FT-FY20-112019-002272-B	<1
WS-002274	4/29/2019	4/29/2020	2	Combo Fountain	In classroom 217	Right	WF-04292019-002274	12/15/2019	FT-FY20-112019-002274-A	<1	FT-FY20-112019-002274-B	<1
WS-002276	4/29/2019	4/29/2020	3	Combo Fountain	In classroom 315	Right	WF-04292019-002276	12/15/2019	FT-FY20-112019-002276-A	<1	FT-FY20-112019-002276-B	<1
WS-002279	4/29/2019	4/29/2020	3	Combo Fountain	In classroom 308	Right	WF-04292019-002279	12/15/2019	FT-FY20-112019-002279-A	<1	FT-FY20-112019-002279-B	<1
WS-002280	4/29/2019	4/29/2020	3	Combo Fountain	In classroom 317	Right	WF-04292019-002280	12/15/2019	FT-FY20-112019-002280-A	<1	FT-FY20-112019-002280-B	<1
WS-002281	4/29/2019	4/29/2020	3	Cooler	In hallway adjacent to room 310		WF-04292019-002281	12/15/2019	FT-FY20-112019-002281-A	<1	FT-FY20-112019-002281-B	<1
WS-002282	4/29/2019	4/29/2020	3	Cooler	In hallway adjacent to room 307		WF-04292019-002282	12/15/2019	FT-FY20-112019-002282-A	<1	FT-FY20-112019-002282-B	<1
WS-002283	4/29/2019	4/29/2020	3	Combo Fountain	In classroom 307	Right	WF-04292019-002283	12/15/2019	FT-FY20-112019-002283-A	<1	FT-FY20-112019-002283-B	<1
WS-002286	4/29/2019	4/29/2020	3	Combo Fountain	In classroom 309	Right	WF-04292019-002286	12/15/2019	FT-FY20-112019-002286-A	<1	FT-FY20-112019-002286-B	<1
WS-002288	4/29/2019	4/29/2020	3	Combo Fountain	In classroom 306	Right	WF-04292019-002288	12/15/2019	FT-FY20-112019-002288-A	<1	FT-FY20-112019-002288-B	<1
WS-002289	4/29/2019	4/29/2020	3	Combo Fountain	In classroom 313		WF-04292019-002289	12/15/2019	FT-FY20-112019-002289-A	<1	FT-FY20-112019-002289-B	<1
WS-002292	4/29/2019	4/29/2020	3	Combo Fountain	In classroom 304	Right	WF-04292019-002292	12/15/2019	FT-FY20-112019-002292-A	<1	FT-FY20-112019-002292-B	<1
WS-002294	4/29/2019	4/29/2020	3	Combo Fountain	In classroom 303	Right	WF-04292019-002294	12/15/2019	FT-FY20-112019-002294-A	<1	FT-FY20-112019-002294-B	<1
WS-002295	4/29/2019	4/29/2020	3	Combo Fountain	In classroom 302	Right	WF-04292019-002295	12/15/2019	FT-FY20-112019-002295-A	<1	FT-FY20-112019-002295-B	<1
WS-002297	4/29/2019	4/29/2020	3	Cooler	In hallway adjacent to room 303		WF-04292019-002297	12/15/2019	FT-FY20-112019-002297-A	<1	FT-FY20-112019-002297-B	<1
WS-002299	4/29/2019	4/29/2020	3	Combo Fountain	In classroom 301	Right	WF-04292019-002299	12/15/2019	FT-FY20-112019-002299-A	<1	FT-FY20-112019-002299-B	<1
WS-002301	4/29/2019	4/29/2020	3	Combo Fountain	In classroom 300	Right	WF-04292019-002301	12/15/2019	FT-FY20-112019-002301-A	<1	FT-FY20-112019-002301-B	<1

**Food Prep Sink**

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002240	7/9/2019	7/9/2020	1	Food Prep Sink	In kitchen	Left	WF-07092019-002240	12/15/2019	FT-FY20-112019-002240-A	<1	FT-FY20-112019-002240-B	<1