



# Janney Elementary School Lead in Water Test Results

## FY22 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-002198	5/18/2021	5/18/2022	2	Combo Fountain	In office room 212A in room 212	WF-05182021-002198	12/4/2021	FT-FY22-11192021-002198-A	<1	FT-FY22-11192021-002198-B	<1	
WS-002200	5/18/2021	5/18/2022	Basement	Combo Fountain	In science lab room fourth clockwise from entry door	WF-05182021-002200	12/4/2021	FT-FY22-11192021-002200-A	<1	FT-FY22-11192021-002200-B	<1	
WS-002203	5/18/2021	5/18/2022	Basement	Combo Fountain	In science lab room third clockwise from entry door	WF-05182021-002203	12/4/2021	FT-FY22-11192021-002203-A	<1	FT-FY22-11192021-002203-B	<1	
WS-002205	5/18/2021	5/18/2022	Basement	Combo Fountain	In science lab room second clockwise from entry door	WF-05182021-002205	12/4/2021	FT-FY22-11192021-002205-A	<1	FT-FY22-11192021-002205-B	<1	
WS-002206	9/13/2021	9/13/2022	Basement	Combo Faucet	In classroom L11	WF-09132021-002206	12/4/2021	FT-FY22-11192021-002206-A	<1	FT-FY22-11192021-002206-B	<1	
WS-002207	5/18/2021	5/18/2022	Basement	Combo Fountain	In classroom L11	WF-05182021-002207	12/4/2021	FT-FY22-11192021-002207-A	<1	FT-FY22-11192021-002207-B	<1	
WS-002209	5/18/2021	5/18/2022	Basement	Cooler	In hallway adjacent to girls' restroom	WF-05182021-002209	12/4/2021	FT-FY22-11192021-002209-A	<1	FT-FY22-11192021-002209-B	<1	
WS-002210	5/18/2021	5/18/2022	1	Combo Fountain	In classroom 117	Right	WF-05182021-002210	12/4/2021	FT-FY22-11192021-002210-A	<1	FT-FY22-11192021-002210-B	<1
WS-002211	5/18/2021	5/18/2022	Basement	Combo Fountain	In science lab room first clockwise from entry door	Left	WF-05182021-002211	12/4/2021	FT-FY22-11192021-002211-A	<1	FT-FY22-11192021-002211-B	<1
WS-002212	9/13/2021	9/13/2022	1	Combo Faucet	In classroom 117	Left	WF-09132021-002212	12/4/2021	FT-FY22-11192021-002212-A	<1	FT-FY22-11192021-002212-B	<1
WS-002213	5/18/2021	5/18/2022	1	Combo Fountain	In classroom 115	Right	WF-05182021-002213	12/4/2021	FT-FY22-11192021-002213-A	<1	FT-FY22-11192021-002213-B	<1
WS-002214	9/13/2021	9/13/2022	1	Combo Faucet	In classroom 115	Left	WF-09132021-002214	12/4/2021	FT-FY22-11192021-002214-A	<1	FT-FY22-11192021-002214-B	<1
WS-002215	5/18/2021	5/18/2022	1	Cooler	In hallway adjacent to room 113	Low Right	WF-05182021-002215	12/4/2021	FT-FY22-11192021-002215-A	<1	FT-FY22-11192021-002215-B	<1
WS-002216	5/18/2021	5/18/2022	1	Cooler	In hallway adjacent to room 113	High Left	WF-05182021-002216	12/4/2021	FT-FY22-11192021-002216-A	<1	FT-FY22-11192021-002216-B	<1
WS-002217	9/13/2021	9/13/2022	1	Combo Faucet	In classroom 113	Left	WF-09132021-002217	12/4/2021	FT-FY22-11192021-002217-A	<1	FT-FY22-11192021-002217-B	<1
WS-002218	5/18/2021	5/18/2022	1	Combo Fountain	In classroom 113	Right	WF-05182021-002218	12/4/2021	FT-FY22-11192021-002218-A	<1	FT-FY22-11192021-002218-B	<1
WS-002219	5/18/2021	5/18/2022	1	Combo Fountain	In classroom 110	Left	WF-05182021-002219	12/4/2021	FT-FY22-11192021-002219-A	2.8	FT-FY22-11192021-002219-B	<1
WS-002221	5/18/2021	5/18/2022	1	Combo Fountain	In classroom 112	Left	WF-05182021-002221	12/4/2021	FT-FY22-11192021-002221-A	<1	FT-FY22-11192021-002221-B	<1
WS-002222	9/13/2021	9/13/2022	1	Combo Faucet	In classroom 112	Right	WF-09132021-002222	12/4/2021	FT-FY22-11192021-002222-A	<1	FT-FY22-11192021-002222-B	<1
WS-002223	5/18/2021	5/18/2022	1	Combo Fountain	In classroom 110	Right	WF-05182021-002223	12/4/2021	FT-FY22-11192021-002223-A	2.4	FT-FY22-11192021-002223-B	<1
WS-002225	5/18/2021	5/18/2022	1	Cooler	In hallway adjacent to room 110		WF-05182021-002225	12/4/2021	FT-FY22-11192021-002225-A	<1	FT-FY22-11192021-002225-B	<1
WS-002226	5/18/2021	5/18/2022	1	Combo Fountain	In classroom 108	Right	WF-05182021-002226	12/4/2021	FT-FY22-11192021-002226-A	<1	FT-FY22-11192021-002226-B	<1
WS-002227	9/13/2021	9/13/2022	1	Combo Faucet	In classroom 108	Left	WF-09132021-002227	12/4/2021	FT-FY22-11192021-002227-A	<1	FT-FY22-11192021-002227-B	<1
WS-002228	5/18/2021	5/18/2022	1	Combo Fountain	In classroom 109	Right	WF-05182021-002228	12/4/2021	FT-FY22-11192021-002228-A	<1	FT-FY22-11192021-002228-B	<1
WS-002229	9/13/2021	9/13/2022	1	Combo Faucet	In classroom 109	Left	WF-09132021-002229	12/4/2021	FT-FY22-11192021-002229-A	<1	FT-FY22-11192021-002229-B	<1
WS-002230	5/18/2021	5/18/2022	1	Combo Fountain	In classroom 106	Right	WF-05182021-002230	12/4/2021	FT-FY22-11192021-002230-A	<1	FT-FY22-11192021-002230-B	<1
WS-002231	9/13/2021	9/13/2022	1	Combo Faucet	In classroom 106	Left	WF-09132021-002231	12/4/2021	FT-FY22-11192021-002231-A	<1	FT-FY22-11192021-002231-B	<1
WS-002232	5/18/2021	5/18/2022	1	Combo Fountain	In classroom 107	Right	WF-05182021-002232	12/4/2021	FT-FY22-11192021-002232-A	1.0	FT-FY22-11192021-002232-B	<1
WS-002233	9/13/2021	9/13/2022	1	Combo Faucet	In classroom 107	Left	WF-09132021-002233	12/4/2021	FT-FY22-11192021-002233-A	<1	FT-FY22-11192021-002233-B	<1
WS-002234	5/18/2021	5/18/2022	1	Cooler	In hallway adjacent to room 107		WF-05182021-002234	12/4/2021	FT-FY22-11192021-002234-A	<1	FT-FY22-11192021-002234-B	<1
WS-002235	5/18/2021	5/18/2022	1	Health Suite	In health suite		WF-05182021-002235	12/4/2021	FT-FY22-11192021-002235-A	<1	FT-FY22-11192021-002235-B	<1
WS-002236	5/18/2021	5/18/2022	1	Health Suite	In health suite adjacent to restroom	Left	WF-05182021-002236	12/4/2021	FT-FY22-11192021-002236-A	1.0	FT-FY22-11192021-002236-B	<1
WS-002237	5/18/2021	5/18/2022	1	Combo Fountain	In health suite adjacent to restroom	Right	WF-05182021-002237	12/4/2021	FT-FY22-11192021-002237-A	<1	FT-FY22-11192021-002237-B	<1
WS-002238	5/18/2021	5/18/2022	1	Cooler	In hallway adjacent to the health suite		WF-05182021-002238	12/4/2021	FT-FY22-11192021-002238-A	<1	FT-FY22-11192021-002238-B	<1
WS-002242	5/18/2021	5/18/2022	2	Combo Fountain	In classroom 200	Right	WF-05182021-002242	12/4/2021	FT-FY22-11192021-002242-A	<1	FT-FY22-11192021-002242-B	<1
WS-002243	5/18/2021	5/18/2022	2	Combo Fountain	In classroom 201	Right	WF-05182021-002243	12/4/2021	FT-FY22-11192021-002243-A	<1	FT-FY22-11192021-002243-B	<1

WS- 002245	5/18/2021	5/18/2022	2	Cooler	In hallway adjacent to room 202		WF-05182021-002245	12/4/2021	FT-FY22-11192021-002245-A	<1	FT-FY22-11192021-002245-B	<1
WS- 002247	5/18/2021	5/18/2022	2	Combo Fountain	In classroom 202	Right	WF-05182021-002247	12/4/2021	FT-FY22-11192021-002247-A	<1	FT-FY22-11192021-002247-B	<1
WS- 002249	5/18/2021	5/18/2022	2	Combo Fountain	In classroom 203	Right	WF-05182021-002249	12/4/2021	FT-FY22-11192021-002249-A	<1	FT-FY22-11192021-002249-B	<1
WS- 002252	5/18/2021	5/18/2022	2	Combo Fountain	In classroom 206	Right	WF-05182021-002252	12/4/2021	FT-FY22-11192021-002252-A	<1	FT-FY22-11192021-002252-B	<1
WS- 002254	5/18/2021	5/18/2022	2	Combo Fountain	In classroom 207	Right	WF-05182021-002254	12/4/2021	FT-FY22-11192021-002254-A	<1	FT-FY22-11192021-002254-B	<1
WS- 002256	5/18/2021	5/18/2022	2	Combo Fountain	In classroom 208	Right	WF-05182021-002256	12/4/2021	FT-FY22-11192021-002256-A	<1	FT-FY22-11192021-002256-B	<1
WS- 002258	5/18/2021	5/18/2022	2	Combo Fountain	In classroom 209	Right	WF-05182021-002258	12/4/2021	FT-FY22-11192021-002258-A	<1	FT-FY22-11192021-002258-B	<1
WS- 002260	5/18/2021	5/18/2022	2	Combo Fountain	In classroom 210A	Left	WF-05182021-002260	12/4/2021	FT-FY22-11192021-002260-A	<1	FT-FY22-11192021-002260-B	<1
WS- 002261	5/18/2021	5/18/2022	2	Cooler	In hallway adjacent to room 210		WF-05182021-002261	12/4/2021	FT-FY22-11192021-002261-A	<1	FT-FY22-11192021-002261-B	<1
WS- 002262	5/18/2021	5/18/2022	2	Combo Fountain	In staff lounge 212	Left	WF-05182021-002262	12/4/2021	FT-FY22-11192021-002262-A	<1	FT-FY22-11192021-002262-B	<1
WS- 002263	5/18/2021	5/18/2022	2	Break Room	In staff lounge 212	Right	WF-05182021-002263	12/4/2021	FT-FY22-11192021-002263-A	<1	FT-FY22-11192021-002263-B	<1
WS- 002265	5/18/2021	5/18/2022	2	Combo Fountain	In classroom 213	Right	WF-05182021-002265	12/4/2021	FT-FY22-11192021-002265-A	<1	FT-FY22-11192021-002265-B	<1
WS- 002266	5/18/2021	5/18/2022	2	Break Room	In office room 212A in room 212		WF-05182021-002266	12/4/2021	FT-FY22-11192021-002266-A	<1	FT-FY22-11192021-002266-B	<1
WS- 002267	5/18/2021	5/18/2022	3	Cooler	In hallway adjacent to room 316	Low Right	WF-05182021-002267	12/4/2021	FT-FY22-11192021-002267-A	<1	FT-FY22-11192021-002267-B	<1
WS- 002269	5/18/2021	5/18/2022	2	Combo Fountain	In classroom 215	Right	WF-05182021-002269	12/4/2021	FT-FY22-11192021-002269-A	<1	FT-FY22-11192021-002269-B	<1
WS- 002270	5/18/2021	5/18/2022	2	Cooler	In hallway adjacent to room 215	High Left	WF-05182021-002270	12/4/2021	FT-FY22-11192021-002270-A	<1	FT-FY22-11192021-002270-B	<1
WS- 002271	5/18/2021	5/18/2022	2	Cooler	In hallway adjacent to room 215	Low Right	WF-05182021-002271	12/4/2021	FT-FY22-11192021-002271-A	<1	FT-FY22-11192021-002271-B	<1
WS- 002272	5/18/2021	5/18/2022	3	Cooler	In hallway adjacent to room 316	High Left	WF-05182021-002272	12/4/2021	FT-FY22-11192021-002272-A	<1	FT-FY22-11192021-002272-B	<1
WS- 002274	5/18/2021	5/18/2022	2	Combo Fountain	In classroom 217	Right	WF-05182021-002274	12/4/2021	FT-FY22-11192021-002274-A	<1	FT-FY22-11192021-002274-B	<1
WS- 002276	5/18/2021	5/18/2022	3	Combo Fountain	In classroom 315	Right	WF-05182021-002276	12/4/2021	FT-FY22-11192021-002276-A	<1	FT-FY22-11192021-002276-B	<1
WS- 002279	5/18/2021	5/18/2022	3	Combo Fountain	In classroom 308	Right	WF-05182021-002279	12/4/2021	FT-FY22-11192021-002279-A	<1	FT-FY22-11192021-002279-B	<1
WS- 002280	5/18/2021	5/18/2022	3	Combo Fountain	In classroom 317	Right	WF-05182021-002280	12/4/2021	FT-FY22-11192021-002280-A	<1	FT-FY22-11192021-002280-B	<1
WS- 002281	5/18/2021	5/18/2022	3	Cooler	In hallway adjacent to room 310		WF-05182021-002281	12/4/2021	FT-FY22-11192021-002281-A	<1	FT-FY22-11192021-002281-B	<1
WS- 002282	5/18/2021	5/18/2022	3	Cooler	In hallway adjacent to room 307		WF-05182021-002282	12/4/2021	FT-FY22-11192021-002282-A	<1	FT-FY22-11192021-002282-B	<1
WS- 002283	5/18/2021	5/18/2022	3	Combo Fountain	In classroom 307	Right	WF-05182021-002283	12/4/2021	FT-FY22-11192021-002283-A	<1	FT-FY22-11192021-002283-B	<1
WS- 002286	5/18/2021	5/18/2022	3	Combo Fountain	In classroom 309	Right	WF-05182021-002286	12/4/2021	FT-FY22-11192021-002286-A	<1	FT-FY22-11192021-002286-B	<1
WS- 002288	5/18/2021	5/18/2022	3	Combo Fountain	In classroom 306	Right	WF-05182021-002288	12/4/2021	FT-FY22-11192021-002288-A	<1	FT-FY22-11192021-002288-B	<1
WS- 002289	5/18/2021	5/18/2022	3	Combo Fountain	In classroom 313		WF-05182021-002289	12/4/2021	FT-FY22-11192021-002289-A	<1	FT-FY22-11192021-002289-B	<1
WS- 002292	5/18/2021	5/18/2022	3	Combo Fountain	In classroom 304	Right	WF-05182021-002292	12/4/2021	FT-FY22-11192021-002292-A	<1	FT-FY22-11192021-002292-B	<1
WS- 002294	5/18/2021	5/18/2022	3	Combo Fountain	In classroom 303	Right	WF-05182021-002294	12/4/2021	FT-FY22-11192021-002294-A	<1	FT-FY22-11192021-002294-B	<1
WS- 002295	5/18/2021	5/18/2022	3	Combo Fountain	In classroom 302	Right	WF-05182021-002295	12/4/2021	FT-FY22-11192021-002295-A	<1	FT-FY22-11192021-002295-B	<1
WS- 002297	5/18/2021	5/18/2022	3	Cooler	In hallway adjacent to room 303		WF-05182021-002297	12/4/2021	FT-FY22-11192021-002297-A	<1	FT-FY22-11192021-002297-B	<1
WS- 002299	5/18/2021	5/18/2022	3	Combo Fountain	In classroom 301	Right	WF-05182021-002299	12/4/2021	FT-FY22-11192021-002299-A	<1	FT-FY22-11192021-002299-B	<1
WS- 002301	5/18/2021	5/18/2022	3	Combo Fountain	In classroom 300	Right	WF-05182021-002301	12/4/2021	FT-FY22-11192021-002301-A	<1	FT-FY22-11192021-002301-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002240	1/25/2021	1/25/2022	1	Food Prep Sink	In kitchen	Left	WF-01252021-002240	12/4/2021	FT-FY22-11192021-002240-A	<1	FT-FY22-11192021-002240-B	<1