



Janney Elementary School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-002198	6/15/2020	6/15/2021	2	Combo Fountain	In office room 212A in room 212	WF-06152020-002198	3/7/2021	FT-FY21-022021-002198-A	<1	FT-FY21-022021-002198-B	<1	
WS-002200	6/15/2020	6/15/2021	Basement	Combo Fountain	In science lab room fourth clockwise from entry door	WF-06152020-002200	3/7/2021	FT-FY21-022021-002200-A	<1	FT-FY21-022021-002200-B	<1	
WS-002203	6/15/2020	6/15/2021	Basement	Combo Fountain	In science lab room third clockwise from entry door	WF-06152020-002203	3/7/2021	FT-FY21-022021-002203-A	<1	FT-FY21-022021-002203-B	<1	
WS-002205	6/15/2020	6/15/2021	Basement	Combo Fountain	In science lab room second clockwise from entry door	WF-06152020-002205	3/7/2021	FT-FY21-022021-002205-A	<1	FT-FY21-022021-002205-B	<1	
WS-002206	9/23/2020	9/23/2021	Basement	Combo Faucet	In classroom L11	WF-09232020-002206	3/7/2021	FT-FY21-022021-002206-A	<1	FT-FY21-022021-002206-B	<1	
WS-002207	6/15/2020	6/15/2021	Basement	Combo Fountain	In classroom L11	WF-06152020-002207	3/7/2021	FT-FY21-022021-002207-A	<1	FT-FY21-022021-002207-B	<1	
WS-002209	6/15/2020	6/15/2021	Basement	Cooler	In hallway adjacent to girls' restroom	WF-06152020-002209	3/7/2021	FT-FY21-022021-002209-A	<1	FT-FY21-022021-002209-B	<1	
WS-002210	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 117	Right	WF-06152020-002210	3/7/2021	FT-FY21-022021-002210-A	<1	FT-FY21-022021-002210-B	<1
WS-002211	6/15/2020	6/15/2021	Basement	Combo Fountain	In science lab room first clockwise from entry door	Left	WF-06152020-002211	3/7/2021	FT-FY21-022021-002211-A	<1	FT-FY21-022021-002211-B	<1
WS-002212	9/23/2020	9/23/2021	1	Combo Faucet	In classroom 117	Left	WF-09232020-002212	3/7/2021	FT-FY21-022021-002212-A	<1	FT-FY21-022021-002212-B	<1
WS-002213	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 115	Right	WF-06152020-002213	3/7/2021	FT-FY21-022021-002213-A	<1	FT-FY21-022021-002213-B	<1
WS-002214	9/23/2020	9/23/2021	1	Combo Faucet	In classroom 115	Left	WF-09232020-002214	3/7/2021	FT-FY21-022021-002214-A	<1	FT-FY21-022021-002214-B	<1
WS-002215	6/15/2020	6/15/2021	1	Cooler	In hallway adjacent to room 113	Low Right	WF-06152020-002215	3/7/2021	FT-FY21-022021-002215-A	<1	FT-FY21-022021-002215-B	<1
WS-002216	6/15/2020	6/15/2021	1	Cooler	In hallway adjacent to room 113	High Left	WF-06152020-002216	3/7/2021	FT-FY21-022021-002216-A	<1	FT-FY21-022021-002216-B	<1
WS-002217	9/23/2020	9/23/2021	1	Combo Faucet	In classroom 113	Left	WF-09232020-002217	3/7/2021	FT-FY21-022021-002217-A	<1	FT-FY21-022021-002217-B	<1
WS-002218	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 113	Right	WF-06152020-002218	3/7/2021	FT-FY21-022021-002218-A	<1	FT-FY21-022021-002218-B	<1
WS-002219	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 110	Left	WF-06152020-002219	3/7/2021	FT-FY21-022021-002219-A	<1	FT-FY21-022021-002219-B	<1
WS-002221	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 112	Left	WF-06152020-002221	3/7/2021	FT-FY21-022021-002221-A	<1	FT-FY21-022021-002221-B	<1
WS-002222	9/23/2020	9/23/2021	1	Combo Faucet	In classroom 112	Right	WF-09232020-002222	3/7/2021	FT-FY21-022021-002222-A	<1	FT-FY21-022021-002222-B	<1
WS-002223	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 110	Right	WF-06152020-002223	3/7/2021	FT-FY21-022021-002223-A	<1	FT-FY21-022021-002223-B	<1
WS-002225	6/15/2020	6/15/2021	1	Cooler	In hallway adjacent to room 110		WF-06152020-002225	3/7/2021	FT-FY21-022021-002225-A	<1	FT-FY21-022021-002225-B	<1
WS-002226	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 108	Right	WF-06152020-002226	3/7/2021	FT-FY21-022021-002226-A	<1	FT-FY21-022021-002226-B	<1
WS-002227	9/23/2020	9/23/2021	1	Combo Faucet	In classroom 108	Left	WF-09232020-002227	3/7/2021	FT-FY21-022021-002227-A	<1	FT-FY21-022021-002227-B	<1
WS-002228	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 109	Right	WF-06152020-002228	3/7/2021	FT-FY21-022021-002228-A	<1	FT-FY21-022021-002228-B	<1
WS-002229	9/23/2020	9/23/2021	1	Combo Faucet	In classroom 109	Left	WF-09232020-002229	3/7/2021	FT-FY21-022021-002229-A	<1	FT-FY21-022021-002229-B	<1
WS-002230	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 106	Right	WF-06152020-002230	3/7/2021	FT-FY21-022021-002230-A	<1	FT-FY21-022021-002230-B	<1
WS-002231	9/23/2020	9/23/2021	1	Combo Faucet	In classroom 106	Left	WF-09232020-002231	3/7/2021	FT-FY21-022021-002231-A	<1	FT-FY21-022021-002231-B	<1
WS-002232	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 107	Right	WF-06152020-002232	3/7/2021	FT-FY21-022021-002232-A	<1	FT-FY21-022021-002232-B	<1
WS-002233	9/23/2020	9/23/2021	1	Combo Faucet	In classroom 107	Left	WF-09232020-002233	3/7/2021	FT-FY21-022021-002233-A	<1	FT-FY21-022021-002233-B	<1
WS-002234	6/15/2020	6/15/2021	1	Cooler	In hallway adjacent to room 107		WF-06152020-002234	3/7/2021	FT-FY21-022021-002234-A	<1	FT-FY21-022021-002234-B	<1
WS-002235	6/15/2020	6/15/2021	1	Health Suite	In health suite		WF-06152020-002235	3/7/2021	FT-FY21-022021-002235-A	<1	FT-FY21-022021-002235-B	<1
WS-002236	6/15/2020	6/15/2021	1	Health Suite	In health suite adjacent to restroom	Left	WF-06152020-002236	3/7/2021	FT-FY21-022021-002236-A	<1	FT-FY21-022021-002236-B	<1
WS-002237	6/15/2020	6/15/2021	1	Combo Fountain	In health suite adjacent to restroom	Right	WF-06152020-002237	3/7/2021	FT-FY21-022021-002237-A	<1	FT-FY21-022021-002237-B	<1

WS-002238	6/15/2020	6/15/2021	1	Cooler	In hallway adjacent to the health suite		WF-06152020-002238	3/7/2021	FT-FY21-022021-002238-A	<1	FT-FY21-022021-002238-B	<1
WS-002242	6/15/2020	6/15/2021	2	Combo Fountain	In classroom 200	Right	WF-06152020-002242	3/7/2021	FT-FY21-022021-002242-A	<1	FT-FY21-022021-002242-B	<1
WS-002243	6/15/2020	6/15/2021	2	Combo Fountain	In classroom 201	Right	WF-06152020-002243	3/7/2021	FT-FY21-022021-002243-A	<1	FT-FY21-022021-002243-B	<1
WS-002247	6/15/2020	6/15/2021	2	Combo Fountain	In classroom 202	Right	WF-06152020-002247	3/7/2021	FT-FY21-022021-002247-A	<1	FT-FY21-022021-002247-B	<1
WS-002249	6/15/2020	6/15/2021	2	Combo Fountain	In classroom 203	Right	WF-06152020-002249	3/7/2021	FT-FY21-022021-002249-A	<1	FT-FY21-022021-002249-B	<1
WS-002250	6/15/2020	6/15/2021	2	Cooler	In hallway adjacent to room 207		WF-06152020-002250	3/7/2021	FT-FY21-022021-002250-A	<1	FT-FY21-022021-002250-B	<1
WS-002252	6/15/2020	6/15/2021	2	Combo Fountain	In classroom 206	Right	WF-06152020-002252	3/7/2021	FT-FY21-022021-002252-A	<1	FT-FY21-022021-002252-B	<1
WS-002254	6/15/2020	6/15/2021	2	Combo Fountain	In classroom 207	Right	WF-06152020-002254	3/7/2021	FT-FY21-022021-002254-A	<1	FT-FY21-022021-002254-B	<1
WS-002256	6/15/2020	6/15/2021	2	Combo Fountain	In classroom 208	Right	WF-06152020-002256	3/7/2021	FT-FY21-022021-002256-A	<1	FT-FY21-022021-002256-B	<1
WS-002258	6/15/2020	6/15/2021	2	Combo Fountain	In classroom 209	Right	WF-06152020-002258	3/7/2021	FT-FY21-022021-002258-A	<1	FT-FY21-022021-002258-B	<1
WS-002260	6/15/2020	6/15/2021	2	Combo Fountain	In classroom 210A	Left	WF-06152020-002260	3/7/2021	FT-FY21-022021-002260-A	<1	FT-FY21-022021-002260-B	<1
WS-002261	6/15/2020	6/15/2021	2	Cooler	In hallway adjacent to room 210		WF-06152020-002261	3/7/2021	FT-FY21-022021-002261-A	<1	FT-FY21-022021-002261-B	<1
WS-002262	6/15/2020	6/15/2021	2	Combo Fountain	In staff lounge 212	Left	WF-06152020-002262	3/7/2021	FT-FY21-022021-002262-A	<1	FT-FY21-022021-002262-B	<1
WS-002263	6/15/2020	6/15/2021	2	Break Room	In staff lounge 212	Right	WF-06152020-002263	3/7/2021	FT-FY21-022021-002263-A	<1	FT-FY21-022021-002263-B	<1
WS-002265	6/15/2020	6/15/2021	2	Combo Fountain	In classroom 213	Right	WF-06152020-002265	3/7/2021	FT-FY21-022021-002265-A	<1	FT-FY21-022021-002265-B	<1
WS-002266	6/15/2020	6/15/2021	2	Break Room	In office room 212A in room 212		WF-06152020-002266	3/7/2021	FT-FY21-022021-002266-A	<1	FT-FY21-022021-002266-B	<1
WS-002267	6/15/2020	6/15/2021	3	Cooler	In hallway adjacent to room 316	Low Right	WF-06152020-002267	3/7/2021	FT-FY21-022021-002267-A	<1	FT-FY21-022021-002267-B	<1
WS-002269	6/15/2020	6/15/2021	2	Combo Fountain	In classroom 215	Right	WF-06152020-002269	3/7/2021	FT-FY21-022021-002269-A	<1	FT-FY21-022021-002269-B	<1
WS-002270	6/15/2020	6/15/2021	2	Cooler	In hallway adjacent to room 215	High Left	WF-06152020-002270	3/7/2021	FT-FY21-022021-002270-A	<1	FT-FY21-022021-002270-B	<1
WS-002271	6/15/2020	6/15/2021	2	Cooler	In hallway adjacent to room 215	Low Right	WF-06152020-002271	3/7/2021	FT-FY21-022021-002271-A	<1	FT-FY21-022021-002271-B	<1
WS-002272	6/15/2020	6/15/2021	3	Cooler	In hallway adjacent to room 316	High Left	WF-06152020-002272	3/7/2021	FT-FY21-022021-002272-A	<1	FT-FY21-022021-002272-B	<1
WS-002274	6/15/2020	6/15/2021	2	Combo Fountain	In classroom 217	Right	WF-06152020-002274	3/7/2021	FT-FY21-022021-002274-A	<1	FT-FY21-022021-002274-B	<1
WS-002276	6/15/2020	6/15/2021	3	Combo Fountain	In classroom 315	Right	WF-06152020-002276	3/7/2021	FT-FY21-022021-002276-A	<1	FT-FY21-022021-002276-B	<1
WS-002279	6/15/2020	6/15/2021	3	Combo Fountain	In classroom 308	Right	WF-06152020-002279	3/7/2021	FT-FY21-022021-002279-A	<1	FT-FY21-022021-002279-B	<1
WS-002280	6/15/2020	6/15/2021	3	Combo Fountain	In classroom 317	Right	WF-06152020-002280	3/7/2021	FT-FY21-022021-002280-A	<1	FT-FY21-022021-002280-B	<1
WS-002281	6/15/2020	6/15/2021	3	Cooler	In hallway adjacent to room 310		WF-06152020-002281	3/7/2021	FT-FY21-022021-002281-A	<1	FT-FY21-022021-002281-B	<1
WS-002283	6/15/2020	6/15/2021	3	Combo Fountain	In classroom 307	Right	WF-06152020-002283	3/7/2021	FT-FY21-022021-002283-A	<1	FT-FY21-022021-002283-B	<1
WS-002286	6/15/2020	6/15/2021	3	Combo Fountain	In classroom 309	Right	WF-06152020-002286	3/7/2021	FT-FY21-022021-002286-A	<1	FT-FY21-022021-002286-B	<1
WS-002288	6/15/2020	6/15/2021	3	Combo Fountain	In classroom 306	Right	WF-06152020-002288	3/7/2021	FT-FY21-022021-002288-A	<1	FT-FY21-022021-002288-B	<1
WS-002289	6/15/2020	6/15/2021	3	Combo Fountain	In classroom 313		WF-06152020-002289	3/7/2021	FT-FY21-022021-002289-A	<1	FT-FY21-022021-002289-B	<1
WS-002292	6/15/2020	6/15/2021	3	Combo Fountain	In classroom 304	Right	WF-06152020-002292	3/7/2021	FT-FY21-022021-002292-A	<1	FT-FY21-022021-002292-B	<1
WS-002294	6/15/2020	6/15/2021	3	Combo Fountain	In classroom 303	Right	WF-06152020-002294	3/7/2021	FT-FY21-022021-002294-A	<1	FT-FY21-022021-002294-B	<1
WS-002295	6/15/2020	6/15/2021	3	Combo Fountain	In classroom 302	Right	WF-06152020-002295	3/7/2021	FT-FY21-022021-002295-A	<1	FT-FY21-022021-002295-B	<1
WS-002299	6/15/2020	6/15/2021	3	Combo Fountain	In classroom 301	Right	WF-06152020-002299	3/7/2021	FT-FY21-022021-002299-A	<1	FT-FY21-022021-002299-B	<1
WS-002301	6/15/2020	6/15/2021	3	Combo Fountain	In classroom 300	Right	WF-06152020-002301	3/7/2021	FT-FY21-022021-002301-A	<1	FT-FY21-022021-002301-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002240	1/25/2021	1/25/2022	1	Food Prep Sink	In kitchen	Left	WF-01252021-002240	3/7/2021	FT-FY21-022021-002240-A	<1	FT-FY21-022021-002240-B	<1