



# Janney Elementary School Lead in Water Test Results

## FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002198	4/22/2024	4/22/2025	2	Combo Fountain	In office room 212A in room 212	WF-04222024-002198	10/30/2024	FT-FY25-10082024-002198-A	<2	FT-FY25-10082024-002198-B	<2
WS- 002203	4/22/2024	4/22/2025	Basement	Combo Fountain	In science lab room third clockwise from entry door	WF-04222024-002203	10/30/2024	FT-FY25-10082024-002203-A	<2	FT-FY25-10082024-002203-B	<2
WS- 002206	8/27/2024	8/27/2025	Basement	Combo Faucet	In classroom L11	WF-08272024-002206	10/30/2024	FT-FY25-10082024-002206-A	<2	FT-FY25-10082024-002206-B	<2
WS- 002207	4/22/2024	4/22/2025	Basement	Combo Fountain	In classroom L11	WF-04222024-002207	10/30/2024	FT-FY25-10082024-002207-A	<2	FT-FY25-10082024-002207-B	<2
WS- 002209	4/22/2024	4/22/2025	Basement	Cooler	In hallway adjacent to girls' restroom	WF-04222024-002209	10/30/2024	FT-FY25-10082024-002209-A	<2	FT-FY25-10082024-002209-B	<2
WS- 002210	4/22/2024	4/22/2025	1	Combo Fountain	In classroom 117	Right WF-04222024-002210	10/30/2024	FT-FY25-10082024-002210-A	<2	FT-FY25-10082024-002210-B	<2
WS- 002211	4/22/2024	4/22/2025	Basement	Combo Fountain	In science lab room first clockwise from entry door	Left WF-04222024-002211	10/30/2024	FT-FY25-10082024-002211-A	<2	FT-FY25-10082024-002211-B	<2
WS- 002212	8/27/2024	8/27/2025	1	Combo Faucet	In classroom 117	Left WF-08272024-002212	10/30/2024	FT-FY25-10082024-002212-A	<2	FT-FY25-10082024-002212-B	<2
WS- 002213	4/22/2024	4/22/2025	1	Combo Fountain	In classroom 115	Right WF-04222024-002213	10/30/2024	FT-FY25-10082024-002213-A	<2	FT-FY25-10082024-002213-B	<2
WS- 002214	8/27/2024	8/27/2025	1	Combo Faucet	In classroom 115	Left WF-08272024-002214	10/30/2024	FT-FY25-10082024-002214-A	<2	FT-FY25-10082024-002214-B	<2
WS- 002217	8/27/2024	8/27/2025	1	Combo Faucet	In classroom 113	Left WF-08272024-002217	10/30/2024	FT-FY25-10082024-002217-A	<2	FT-FY25-10082024-002217-B	<2
WS- 002218	4/22/2024	4/22/2025	1	Combo Fountain	In classroom 113	Right WF-04222024-002218	10/30/2024	FT-FY25-10082024-002218-A	<2	FT-FY25-10082024-002218-B	<2
WS- 002219	4/22/2024	4/22/2025	1	Combo Fountain	In classroom 110	Left WF-04222024-002219	10/30/2024	FT-FY25-10082024-002219-A	<2	FT-FY25-10082024-002219-B	<2
WS- 002221	4/22/2024	4/22/2025	1	Combo Fountain	In classroom 112	Left WF-04222024-002221	10/30/2024	FT-FY25-10082024-002221-A	<2	FT-FY25-10082024-002221-B	<2
WS- 002222	8/27/2024	8/27/2025	1	Combo Faucet	In classroom 112	Right WF-08272024-002222	10/30/2024	FT-FY25-10082024-002222-A	<2	FT-FY25-10082024-002222-B	<2
WS- 002223	4/22/2024	4/22/2025	1	Combo Fountain	In classroom 110	Right WF-04222024-002223	10/30/2024	FT-FY25-10082024-002223-A	<2	FT-FY25-10082024-002223-B	<2
WS- 002225	4/22/2024	4/22/2025	1	Cooler	In hallway adjacent to room 110	WF-04222024-002225	10/30/2024	FT-FY25-10082024-002225-A	<2	FT-FY25-10082024-002225-B	<2
WS- 002226	4/22/2024	4/22/2025	1	Combo Fountain	In classroom 108	Right WF-04222024-002226	10/30/2024	FT-FY25-10082024-002226-A	<2	FT-FY25-10082024-002226-B	<2
WS- 002227	8/27/2024	8/27/2025	1	Combo Faucet	In classroom 108	Left WF-08272024-002227	10/30/2024	FT-FY25-10082024-002227-A	<2	FT-FY25-10082024-002227-B	<2
WS- 002228	4/22/2024	4/22/2025	1	Combo Fountain	In classroom 109	Right WF-04222024-002228	10/30/2024	FT-FY25-10082024-002228-A	<2	FT-FY25-10082024-002228-B	<2
WS- 002229	8/27/2024	8/27/2025	1	Combo Faucet	In classroom 109	Left WF-08272024-002229	10/30/2024	FT-FY25-10082024-002229-A	<2	FT-FY25-10082024-002229-B	<2
WS- 002230	4/22/2024	4/22/2025	1	Combo Fountain	In classroom 106	Right WF-04222024-002230	10/30/2024	FT-FY25-10082024-002230-A	<2	FT-FY25-10082024-002230-B	<2
WS- 002231	8/27/2024	8/27/2025	1	Combo Faucet	In classroom 106	Left WF-08272024-002231	10/30/2024	FT-FY25-10082024-002231-A	<2	FT-FY25-10082024-002231-B	<2
WS- 002232	4/22/2024	4/22/2025	1	Combo Fountain	In classroom 107	Right WF-04222024-002232	10/30/2024	FT-FY25-10082024-002232-A	<2	FT-FY25-10082024-002232-B	<2
WS- 002233	8/27/2024	8/27/2025	1	Combo Faucet	In classroom 107	Left WF-08272024-002233	10/30/2024	FT-FY25-10082024-002233-A	<2	FT-FY25-10082024-002233-B	<2
WS- 002234	4/22/2024	4/22/2025	1	Cooler	In hallway adjacent to room 107	WF-04222024-002234	10/30/2024	FT-FY25-10082024-002234-A	<2	FT-FY25-10082024-002234-B	<2
WS- 002235	4/22/2024	4/22/2025	1	Health Suite	In health suite	WF-04222024-002235	10/30/2024	FT-FY25-10082024-002235-A	<2	FT-FY25-10082024-002235-B	<2
WS- 002236	4/22/2024	4/22/2025	1	Health Suite	In health suite adjacent to restroom	Left WF-04222024-002236	10/30/2024	FT-FY25-10082024-002236-A	<2	FT-FY25-10082024-002236-B	<2
WS- 002237	4/22/2024	4/22/2025	1	Combo Fountain	In health suite adjacent to restroom	Right WF-04222024-002237	10/30/2024	FT-FY25-10082024-002237-A	<2	FT-FY25-10082024-002237-B	<2
WS- 002242	4/22/2024	4/22/2025	2	Combo Fountain	In classroom 200	Right WF-04222024-002242	10/30/2024	FT-FY25-10082024-002242-A	<2	FT-FY25-10082024-002242-B	<2
WS- 002243	4/22/2024	4/22/2025	2	Combo Fountain	In classroom 201	Right WF-04222024-002243	10/30/2024	FT-FY25-10082024-002243-A	<2	FT-FY25-10082024-002243-B	<2
WS- 002245	4/22/2024	4/22/2025	2	Cooler	In hallway adjacent to room 202	WF-04222024-002245	10/30/2024	FT-FY25-10082024-002245-A	<2	FT-FY25-10082024-002245-B	<2
WS- 002247	4/22/2024	4/22/2025	2	Combo Fountain	In classroom 202	Right WF-04222024-002247	10/30/2024	FT-FY25-10082024-002247-A	<2	FT-FY25-10082024-002247-B	<2
WS- 002249	4/22/2024	4/22/2025	2	Combo Fountain	In classroom 203	Right WF-04222024-002249	10/30/2024	FT-FY25-10082024-002249-A	<2	FT-FY25-10082024-002249-B	<2

WS- 002252	4/22/2024	4/22/2025	2	Combo Fountain	In classroom 206	Right	WF-04222024-002252	10/30/2024	FT-FY25-10082024-002252-A	<2	FT-FY25-10082024-002252-B	<2
WS- 002254	4/22/2024	4/22/2025	2	Combo Fountain	In classroom 207	Right	WF-04222024-002254	10/30/2024	FT-FY25-10082024-002254-A	<2	FT-FY25-10082024-002254-B	<2
WS- 002256	4/22/2024	4/22/2025	2	Combo Fountain	In classroom 208	Right	WF-04222024-002256	10/30/2024	FT-FY25-10082024-002256-A	<2	FT-FY25-10082024-002256-B	<2
WS- 002258	4/22/2024	4/22/2025	2	Combo Fountain	In classroom 209	Right	WF-04222024-002258	10/30/2024	FT-FY25-10082024-002258-A	<2	FT-FY25-10082024-002258-B	<2
WS- 002260	4/22/2024	4/22/2025	2	Combo Fountain	In classroom 210A	Left	WF-04222024-002260	10/30/2024	FT-FY25-10082024-002260-A	<2	FT-FY25-10082024-002260-B	<2
WS- 002261	4/22/2024	4/22/2025	2	Cooler	In hallway adjacent to room 210		WF-04222024-002261	10/30/2024	FT-FY25-10082024-002261-A	<2	FT-FY25-10082024-002261-B	<2
WS- 002262	4/22/2024	4/22/2025	2	Combo Fountain	In staff lounge 212	Left	WF-04222024-002262	10/30/2024	FT-FY25-10082024-002262-A	<2	FT-FY25-10082024-002262-B	<2
WS- 002263	4/22/2024	4/22/2025	2	Break Room	In staff lounge 212	Right	WF-04222024-002263	10/30/2024	FT-FY25-10082024-002263-A	<2	FT-FY25-10082024-002263-B	<2
WS- 002266	4/22/2024	4/22/2025	2	Break Room	In office room 212A in room 212		WF-04222024-002266	10/30/2024	FT-FY25-10082024-002266-A	<2	FT-FY25-10082024-002266-B	<2
WS- 002267	4/22/2024	4/22/2025	3	Cooler	In hallway adjacent to room 316	Low Right	WF-04222024-002267	10/30/2024	FT-FY25-10082024-002267-A	<2	FT-FY25-10082024-002267-B	<2
WS- 002269	4/22/2024	4/22/2025	2	Combo Fountain	In classroom 215	Right	WF-04222024-002269	10/30/2024	FT-FY25-10082024-002269-A	<2	FT-FY25-10082024-002269-B	<2
WS- 002270	4/22/2024	4/22/2025	2	Cooler	In hallway adjacent to room 215	High Left	WF-04222024-002270	10/30/2024	FT-FY25-10082024-002270-A	<2	FT-FY25-10082024-002270-B	<2
WS- 002271	4/22/2024	4/22/2025	2	Cooler	In hallway adjacent to room 215	Low Right	WF-04222024-002271	10/30/2024	FT-FY25-10082024-002271-A	<2	FT-FY25-10082024-002271-B	<2
WS- 002272	4/22/2024	4/22/2025	3	Cooler	In hallway adjacent to room 316	High Left	WF-04222024-002272	10/30/2024	FT-FY25-10082024-002272-A	<2	FT-FY25-10082024-002272-B	<2
WS- 002274	4/22/2024	4/22/2025	2	Combo Fountain	In classroom 217	Right	WF-04222024-002274	10/30/2024	FT-FY25-10082024-002274-A	<2	FT-FY25-10082024-002274-B	<2
WS- 002276	4/22/2024	4/22/2025	3	Combo Fountain	In classroom 315	Right	WF-04222024-002276	10/30/2024	FT-FY25-10082024-002276-A	<2	FT-FY25-10082024-002276-B	<2
WS- 002279	4/22/2024	4/22/2025	3	Combo Fountain	In classroom 308	Right	WF-04222024-002279	10/30/2024	FT-FY25-10082024-002279-A	<2	FT-FY25-10082024-002279-B	<2
WS- 002280	4/22/2024	4/22/2025	3	Combo Fountain	In classroom 317	Right	WF-04222024-002280	10/30/2024	FT-FY25-10082024-002280-A	<2	FT-FY25-10082024-002280-B	<2
WS- 002281	4/22/2024	4/22/2025	3	Cooler	In hallway adjacent to room 310		WF-04222024-002281	10/30/2024	FT-FY25-10082024-002281-A	<2	FT-FY25-10082024-002281-B	<2
WS- 002282	4/22/2024	4/22/2025	3	Cooler	In hallway adjacent to room 307		WF-04222024-002282	10/30/2024	FT-FY25-10082024-002282-A	<2	FT-FY25-10082024-002282-B	<2
WS- 002283	4/22/2024	4/22/2025	3	Combo Fountain	In classroom 307	Right	WF-04222024-002283	10/30/2024	FT-FY25-10082024-002283-A	<2	FT-FY25-10082024-002283-B	<2
WS- 002286	4/22/2024	4/22/2025	3	Combo Fountain	In classroom 309	Right	WF-04222024-002286	10/30/2024	FT-FY25-10082024-002286-A	<2	FT-FY25-10082024-002286-B	<2
WS- 002288	4/22/2024	4/22/2025	3	Combo Fountain	In classroom 306	Right	WF-04222024-002288	10/30/2024	FT-FY25-10082024-002288-A	<2	FT-FY25-10082024-002288-B	<2
WS- 002289	4/22/2024	4/22/2025	3	Combo Fountain	In classroom 313		WF-04222024-002289	10/30/2024	FT-FY25-10082024-002289-A	<2	FT-FY25-10082024-002289-B	<2
WS- 002292	4/22/2024	4/22/2025	3	Combo Fountain	In classroom 304	Right	WF-04222024-002292	10/30/2024	FT-FY25-10082024-002292-A	<2	FT-FY25-10082024-002292-B	<2
WS- 002294	4/22/2024	4/22/2025	3	Combo Fountain	In classroom 303	Right	WF-04222024-002294	10/30/2024	FT-FY25-10082024-002294-A	<2	FT-FY25-10082024-002294-B	<2
WS- 002297	4/22/2024	4/22/2025	3	Cooler	In hallway adjacent to room 303		WF-04222024-002297	10/30/2024	FT-FY25-10082024-002297-A	<2	FT-FY25-10082024-002297-B	<2
WS- 002299	4/22/2024	4/22/2025	3	Combo Fountain	In classroom 301	Right	WF-04222024-002299	10/30/2024	FT-FY25-10082024-002299-A	<2	FT-FY25-10082024-002299-B	<2
WS- 002301	4/22/2024	4/22/2025	3	Combo Fountain	In classroom 300	Right	WF-04222024-002301	10/30/2024	FT-FY25-10082024-002301-A	<2	FT-FY25-10082024-002301-B	<2

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002240	11/27/2023	11/27/2024	1	Food Prep Sink	In kitchen	Left	WF-11272023-002240	10/30/2024	FT-FY25-10082024-002240-A	<2	FT-FY25-10082024-002240-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.