



JANNEY LEAD WATER TEST RESULTS

May 15, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location		1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002301	Fountain	3	In room 300 adjacent to the back window	Right	WT-042916-2318-A	< 1	WT-042916-2318-B	< 1				
2	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002300	Classroom	3	In room 300	Left	WT-042916-2317-A	< 1	WT-042916-2317-B	< 1				
3	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002299	Fountain	3	Room 301	Right	WT-042916-2316-A	< 1	WT-042916-2316-B	< 1				
4	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002298	Classroom	3	Room 301	Left	WT-042916-2315-A	< 1	WT-042916-2315-B	< 1				
5	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002297	Cooler	3	In hallway adjacent to room 303		WT-042916-2314-A	< 1	WT-042916-2314-B	< 1				
6	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002296	Classroom	3	In classroom 302	Left	WT-042916-2313-A	< 1	WT-042916-2313-B	< 1				
7	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002295	Fountain	3	In classroom 302	Right	WT-042916-2312-A	< 1	WT-042916-2312-B	< 1				
8	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002294	Fountain	3	In room 303 adjacent to the window	Right	WT-042916-2311-A	< 1	WT-042916-2311-B	< 1				
9	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002293	Classroom	3	In room 303 adjacent to the window	Left	WT-042916-2310-A	2.2	WT-042916-2310-B	< 1				
10	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002292	Fountain	3	In room 304	Right	WT-042916-2309-A	< 1	WT-042916-2309-B	< 1				
11	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002291	Classroom	3	In room 304	Left	WT-042916-2308-A	< 1	WT-042916-2308-B	< 1				
12	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002290	Classroom	3	In classroom 313		WT-042916-2307-A	< 1	WT-042916-2307-B	< 1				
13	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002289	Fountain	3	In classroom 313		WT-042916-2306-A	< 1	WT-042916-2306-B	< 1				
14	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002288	Fountain	3	In room 306	Right	WT-042916-2305-A	< 1	WT-042916-2305-B	6				
15	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002287	Classroom	3	In room 306	Left	WT-042916-2304-A	< 1	WT-042916-2304-B	< 1				
16	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002286	Fountain	3	In room 309	Right	WT-042916-2303-A	< 1	WT-042916-2303-B	< 1				
17	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002285	Classroom	3	In room 309	Left	WT-042916-2302-A	< 1	WT-042916-2302-B	< 1				
18	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002284	Classroom	3	In classroom 307	Left	WT-042916-2301-A	< 1	WT-042916-2301-B	< 1				
19	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002283	Fountain	3	In classroom 310	Right	WT-042916-2300-A	< 1	WT-042916-2300-B	< 1				
20	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002282	Cooler	3	In hallway adjacent to room 307		WT-042916-2299-A	< 1	WT-042916-2299-B	< 1				
21	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002281	Cooler	3	In hallway adjacent to room 310		WT-042916-2298-A	< 1	WT-042916-2298-B	< 1				
22	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002280	Fountain	3	In room 317	Right	WT-042916-2297-A	< 1	WT-042916-2297-B	< 1				
23	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002279	Fountain	3	In classroom 308	Right	WT-042916-2296-A	< 1	WT-042916-2296-B	< 1				
24	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002278	Classroom	3	In classroom 308	Left	WT-042916-2295-A	< 1	WT-042916-2295-B	< 1				
25	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002277	Classroom	3	In room 317	Left	WT-042916-2294-A	< 1	WT-042916-2294-B	< 1				
26	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002276	Fountain	3	In room 315 adjacent to the front door	Right	WT-042916-2293-A	< 1	WT-042916-2293-B	< 1				
27	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002275	Fountain	3	In room 315 adjacent to the front door	Left	WT-042916-2292-A	< 1	WT-042916-2292-B	< 1				
28	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002274	Fountain	2	In room 217 adjacent to the front door	Right	WT-042916-2291-A	< 1	WT-042916-2291-B	< 1				
29	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002273	Classroom	2	In room 217 adjacent to the front door	Left	WT-042916-2290-A	1.6	WT-042916-2290-B	< 1				
30	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002272	Cooler	3	In hallway adjacent to room 316	Left High	WT-042916-2289-A	< 1	WT-042916-2289-B	< 1				
31	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002271	Cooler	2	In hallway adjacent to room 215	Right Low	WT-042916-2288-A	< 1	WT-042916-2288-B	< 1				
32	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002270	Cooler	2	In hallway adjacent to room 215	Left High	WT-042916-2287-A	< 1	WT-042916-2287-B	< 1				
33	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002269	Fountain	2	In room 215 adjacent to the front door	Right	WT-042916-2286-A	< 1	WT-042916-2286-B	< 1				
34	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002268	Classroom	2	In room 215 adjacent to the front door	Left	WT-042916-2285-A	1.1	WT-042916-2285-B	< 1				
35	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002267	Cooler	3	In hallway adjacent to room 316	Right Low	WT-042916-2284-A	< 1	WT-042916-2284-B	< 1				
36	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002266	Classroom	2	In room 212A		WT-042916-2283-A	4.8	WT-042916-2283-B	1.6				
37	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002265	Fountain	2	In classroom 213	Right	WT-042916-2282-A	< 1	WT-042916-2282-B	< 1				
38	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002264	Classroom	2	In classroom 213	Left	WT-042916-2281-A	1.8	WT-042916-2281-B	< 1				
39	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002263	Classroom	2	In room 212 adjacent to the window	Right	WT-042916-2280-A	< 1	WT-042916-2280-B	< 1				
40	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002262	Fountain	2	In room 212 adjacent to the window	Left	WT-042916-2279-A	< 1	WT-042916-2279-B	< 1				
41	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002261	Cooler	2	In hallway adjacent to room 210		WT-042916-2278-A	< 1	WT-042916-2278-B	< 1				
42	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002260	Fountain	2	In room 210A	Left	WT-042916-2277-A	< 1	WT-042916-2277-B	< 1				
43	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002259	Classroom	2	In room 210A	Right	WT-042916-2276-A	< 1	WT-042916-2276-B	< 1				
44	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002258	Fountain	2	Room 209	Right	WT-042916-2275-A	< 1	WT-042916-2275-B	1.7				
45	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002257	Classroom	2	Room 209	Left	WT-042916-2274-A	< 1	WT-042916-2274-B	< 1				
46	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002256	Fountain	2	In room 208	Right	WT-042916-2273-A	< 1	WT-042916-2273-B	< 1				
47	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002255	Classroom	2	In room 208	Left	WT-042916-2272-A	< 1	WT-042916-2272-B	< 1				
48	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002254	Classroom	2	In room 207	Right	WT-042916-2271-A	< 1	WT-042916-2271-B	< 1				
49	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002253	Classroom	2	In room 207	Left	WT-042916-2270-A	< 1	WT-042916-2270-B	< 1				
50	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002252	Fountain	2	In room 206	Right	WT-042916-2269-A	< 1	WT-042916-2269-B	< 1				
51	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002251	Classroom	2	In room 206	Left	WT-042916-2268-A	< 1	WT-042916-2268-B	< 1				
52	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002250	Cooler	2	In hallway adjacent to room 207		WT-042916-2267-A	< 1	WT-042916-2267-B	< 1				
53	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002249	Fountain	2	In room 203	Right	WT-042916-2266-A	< 1	WT-042916-2266-B	< 1				
54	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002248	Classroom	2	In room 203	Left	WT-042916-2265-A	< 1	WT-042916-2265-B	< 1				
55	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002247	Fountain	2	In room 202 back corner wall	Right	WT-042916-2264-A	< 1	WT-042916-2264-B	< 1				
56	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002246	Classroom	2	In room 202 back corner wall	Left	WT-042916-2263-A	< 1	WT-042916-2263-B	< 1				
57	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002245	Cooler	2	In hallway adjacent to room 202		WT-042916-2262-A	< 1	WT-042916-2262-B	< 1				
58	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002244	Classroom	2	In room 201	Left	WT-042916-2261-A	< 1	WT-042916-2261-B	< 1				
59	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002243	Fountain	2	In room 201	Right	WT-042916-2260-A	< 1	WT-042916-2260-B	< 1				
60	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002242	Fountain	2	In room 200	Right	WT-042916-2259-A	< 1	WT-042916-2259-B	< 1				
61	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002241	Classroom	2	In room 200	Left	WT-042916-2258-A	< 1	WT-042916-2258-B	< 1				
62	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002240	Kitchen	1	In kitchen sink	Left	WT-042916-2257-A	< 1	WT-042916-2257-B	< 1				
63	JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002239	Kitchen	1	In kitchen sink	Right	WT-042916-2256-A	< 1	WT-042916-2256-B	< 1				



JANNEY LEAD WATER TEST RESULTS

May 15, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002238	Cooler	1	In hallways adjacent to the health suite	WT-042916-2255-A	2.5	WT-042916-2255-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002237	Health Suite	1	In health suite adjacent to the bathroom	WT-042916-2254-A	9.4	WT-042916-2254-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002236	Health Suite	1	In health suite adjacent to bathroom	WT-042916-2253-A	< 1	WT-042916-2253-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002235	Health Suite	1	Sink in health suite	WT-042916-2252-A	< 1	WT-042916-2252-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002234	Cooler	1	In hallway adjacent to room 107	WT-042916-2251-A	< 1	WT-042916-2251-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002233	Classroom	1	In room 107	WT-042916-2250-A	< 1	WT-042916-2250-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002232	Fountain	1	In room 107	WT-042916-2249-A	< 1	WT-042916-2249-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002231	Classroom	1	In room 106	WT-042916-2248-A	< 1	WT-042916-2248-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002230	Fountain	1	In room 106	WT-042916-2247-A	< 1	WT-042916-2247-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002229	Classroom	1	In room 109	WT-042916-2246-A	< 1	WT-042916-2246-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002228	Fountain	1	In room 109	WT-042916-2245-A	< 1	WT-042916-2245-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002227	Classroom	1	In room 108	WT-042916-2244-A	< 1	WT-042916-2244-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002226	Fountain	1	In room 108	WT-042916-2243-A	< 1	WT-042916-2243-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002225	Cooler	1	In hallway adjacent to room 110	WT-042916-2242-A	< 1	WT-042916-2242-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002224	Classroom	1	In room 110 adjacent to the window	WT-042916-2241-A	< 1	WT-042916-2241-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002223	Fountain	1	In room 110 adjacent to the window	WT-042916-2240-A	< 1	WT-042916-2240-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002222	Classroom	1	In room 112	WT-042916-2239-A	< 1	WT-042916-2239-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002221	Fountain	1	In room 112	WT-042916-2238-A	< 1	WT-042916-2238-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002220	Classroom	1	In room 110	WT-042916-2237-A	< 1	WT-042916-2237-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002219	Fountain	1	In room 110	WT-042916-2236-A	< 1	WT-042916-2236-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002218	Fountain	1	In room 113 on the back wall	WT-042916-2235-A	< 1	WT-042916-2235-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002217	Classroom	1	In room 113 on the back wall	WT-042916-2234-A	< 1	WT-042916-2234-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002216	Cooler	1	In hallway adjacent to room 113	WT-042916-2233-A	< 1	WT-042916-2233-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002215	Cooler	1	In hallway adjacent to room 113	WT-042916-2232-A	< 1	WT-042916-2232-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002214	Kitchen	1	In kitchen room 115	WT-042916-2231-A	< 1	WT-042916-2231-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002213	Fountain	1	In room 115	WT-042916-2230-A	< 1	WT-042916-2230-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002212	Classroom	1	In room 117 on the back wall	WT-042916-2229-A	< 1	WT-042916-2229-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002211	Fountain	Basement	In science room adjacent to the window	WT-042916-2228-A	< 1	WT-042916-2228-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002210	Fountain	1	In room 117 on the back wall	WT-042916-2227-A	< 1	WT-042916-2227-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002209	Cooler	Basement	In hallway adjacent to girls bathroom	WT-042916-2226-A	< 1	WT-042916-2226-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002208	Classroom	Basement	In science room adjacent to the window.	WT-042916-2225-A	< 1	WT-042916-2225-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002207	Fountain	Basement	In room L11 on south wall adjacent to the window	WT-042916-2224-A	< 1	WT-042916-2224-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002206	Classroom	Basement	In room L11 on south wall adjacent to the window	WT-042916-2223-A	< 1	WT-042916-2223-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002205	Fountain	Basement	In science room adjacent to the window	WT-042916-2222-A	< 1	WT-042916-2222-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002204	Classroom	Basement	In science room adjacent to the window	WT-042916-2221-A	< 1	WT-042916-2221-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002203	Fountain	Basement	In science room along north wall	WT-042916-2220-A	< 1	WT-042916-2220-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002202	Classroom	Basement	In science room along north wall	WT-042916-2219-A	< 1	WT-042916-2219-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002201	Classroom	Basement	In science room along north wall	WT-042916-2218-A	< 1	WT-042916-2218-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002200	Fountain	Basement	In science room along north wall	WT-042916-2217-A	< 1	WT-042916-2217-B	< 1				
JANNEY ELEMENTARY SCHOOL	5/4/2016	WS-002199	Utility	Basement	Water room (Main water source)	WT-042916-2216-A	2.7	WT-042916-2216-B	< 1				

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.