



# Janney ES Lead Water Test Results



## FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002200	6/9/2017	6/9/2018	Basement	Combo Fountain	In science lab room fourth clockwise from entry door	WF-62017-002200	11/28/2017	FT-FY18-62017-002200-A	<1	FT-FY18-62017-002200-B	<1
WS-002209	6/9/2017	6/9/2018	Basement	Cooler	In hallway adjacent to girls' restroom	WF-62017-002209	11/28/2017	FT-FY18-62017-002209-A	<1	FT-FY18-62017-002209-B	<1
WS-002210	6/9/2017	6/9/2018	1	Combo Fountain	In classroom 117	WF-62017-002210	11/28/2017	FT-FY18-62017-002210-A	<1	FT-FY18-62017-002210-B	<1
WS-002212	11/1/2017	11/1/2018	1	Combo Faucet	In classroom 117	WF-112017-002212	11/28/2017	FT-FY18-112017-002212-A	<1	FT-FY18-112017-002212-B	<1
WS-002213	6/9/2017	6/9/2018	1	Combo Fountain	In classroom 115	WF-62017-002213	11/28/2017	FT-FY18-62017-002213-A	<1	FT-FY18-62017-002213-B	<1
WS-002222	11/1/2017	11/1/2018	1	Combo Faucet	In classroom 112	WF-112017-002222	11/28/2017	FT-FY18-112017-002222-A	<1	FT-FY18-112017-002222-B	<1
WS-002226	6/9/2017	6/9/2018	1	Combo Fountain	In classroom 108	WF-62017-002226	11/28/2017	FT-FY18-62017-002226-A	<1	FT-FY18-62017-002226-B	<1
WS-002228	6/9/2017	6/9/2018	1	Combo Fountain	In classroom 109	WF-62017-002228	11/28/2017	FT-FY18-62017-002228-A	<1	FT-FY18-62017-002228-B	<1
WS-002229	11/1/2017	11/1/2018	1	Combo Faucet	In classroom 109	WF-112017-002229	11/28/2017	FT-FY18-112017-002229-A	<1	FT-FY18-112017-002229-B	<1
WS-002231	11/1/2017	11/1/2018	1	Combo Faucet	In classroom 106	WF-112017-002231	11/28/2017	FT-FY18-112017-002231-A	<1	FT-FY18-112017-002231-B	<1
WS-002235	6/9/2017	6/9/2018	1	Health Suite	In health suite	WF-62017-002235	11/28/2017	FT-FY18-62017-002235-A	<1	FT-FY18-62017-002235-B	<1
WS-002247	6/9/2017	6/9/2018	2	Combo Fountain	In classroom 202	WF-62017-002247	11/28/2017	FT-FY18-62017-002247-A	<1	FT-FY18-62017-002247-B	<1
WS-002253	6/9/2017	6/9/2018	2	Combo Faucet	In classroom 207	WF-62017-002253	11/28/2017	FT-FY18-62017-002253-A	<1	FT-FY18-62017-002253-B	<1
WS-002254	6/9/2017	6/9/2018	2	Combo Fountain	In classroom 207	WF-62017-002254	11/28/2017	FT-FY18-62017-002254-A	<1	FT-FY18-62017-002254-B	<1
WS-002261	6/9/2017	6/9/2018	2	Cooler	In hallway adjacent to room 210	WF-62017-002261	11/28/2017	FT-FY18-62017-002261-A	<1	FT-FY18-62017-002261-B	<1
WS-002262	6/9/2017	6/9/2018	2	Combo Fountain	In staff lounge 212	WF-62017-002262	11/28/2017	FT-FY18-62017-002262-A	<1	FT-FY18-62017-002262-B	<1
WS-002263	6/9/2017	6/9/2018	2	Break Room	In staff lounge 212	WF-62017-002263	11/28/2017	FT-FY18-62017-002263-A	<1	FT-FY18-62017-002263-B	<1
WS-002265	6/9/2017	6/9/2018	2	Combo Fountain	In classroom 213	WF-62017-002265	11/28/2017	FT-FY18-62017-002265-A	<1	FT-FY18-62017-002265-B	<1
WS-002266	6/9/2017	6/9/2018	2	Break Room	In office room 212A in room 212	WF-62017-002266	11/28/2017	FT-FY18-62017-002266-A	<1	FT-FY18-62017-002266-B	<1
WS-002272	6/9/2017	6/9/2018	3	Cooler	In hallway adjacent to room 316	WF-62017-002272	11/28/2017	FT-FY18-62017-002272-A	<1	FT-FY18-62017-002272-B	<1
WS-002276	6/9/2017	6/9/2018	3	Combo Fountain	In classroom 315	WF-62017-002276	11/28/2017	FT-FY18-62017-002276-A	<1	FT-FY18-62017-002276-B	<1
WS-002288	6/9/2017	6/9/2018	3	Combo Fountain	In classroom 306	WF-62017-002288	11/28/2017	FT-FY18-62017-002288-A	<1	FT-FY18-62017-002288-B	<1
WS-002292	6/9/2017	6/9/2018	3	Combo Fountain	In classroom 304	WF-62017-002292	11/28/2017	FT-FY18-62017-002292-A	<1	FT-FY18-62017-002292-B	<1
WS-002299	6/9/2017	6/9/2018	3	Combo Fountain	In classroom 301	WF-62017-002299	11/28/2017	FT-FY18-62017-002299-A	<1	FT-FY18-62017-002299-B	<1

## Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)			
WS-002239	1	Food Prep Sink	In kitchen	11/28/2017	FT-FY18-102017-002239-A	<1	FT-FY18-102017-002239-B	<1			