



# Janney ES Lead Water Test Results



## FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002198	5/9/2018	5/9/2019	2	Combo Fountain	In office room 212A in room 212	WF-05092018-002198	12/5/2018	FT-FY19-112018-002198-A	<1	FT-FY19-112018-002198-B	<1
WS- 002200	5/9/2018	5/9/2019	Basement	Combo Fountain	In science lab room fourth clockwise from entry door	WF-05092018-002200	12/5/2018	FT-FY19-112018-002200-A	<1	FT-FY19-112018-002200-B	<1
WS- 002203	5/9/2018	5/9/2019	Basement	Combo Fountain	In science lab room third clockwise from entry door	WF-05092018-002203	12/5/2018	FT-FY19-112018-002203-A	<1	FT-FY19-112018-002203-B	<1
WS- 002205	5/9/2018	5/9/2019	Basement	Combo Fountain	In science lab room second clockwise from entry door	WF-05092018-002205	12/5/2018	FT-FY19-112018-002205-A	<1	FT-FY19-112018-002205-B	<1
WS- 002206	10/8/2018	10/8/2019	Basement	Combo Faucet	In classroom L11	WF-10082018-002206	12/5/2018	FT-FY19-112018-002206-A	<1	FT-FY19-112018-002206-B	<1
WS- 002207	5/9/2018	5/9/2019	Basement	Combo Fountain	In classroom L11	WF-05092018-002207	12/5/2018	FT-FY19-112018-002207-A	<1	FT-FY19-112018-002207-B	<1
WS- 002209	5/9/2018	5/9/2019	Basement	Cooler	In hallway adjacent to girls' restroom	WF-05092018-002209	12/5/2018	FT-FY19-112018-002209-A	<1	FT-FY19-112018-002209-B	<1
WS- 002210	5/9/2018	5/9/2019	1	Combo Fountain	In classroom 117	Right WF-05092018-002210	12/5/2018	FT-FY19-112018-002210-A	<1	FT-FY19-112018-002210-B	<1
WS- 002211	5/9/2018	5/9/2019	Basement	Combo Fountain	In science lab room first clockwise from entry door	Left WF-05092018-002211	12/5/2018	FT-FY19-112018-002211-A	<1	FT-FY19-112018-002211-B	<1
WS- 002212	10/8/2018	10/8/2019	1	Combo Faucet	In classroom 117	Left WF-10082018-002212	12/5/2018	FT-FY19-112018-002212-A	<1	FT-FY19-112018-002212-B	<1
WS- 002213	5/9/2018	5/9/2019	1	Combo Fountain	In classroom 115	Right WF-05092018-002213	12/5/2018	FT-FY19-112018-002213-A	<1	FT-FY19-112018-002213-B	<1
WS- 002214	10/8/2018	10/8/2019	1	Combo Faucet	In classroom 115	Left WF-10082018-002214	12/5/2018	FT-FY19-112018-002214-A	<1	FT-FY19-112018-002214-B	<1
WS- 002215	5/9/2018	5/9/2019	1	Cooler	In hallway adjacent to room 113	Low Right WF-05092018-002215	12/5/2018	FT-FY19-112018-002215-A	<1	FT-FY19-112018-002215-B	<1
WS- 002216	5/9/2018	5/9/2019	1	Cooler	In hallway adjacent to room 113	High Left WF-05092018-002216	12/5/2018	FT-FY19-112018-002216-A	<1	FT-FY19-112018-002216-B	<1
WS- 002217	10/8/2018	10/8/2019	1	Combo Faucet	In classroom 113	Left WF-10082018-002217	12/5/2018	FT-FY19-112018-002217-A	<1	FT-FY19-112018-002217-B	<1
WS- 002218	5/9/2018	5/9/2019	1	Combo Fountain	In classroom 113	Right WF-05092018-002218	12/5/2018	FT-FY19-112018-002218-A	<1	FT-FY19-112018-002218-B	<1
WS- 002219	5/9/2018	5/9/2019	1	Combo Fountain	In classroom 110	Left WF-05092018-002219	12/5/2018	FT-FY19-112018-002219-A	<1	FT-FY19-112018-002219-B	<1
WS- 002221	5/9/2018	5/9/2019	1	Combo Fountain	In classroom 112	Left WF-05092018-002221	12/5/2018	FT-FY19-112018-002221-A	<1	FT-FY19-112018-002221-B	<1
WS- 002222	10/8/2018	10/8/2019	1	Combo Faucet	In classroom 112	Right WF-10082018-002222	12/5/2018	FT-FY19-112018-002222-A	<1	FT-FY19-112018-002222-B	<1
WS- 002223	5/9/2018	5/9/2019	1	Combo Fountain	In classroom 110	Right WF-05092018-002223	12/5/2018	FT-FY19-112018-002223-A	<1	FT-FY19-112018-002223-B	<1
WS- 002225	5/9/2018	5/9/2019	1	Cooler	In hallway adjacent to room 110	WF-05092018-002225	12/5/2018	FT-FY19-112018-002225-A	<1	FT-FY19-112018-002225-B	<1
WS- 002226	5/9/2018	5/9/2019	1	Combo Fountain	In classroom 108	Right WF-05092018-002226	12/5/2018	FT-FY19-112018-002226-A	<1	FT-FY19-112018-002226-B	<1
WS- 002227	10/8/2018	10/8/2019	1	Combo Faucet	In classroom 108	Left WF-10082018-002227	12/5/2018	FT-FY19-112018-002227-A	<1	FT-FY19-112018-002227-B	<1
WS- 002228	5/9/2018	5/9/2019	1	Combo Fountain	In classroom 109	Right WF-05092018-002228	12/5/2018	FT-FY19-112018-002228-A	<1	FT-FY19-112018-002228-B	<1
WS- 002229	10/8/2018	10/8/2019	1	Combo Faucet	In classroom 109	Left WF-10082018-002229	12/5/2018	FT-FY19-112018-002229-A	<1	FT-FY19-112018-002229-B	<1
WS- 002230	5/9/2018	5/9/2019	1	Combo Fountain	In classroom 106	Right WF-05092018-002230	12/5/2018	FT-FY19-112018-002230-A	<1	FT-FY19-112018-002230-B	<1
WS- 002231	10/8/2018	10/8/2019	1	Combo Faucet	In classroom 106	Left WF-10082018-002231	12/5/2018	FT-FY19-112018-002231-A	<1	FT-FY19-112018-002231-B	<1
WS- 002232	5/9/2018	5/9/2019	1	Combo Fountain	In classroom 107	Right WF-05092018-002232	12/5/2018	FT-FY19-112018-002232-A	<1	FT-FY19-112018-002232-B	<1
WS- 002233	10/8/2018	10/8/2019	1	Combo Faucet	In classroom 107	Left WF-10082018-002233	12/5/2018	FT-FY19-112018-002233-A	<1	FT-FY19-112018-002233-B	<1
WS- 002234	5/9/2018	5/9/2019	1	Cooler	In hallway adjacent to room 107	WF-05092018-002234	12/5/2018	FT-FY19-112018-002234-A	<1	FT-FY19-112018-002234-B	<1
WS- 002235	5/9/2018	5/9/2019	1	Health Suite	In health suite	WF-05092018-002235	12/5/2018	FT-FY19-112018-002235-A	<1	FT-FY19-112018-002235-B	<1
WS- 002236	5/9/2018	5/9/2019	1	Health Suite	In health suite adjacent to restroom	Left WF-05092018-002236	12/5/2018	FT-FY19-112018-002236-A	<1	FT-FY19-112018-002236-B	<1
WS- 002237	5/9/2018	5/9/2019	1	Combo Fountain	In health suite adjacent to restroom	Right WF-05092018-002237	12/5/2018	FT-FY19-112018-002237-A	<1	FT-FY19-112018-002237-B	<1
WS- 002238	5/9/2018	5/9/2019	1	Cooler	In hallway adjacent to the health suite	WF-05092018-002238	12/5/2018	FT-FY19-112018-002238-A	<1	FT-FY19-112018-002238-B	<1
WS- 002242	5/9/2018	5/9/2019	2	Combo Fountain	In classroom 200	Right WF-05092018-002242	12/5/2018	FT-FY19-112018-002242-A	<1	FT-FY19-112018-002242-B	<1

WS-002243	5/9/2018	5/9/2019	2	Combo Fountain	In classroom 201	Right	WF-05092018-002243	12/5/2018	FT-FY19-112018-002243-A	<1	FT-FY19-112018-002243-B	<1
WS-002245	5/9/2018	5/9/2019	2	Cooler	In hallway adjacent to room 202		WF-05092018-002245	12/5/2018	FT-FY19-112018-002245-A	<1	FT-FY19-112018-002245-B	<1
WS-002247	5/9/2018	5/9/2019	2	Combo Fountain	In classroom 202	Right	WF-05092018-002247	12/5/2018	FT-FY19-112018-002247-A	<1	FT-FY19-112018-002247-B	<1
WS-002249	5/9/2018	5/9/2019	2	Combo Fountain	In classroom 203	Right	WF-05092018-002249	12/5/2018	FT-FY19-112018-002249-A	<1	FT-FY19-112018-002249-B	<1
WS-002250	5/9/2018	5/9/2019	2	Cooler	In hallway adjacent to room 207		WF-05092018-002250	12/5/2018	FT-FY19-112018-002250-A	<1	FT-FY19-112018-002250-B	<1
WS-002252	5/9/2018	5/9/2019	2	Combo Fountain	In classroom 206	Right	WF-05092018-002252	12/5/2018	FT-FY19-112018-002252-A	<1	FT-FY19-112018-002252-B	<1
WS-002254	5/9/2018	5/9/2019	2	Combo Fountain	In classroom 207	Right	WF-05092018-002254	12/5/2018	FT-FY19-112018-002254-A	<1	FT-FY19-112018-002254-B	<1
WS-002256	5/9/2018	5/9/2019	2	Combo Fountain	In classroom 208	Right	WF-05092018-002256	12/5/2018	FT-FY19-112018-002256-A	<1	FT-FY19-112018-002256-B	<1
WS-002258	5/9/2018	5/9/2019	2	Combo Fountain	In classroom 209	Right	WF-05092018-002258	12/5/2018	FT-FY19-112018-002258-A	<1	FT-FY19-112018-002258-B	<1
WS-002260	5/9/2018	5/9/2019	2	Combo Fountain	In classroom 210A	Left	WF-05092018-002260	12/5/2018	FT-FY19-112018-002260-A	<1	FT-FY19-112018-002260-B	<1
WS-002261	5/9/2018	5/9/2019	2	Cooler	In hallway adjacent to room 210		WF-05092018-002261	12/5/2018	FT-FY19-112018-002261-A	<1	FT-FY19-112018-002261-B	<1
WS-002262	5/9/2018	5/9/2019	2	Combo Fountain	In staff lounge 212	Left	WF-05092018-002262	12/5/2018	FT-FY19-112018-002262-A	<1	FT-FY19-112018-002262-B	<1
WS-002263	5/9/2018	5/9/2019	2	Break Room	In staff lounge 212	Right	WF-05092018-002263	12/5/2018	FT-FY19-112018-002263-A	<1	FT-FY19-112018-002263-B	<1
WS-002265	5/9/2018	5/9/2019	2	Combo Fountain	In classroom 213	Right	WF-05092018-002265	12/5/2018	FT-FY19-112018-002265-A	<1	FT-FY19-112018-002265-B	<1
WS-002266	5/9/2018	5/9/2019	2	Break Room	In office room 212A in room 212		WF-05092018-002266	12/5/2018	FT-FY19-112018-002266-A	<1	FT-FY19-112018-002266-B	<1
WS-002267	5/9/2018	5/9/2019	3	Cooler	In hallway adjacent to room 316	Low Right	WF-05092018-002267	12/5/2018	FT-FY19-112018-002267-A	<1	FT-FY19-112018-002267-B	<1
WS-002269	5/9/2018	5/9/2019	2	Combo Fountain	In classroom 215	Right	WF-05092018-002269	12/5/2018	FT-FY19-112018-002269-A	<1	FT-FY19-112018-002269-B	<1
WS-002270	5/9/2018	5/9/2019	2	Cooler	In hallway adjacent to room 215	High Left	WF-05092018-002270	12/5/2018	FT-FY19-112018-002270-A	<1	FT-FY19-112018-002270-B	<1
WS-002271	5/9/2018	5/9/2019	2	Cooler	In hallway adjacent to room 215	Low Right	WF-05092018-002271	12/5/2018	FT-FY19-112018-002271-A	<1	FT-FY19-112018-002271-B	<1
WS-002272	5/9/2018	5/9/2019	3	Cooler	In hallway adjacent to room 316	High Left	WF-05092018-002272	12/5/2018	FT-FY19-112018-002272-A	<1	FT-FY19-112018-002272-B	<1
WS-002274	5/9/2018	5/9/2019	2	Combo Fountain	In classroom 217	Right	WF-05092018-002274	12/5/2018	FT-FY19-112018-002274-A	<1	FT-FY19-112018-002274-B	<1
WS-002276	5/9/2018	5/9/2019	3	Combo Fountain	In classroom 315	Right	WF-05092018-002276	12/5/2018	FT-FY19-112018-002276-A	<1	FT-FY19-112018-002276-B	<1
WS-002279	5/9/2018	5/9/2019	3	Combo Fountain	In classroom 308	Right	WF-05092018-002279	12/5/2018	FT-FY19-112018-002279-A	<1	FT-FY19-112018-002279-B	<1
WS-002280	5/9/2018	5/9/2019	3	Combo Fountain	In classroom 317	Right	WF-05092018-002280	12/5/2018	FT-FY19-112018-002280-A	<1	FT-FY19-112018-002280-B	<1
WS-002281	5/9/2018	5/9/2019	3	Cooler	In hallway adjacent to room 310		WF-05092018-002281	12/5/2018	FT-FY19-112018-002281-A	<1	FT-FY19-112018-002281-B	<1
WS-002282	5/9/2018	5/9/2019	3	Cooler	In hallway adjacent to room 307		WF-05092018-002282	12/5/2018	FT-FY19-112018-002282-A	<1	FT-FY19-112018-002282-B	<1
WS-002283	5/9/2018	5/9/2019	3	Combo Fountain	In classroom 307	Right	WF-05092018-002283	12/5/2018	FT-FY19-112018-002283-A	<1	FT-FY19-112018-002283-B	<1
WS-002286	5/9/2018	5/9/2019	3	Combo Fountain	In classroom 309	Right	WF-05092018-002286	12/5/2018	FT-FY19-112018-002286-A	<1	FT-FY19-112018-002286-B	<1
WS-002288	5/9/2018	5/9/2019	3	Combo Fountain	In classroom 306	Right	WF-05092018-002288	12/5/2018	FT-FY19-112018-002288-A	<1	FT-FY19-112018-002288-B	<1
WS-002289	5/9/2018	5/9/2019	3	Combo Fountain	In classroom 313		WF-05092018-002289	12/5/2018	FT-FY19-112018-002289-A	<1	FT-FY19-112018-002289-B	<1
WS-002292	5/9/2018	5/9/2019	3	Combo Fountain	In classroom 304	Right	WF-05092018-002292	12/5/2018	FT-FY19-112018-002292-A	<1	FT-FY19-112018-002292-B	<1
WS-002294	5/9/2018	5/9/2019	3	Combo Fountain	In classroom 303	Right	WF-05092018-002294	12/5/2018	FT-FY19-112018-002294-A	<1	FT-FY19-112018-002294-B	<1
WS-002295	5/9/2018	5/9/2019	3	Combo Fountain	In classroom 302	Right	WF-05092018-002295	12/5/2018	FT-FY19-112018-002295-A	<1	FT-FY19-112018-002295-B	<1
WS-002297	5/9/2018	5/9/2019	3	Cooler	In hallway adjacent to room 303		WF-05092018-002297	12/5/2018	FT-FY19-112018-002297-A	<1	FT-FY19-112018-002297-B	<1
WS-002299	5/9/2018	5/9/2019	3	Combo Fountain	In classroom 301	Right	WF-05092018-002299	12/5/2018	FT-FY19-112018-002299-A	<1	FT-FY19-112018-002299-B	<1
WS-002301	5/9/2018	5/9/2019	3	Combo Fountain	In classroom 300	Right	WF-05092018-002301	12/5/2018	FT-FY19-112018-002301-A	<1	FT-FY19-112018-002301-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Floor	Device Type	Device Location				Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002239	1	Food Prep Sink	In kitchen			Right	12/5/2018	FT-FY19-112018-002239-A	<1	FT-FY19-112018-002239-B	<1