



JEFFERSON MS LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	JEFFERSON MIDDLE SCHOOL	WS- 002589	8/20/2016	Basement	Cooler	In hallway adjacent to boiler room B-20	FT-82016-002589-A	< 1	FT-82016-002589-B	< 1
2	JEFFERSON MIDDLE SCHOOL	WS- 010654	8/20/2016	Basement	Cooler	In hallway adjacent to stairwell	FT-82016-010654-A	< 1	FT-82016-010654-B	< 1
3	JEFFERSON MIDDLE SCHOOL	WS- 010655	8/20/2016	Basement	Cooler	In cafeteria	FT-82016-010655-A	< 1	FT-82016-010655-B	< 1
4	JEFFERSON MIDDLE SCHOOL	WS- 010656	8/20/2016	Basement	Food Prep Sink	In kitchen first clockwise from entry door	FT-82016-010656-A	< 1	FT-82016-010656-B	< 1
5	JEFFERSON MIDDLE SCHOOL	WS- 010659	8/20/2016	Basement	Cooler	In hallway adjacent to room B01	FT-82016-010659-A	< 1	FT-82016-010659-B	< 1
6	JEFFERSON MIDDLE SCHOOL	WS- 010660	8/20/2016	Basement	Cooler	In hallway adjacent to storage room	FT-82016-010660-A	< 1	FT-82016-010660-B	3.15
			10/17/2016				Re-test A	< 1	Re-test B	< 1
7	JEFFERSON MIDDLE SCHOOL	WS- 010662	8/20/2016	1	Cooler	In hallway adjacent to staff lounge 105	FT-82016-010662-A	< 1	FT-82016-010662-B	< 1
8	JEFFERSON MIDDLE SCHOOL	WS- 010663	8/20/2016	1	Health Suite	In health suite 107	FT-82016-010663-A	< 1	FT-82016-010663-B	< 1
9	JEFFERSON MIDDLE SCHOOL	WS- 010666	8/20/2016	1	Cooler	In hallway adjacent to room 109	FT-82016-010666-A	< 1	FT-82016-010666-B	< 1
10	JEFFERSON MIDDLE SCHOOL	WS- 010667	8/20/2016	1	Cooler	In hallway adjacent to room 004	FT-82016-010667-A	< 1	FT-82016-010667-B	< 1
11	JEFFERSON MIDDLE SCHOOL	WS- 010668	8/20/2016	1	Cooler	In boys' locker room	FT-82016-010668-A	< 1	FT-82016-010668-B	< 1
12	JEFFERSON MIDDLE SCHOOL	WS- 010669	8/20/2016	1	Cooler	In girls' locker room	FT-82016-010669-A	< 1	FT-82016-010669-B	< 1
13	JEFFERSON MIDDLE SCHOOL	WS- 010673	8/20/2016	2	Cooler	In hallway adjacent to room 207	FT-82016-010673-A	< 1	FT-82016-010673-B	< 1
14	JEFFERSON MIDDLE SCHOOL	WS- 010674	8/20/2016	2	Cooler	In hallway adjacent to room 219	FT-82016-010674-A	< 1	FT-82016-010674-B	< 1
15	JEFFERSON MIDDLE SCHOOL	WS- 010676	8/20/2016	3	Cooler	In hallway adjacent to boys' restroom	FT-82016-010676-A	< 1	FT-82016-010676-B	< 1