



# JEFFERSON LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010653	Utility	Basement	In boiler room (water source)	WT-042916-10670-A	14.4	WT-042916-10670-B	6.2				
2 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010654	Cooler	Basement	In hallway adjacent to boiler room	WT-042916-10671-A	< 1	WT-042916-10671-B	< 1				
3 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010655	Cooler	Basement	In cafeteria	WT-042916-10672-A	< 1	WT-042916-10672-B	< 1				
4 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010656	Kitchen	Basement	In kitchen, east wall	WT-042916-10673-A	< 1	WT-042916-10673-B	< 1				
5 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010657	Kitchen	Basement	In kitchen, west wall	WT-042916-10674-A	< 1	WT-042916-10674-B	< 1				
6 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010658	Kitchen	Basement	In kitchen, west wall	WT-042916-10675-A	< 1	WT-042916-10675-B	< 1				
7 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010659	Cooler	Basement	In hallway adjacent to B01	WT-042916-10676-A	< 1	WT-042916-10676-B	< 1				
8 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010660	Cooler	Basement	In hallway adjacent to storage	WT-042916-10677-A	< 1	WT-042916-10677-B	< 1				
9 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010661	Classroom	1	In classroom 101A	WT-042916-10678-A	3.3	WT-042916-10678-B	< 1				
10 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010662	Cooler	1	In hallway adjacent to boys restroom	WT-042916-10679-A	< 1	WT-042916-10679-B	< 1				
11 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010663	Health Suite	1	In health suite 107	WT-042916-10680-A	< 1	WT-042916-10680-B	< 1				
12 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010664	Classroom	1	In classroom 109	WT-042916-10681-A	1130	WT-042916-10681-B	2.7	Filter will be installed and then retested			
13 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010665	Classroom	1	In classroom 109	WT-042916-10682-A	50.6	WT-042916-10682-B	< 1	Filter will be installed and then retested			
14 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010666	Cooler	1	In hallway adjacent to room 109	WT-042916-10683-A	< 1	WT-042916-10683-B	< 1				
15 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010667	Cooler	1	In hallway adjacent to 004	WT-042916-10684-A	< 1	WT-042916-10684-B	< 1				
16 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010668	Cooler	1	In boys locker room	WT-042916-10685-A	< 1	WT-042916-10685-B	< 1				
17 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010669	Cooler	1	In girls locker room	WT-042916-10686-A	< 1	WT-042916-10686-B	< 1				
18 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010670	Classroom	2	In classroom 203, SW wall	WT-042916-10687-A	30.5	WT-042916-10687-B	31.9	Filter will be installed and then retested			
19 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010671	Classroom	2	In classroom 203, SW	WT-042916-10688-A	2	WT-042916-10688-B	< 1				
20 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010672	Classroom	2	In classroom 203	WT-042916-10689-A	811	WT-042916-10689-B	5.2	Filter will be installed and then retested			
21 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010673	Cooler	2	In hallway adjacent to 207	WT-042916-10690-A	< 1	WT-042916-10690-B	< 1				
22 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010674	Cooler	2	In hallway adjacent to room 219	WT-042916-10691-A	< 1	WT-042916-10691-B	< 1				
23 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010675	Classroom	2	In classroom 220	WT-042916-10692-A	15.9	WT-042916-10692-B	< 1	Filter will be installed and then retested			
24 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010676	Cooler	3	In hallway adjacent to boys restroom	WT-042916-10693-A	< 1	WT-042916-10693-B	< 1				
25 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010677	Classroom	3	In classroom 304	WT-042916-10694-A	5.5	WT-042916-10694-B	< 1				
26 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010678	Classroom	3	In classroom 302	WT-042916-10695-A	20.6	WT-042916-10695-B	1	Filter will be installed and then retested			
27 JEFFERSON MIDDLE SCHOOL	5/14/2016	WS-010679	Other	3	In classroom 302 (spray nozzle)	WT-042916-10696-A	70.6	WT-042916-10696-B	5.4	Filter will be installed and then retested			

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.