



# Jefferson MS Lead in Water Test Results

## FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014909	3/11/2025	3/11/2026	Basement	Bottle Filler	In hallway adjacent to room L35 MDF	WF-03112025-014909	12/30/2025	FT-FY26-12112025-014909-A	<2	FT-FY26-12112025-014909-B	<2
WS-014910	3/11/2025	3/11/2026	Basement	Cooler	In hallway adjacent to room L35 MDF High Left	WF-03112025-014910	12/30/2025	FT-FY26-12112025-014910-A	<2	FT-FY26-12112025-014910-B	<2
WS-014911	3/11/2025	3/11/2026	Basement	Cooler	In hallway adjacent to room L35 MDF Low Right	WF-03112025-014911	12/30/2025	FT-FY26-12112025-014911-A	<2	FT-FY26-12112025-014911-B	<2
WS-014912	3/11/2025	3/11/2026	Basement	Break Room	In room L36 teacher collaboration	WF-03112025-014912	12/30/2025	FT-FY26-12112025-014912-A	<2	FT-FY26-12112025-014912-B	<2
WS-014913	3/11/2025	3/11/2026	Basement	Break Room	In room L16 staff lounge	WF-03112025-014913	12/30/2025	FT-FY26-12112025-014913-A	<2	FT-FY26-12112025-014913-B	<2
WS-014914	3/11/2025	3/11/2026	Basement	Combo Fountain	In room L16 staff lounge	WF-03112025-014914	12/30/2025	FT-FY26-12112025-014914-A	<2	FT-FY26-12112025-014914-B	<2
WS-014916	3/11/2025	3/11/2026	1	Combo Fountain	In room 113 reading in 114 office/workroom	WF-03112025-014916	12/30/2025	FT-FY26-12112025-014916-A	<2	FT-FY26-12112025-014916-B	<2
WS-014917	3/11/2025	3/11/2026	1	Combo Fountain	In room 111 reading in 110 makerspace	WF-03112025-014917	12/30/2025	FT-FY26-12112025-014917-A	<2	FT-FY26-12112025-014917-B	<2
WS-014920	3/11/2025	3/11/2026	1	Combo Fountain	In room 108 speech/ot/pt	WF-03112025-014920	12/30/2025	FT-FY26-12112025-014920-A	<2	FT-FY26-12112025-014920-B	<2
WS-014922	3/11/2025	3/11/2026	1	Combo Fountain	In room 119 speech/ot/pt	WF-03112025-014922	12/30/2025	FT-FY26-12112025-014922-A	<2	FT-FY26-12112025-014922-B	<2
WS-014924	3/11/2025	3/11/2026	1	Combo Fountain	In room 106 speech/ot/pt	WF-03112025-014924	12/30/2025	FT-FY26-12112025-014924-A	<2	FT-FY26-12112025-014924-B	<2
WS-014925	3/11/2025	3/11/2026	1	Break Room	In room 103 teacher collaboration	WF-03112025-014925	12/30/2025	FT-FY26-12112025-014925-A	<2	FT-FY26-12112025-014925-B	<2
WS-014930	3/11/2025	3/11/2026	1	Cooler	In hallway adjacent to stair D level 1 High Left	WF-03112025-014930	12/30/2025	FT-FY26-12112025-014930-A	<2	FT-FY26-12112025-014930-B	<2
WS-014931	3/11/2025	3/11/2026	1	Cooler	In hallway adjacent to stair D level 1 Low Right	WF-03112025-014931	12/30/2025	FT-FY26-12112025-014931-A	<2	FT-FY26-12112025-014931-B	<2
WS-014963	3/11/2025	3/11/2026	2	Combo Fountain	In room 219 classroom	WF-03112025-014963	12/30/2025	FT-FY26-12112025-014963-A	<2	FT-FY26-12112025-014963-B	<2
WS-014964	3/11/2025	3/11/2026	2	Break Room	In room 222	WF-03112025-014964	12/30/2025	FT-FY26-12112025-014964-A	<2	FT-FY26-12112025-014964-B	<2
WS-014966	3/11/2025	3/11/2026	3	Combo Fountain	In room 305 classroom	WF-03112025-014966	12/30/2025	FT-FY26-12112025-014966-A	<2	FT-FY26-12112025-014966-B	<2
WS-014967	3/11/2025	3/11/2026	3	Bottle Filler	In hallway across from stair B level 3	WF-03112025-014967	12/30/2025	FT-FY26-12112025-014967-A	<2	FT-FY26-12112025-014967-B	<2
WS-014969	3/11/2025	3/11/2026	3	Cooler	In hallway across from stair B level 3 Low Right	WF-03112025-014969	12/30/2025	FT-FY26-12112025-014969-A	<2	FT-FY26-12112025-014969-B	<2
WS-014975	3/11/2025	3/11/2026	1	Bottle Filler	In room 113 reading room	WF-03112025-014975	12/30/2025	FT-FY26-12112025-014975-A	<2	FT-FY26-12112025-014975-B	<2
WS-014976	3/11/2025	3/11/2026	1	Cooler	In room 113 reading room High Left	WF-03112025-014976	12/30/2025	FT-FY26-12112025-014976-A	<2	FT-FY26-12112025-014976-B	<2
WS-014977	3/11/2025	3/11/2026	1	Cooler	In room 113 reading room Low Right	WF-03112025-014977	12/30/2025	FT-FY26-12112025-014977-A	<2	FT-FY26-12112025-014977-B	<2
WS-014978	3/11/2025	3/11/2026	2	Bottle Filler	In hallway adjacent to room 203	WF-03112025-014978	12/30/2025	FT-FY26-12112025-014978-A	<2	FT-FY26-12112025-014978-B	<2
WS-014979	3/11/2025	3/11/2026	2	Cooler	In hallway adjacent to room 203 High Left	WF-03112025-014979	12/30/2025	FT-FY26-12112025-014979-A	<2	FT-FY26-12112025-014979-B	<2
WS-014982	3/11/2025	3/11/2026	Basement	Combo Fountain	In classroom L48 instrumental	WF-03112025-014982	12/30/2025	FT-FY26-12112025-014982-A	<2	FT-FY26-12112025-014982-B	<2
WS-014984	3/11/2025	3/11/2026	Basement	Combo Fountain	In classroom L43	WF-03112025-014984	12/30/2025	FT-FY26-12112025-014984-A	<2	FT-FY26-12112025-014984-B	<2
WS-014987	3/11/2025	3/11/2026	Basement	Combo Fountain	In classroom L39	WF-03112025-014987	12/30/2025	FT-FY26-12112025-014987-A	<2	FT-FY26-12112025-014987-B	<2
WS-014988	3/11/2025	3/11/2026	1	Bottle Filler	In gym on boy's locker room side	WF-03112025-014988	12/30/2025	FT-FY26-12112025-014988-A	<2	FT-FY26-12112025-014988-B	<2
WS-014989	3/11/2025	3/11/2026	1	Cooler	In gym on boy's locker room side High Left	WF-03112025-014989	12/30/2025	FT-FY26-12112025-014989-A	<2	FT-FY26-12112025-014989-B	<2
WS-014990	3/11/2025	3/11/2026	1	Cooler	In gym on boy's locker room side Low Right	WF-03112025-014990	12/30/2025	FT-FY26-12112025-014990-A	<2	FT-FY26-12112025-014990-B	<2
WS-014991	3/11/2025	3/11/2026	1	Bottle Filler	In gym on girls's locker room side	WF-03112025-014991	12/30/2025	FT-FY26-12112025-014991-A	<2	FT-FY26-12112025-014991-B	<2
WS-014992	3/11/2025	3/11/2026	1	Cooler	In gym on girls's locker room side High Left	WF-03112025-014992	12/30/2025	FT-FY26-12112025-014992-A	<2	FT-FY26-12112025-014992-B	<2
WS-014993	3/11/2025	3/11/2026	1	Cooler	In gym on girls's locker room side Low Right	WF-03112025-014993	12/30/2025	FT-FY26-12112025-014993-A	<2	FT-FY26-12112025-014993-B	<2
WS-014994	3/11/2025	3/11/2026	Basement	Bottle Filler	In cafeteria	WF-03112025-014994	12/30/2025	FT-FY26-12112025-014994-A	<2	FT-FY26-12112025-014994-B	<2

WS-014995	3/11/2025	3/11/2026	Basement	Cooler	In cafeteria	High Left	WF-03112025-014995	12/30/2025	FT-FY26-12112025-014995-A	<2	FT-FY26-12112025-014995-B	<2
WS-014996	3/11/2025	3/11/2026	Basement	Cooler	In cafeteria	Low Right	WF-03112025-014996	12/30/2025	FT-FY26-12112025-014996-A	<2	FT-FY26-12112025-014996-B	<2
WS-006983	3/11/2025	3/11/2026	Basement	Fountain	In Staff Lounge L63 (East Basement)		WF-03112025-006983	12/30/2025	FT-FY26-12112025-006983-A	<2	FT-FY26-12112025-006983-B	<2

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014902	12/4/2025	12/4/2026	Basement	Food Prep Sink	In kitchen third clockwise from entry	WF-12042025-014902	12/30/2025	FT-FY26-12112025-014902-A	<2	FT-FY26-12112025-014902-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.