



Jefferson Middle School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014909	4/4/2022	4/4/2023	Basement	Bottle Filler	In hallway adjacent to room L35 MDF	WF-04042022-014909	1/23/2023	FT-FY23-01102023-014909-A	<1	FT-FY23-01102023-014909-B	<1
WS-014910	4/4/2022	4/4/2023	Basement	Cooler	In hallway adjacent to room L35 MDF High Left	WF-04042022-014910	1/23/2023	FT-FY23-01102023-014910-A	<1	FT-FY23-01102023-014910-B	<1
WS-014911	4/4/2022	4/4/2023	Basement	Cooler	In hallway adjacent to room L35 MDF Low Right	WF-04042022-014911	1/23/2023	FT-FY23-01102023-014911-A	<1	FT-FY23-01102023-014911-B	<1
WS-014912	4/4/2022	4/4/2023	Basement	Break Room	In room L36 teacher collaboration	WF-04042022-014912	1/23/2023	FT-FY23-01102023-014912-A	<1	FT-FY23-01102023-014912-B	<1
WS-014913	4/4/2022	4/4/2023	Basement	Break Room	In room L16 staff lounge	WF-04042022-014913	1/23/2023	FT-FY23-01102023-014913-A	<1	FT-FY23-01102023-014913-B	<1
WS-014914	4/4/2022	4/4/2023	Basement	Combo Fountain	In room L16 staff lounge	WF-04042022-014914	1/23/2023	FT-FY23-01102023-014914-A	<1	FT-FY23-01102023-014914-B	<1
WS-014917	4/4/2022	4/4/2023	1	Combo Fountain	In room 111 reading in 110 makerspace	WF-04042022-014917	1/23/2023	FT-FY23-01102023-014917-A	<1	FT-FY23-01102023-014917-B	<1
WS-014920	4/4/2022	4/4/2023	1	Combo Fountain	In room 108 speech/ot/pt	WF-04042022-014920	1/23/2023	FT-FY23-01102023-014920-A	<1	FT-FY23-01102023-014920-B	<1
WS-014922	4/4/2022	4/4/2023	1	Combo Fountain	In room 119 speech/ot/pt	WF-04042022-014922	1/23/2023	FT-FY23-01102023-014922-A	<1	FT-FY23-01102023-014922-B	<1
WS-014925	4/4/2022	4/4/2023	1	Break Room	In room 103 teacher collaboration	WF-04042022-014925	1/23/2023	FT-FY23-01102023-014925-A	<1	FT-FY23-01102023-014925-B	<1
WS-014927	4/4/2022	4/4/2023	1	Health Suite	In room 127 treatment	WF-04042022-014927	1/23/2023	FT-FY23-01102023-014927-A	<1	FT-FY23-01102023-014927-B	<1
WS-014928	4/4/2022	4/4/2023	1	Combo Fountain	In room 127 treatment	WF-04042022-014928	1/23/2023	FT-FY23-01102023-014928-A	<1	FT-FY23-01102023-014928-B	<1
WS-014929	4/4/2022	4/4/2023	1	Bottle Filler	In hallway adjacent to stair D level 1	WF-04042022-014929	1/23/2023	FT-FY23-01102023-014929-A	<1	FT-FY23-01102023-014929-B	<1
WS-014930	4/4/2022	4/4/2023	1	Cooler	In hallway adjacent to stair D level 1 High Left	WF-04042022-014930	1/23/2023	FT-FY23-01102023-014930-A	<1	FT-FY23-01102023-014930-B	<1
WS-014963	4/4/2022	4/4/2023	2	Combo Fountain	In room 219 classroom	WF-04042022-014963	1/23/2023	FT-FY23-01102023-014963-A	<1	FT-FY23-01102023-014963-B	<1
WS-014964	4/4/2022	4/4/2023	2	Break Room	In room 222	WF-04042022-014964	1/23/2023	FT-FY23-01102023-014964-A	<1	FT-FY23-01102023-014964-B	<1
WS-014966	4/4/2022	4/4/2023	3	Combo Fountain	In room 305 classroom	WF-04042022-014966	1/23/2023	FT-FY23-01102023-014966-A	<1	FT-FY23-01102023-014966-B	<1
WS-014967	4/4/2022	4/4/2023	3	Bottle Filler	In hallway across from stair B level 3	WF-04042022-014967	1/23/2023	FT-FY23-01102023-014967-A	<1	FT-FY23-01102023-014967-B	<1
WS-014969	4/4/2022	4/4/2023	3	Cooler	In hallway across from stair B level 3 Low Right	WF-04042022-014969	1/23/2023	FT-FY23-01102023-014969-A	<1	FT-FY23-01102023-014969-B	<1
WS-014975	4/4/2022	4/4/2023	1	Bottle Filler	In room 113 reading room	WF-04042022-014975	1/23/2023	FT-FY23-01102023-014975-A	<1	FT-FY23-01102023-014975-B	<1
WS-014978	4/4/2022	4/4/2023	2	Bottle Filler	In hallway adjacent to room 203	WF-04042022-014978	1/23/2023	FT-FY23-01102023-014978-A	<1	FT-FY23-01102023-014978-B	<1
WS-014982	4/4/2022	4/4/2023	Basement	Combo Fountain	In classroom L48 instrumental	WF-04042022-014982	1/23/2023	FT-FY23-01102023-014982-A	<1	FT-FY23-01102023-014982-B	<1
WS-014984	4/4/2022	4/4/2023	Basement	Combo Fountain	In classroom L43	WF-04042022-014984	1/23/2023	FT-FY23-01102023-014984-A	<1	FT-FY23-01102023-014984-B	<1
WS-014987	4/4/2022	4/4/2023	Basement	Combo Fountain	In classroom L39	WF-04042022-014987	1/23/2023	FT-FY23-01102023-014987-A	<1	FT-FY23-01102023-014987-B	<1
WS-014988	4/4/2022	4/4/2023	1	Bottle Filler	In gym on boy's locker room side	WF-04042022-014988	1/23/2023	FT-FY23-01102023-014988-A	<1	FT-FY23-01102023-014988-B	<1
WS-014989	4/4/2022	4/4/2023	1	Cooler	In gym on boy's locker room side High Left	WF-04042022-014989	1/23/2023	FT-FY23-01102023-014989-A	<1	FT-FY23-01102023-014989-B	<1
WS-014990	4/4/2022	4/4/2023	1	Cooler	In gym on boy's locker room side Low Right	WF-04042022-014990	1/23/2023	FT-FY23-01102023-014990-A	<1	FT-FY23-01102023-014990-B	<1
WS-014991	4/4/2022	4/4/2023	1	Bottle Filler	In gym on girls's locker room side	WF-04042022-014991	1/23/2023	FT-FY23-01102023-014991-A	<1	FT-FY23-01102023-014991-B	<1
WS-014992	4/4/2022	4/4/2023	1	Cooler	In gym on girls's locker room side High Left	WF-04042022-014992	1/23/2023	FT-FY23-01102023-014992-A	<1	FT-FY23-01102023-014992-B	<1
WS-014993	4/4/2022	4/4/2023	1	Cooler	In gym on girls's locker room side Low Right	WF-04042022-014993	1/23/2023	FT-FY23-01102023-014993-A	<1	FT-FY23-01102023-014993-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014902	1/9/2023	1/9/2024	Basement	Food Prep Sink	In kitchen third clockwise from entry	WF-01092023-014902	1/23/2023	FT-FY23-01102023-014902-A	<1	FT-FY23-01102023-014902-B	<1