



# Jefferson Middle School Lead in Water Test Results

## FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 006983	3/20/2024	3/20/2025	Basement	Fountain	In Staff Lounge L63 (East Basement)	WF-03202024-006983	1/3/2025	FT-FY25-11082024-006983-A	<2	FT-FY25-11082024-006983-B	<2
WS-014909	3/20/2024	3/20/2025	Basement	Bottle Filler	In hallway adjacent to room L35 MDF	WF-03202024-014909	1/3/2025	FT-FY25-11082024-014909-A	<2	FT-FY25-11082024-014909-B	<2
WS-014910	3/20/2024	3/20/2025	Basement	Cooler	In hallway adjacent to room L35 MDF High Left	WF-03202024-014910	1/3/2025	FT-FY25-11082024-014910-A	<2	FT-FY25-11082024-014910-B	<2
WS-014911	3/20/2024	3/20/2025	Basement	Cooler	In hallway adjacent to room L35 MDF Low Right	WF-03202024-014911	1/3/2025	FT-FY25-11082024-014911-A	<2	FT-FY25-11082024-014911-B	<2
WS-014913	3/20/2024	3/20/2025	Basement	Break Room	In room L16 staff lounge	WF-03202024-014913	1/3/2025	FT-FY25-11082024-014913-A	<2	FT-FY25-11082024-014913-B	<2
WS-014914	3/20/2024	3/20/2025	Basement	Combo Fountain	In room L16 staff lounge	WF-03202024-014914	1/3/2025	FT-FY25-11082024-014914-A	<2	FT-FY25-11082024-014914-B	<2
WS-014916	3/20/2024	3/20/2025	1	Combo Fountain	In room 113 reading in 114 office/workroom	WF-03202024-014916	1/3/2025	FT-FY25-11082024-014916-A	<2	FT-FY25-11082024-014916-B	<2
WS-014917	3/20/2024	3/20/2025	1	Combo Fountain	In room 111 reading in 110 makerspace	WF-03202024-014917	1/3/2025	FT-FY25-11082024-014917-A	<2	FT-FY25-11082024-014917-B	<2
WS-014920	3/20/2024	3/20/2025	1	Combo Fountain	In room 108 speech/ot/pt	WF-03202024-014920	1/3/2025	FT-FY25-11082024-014920-A	<2	FT-FY25-11082024-014920-B	<2
WS-014922	3/20/2024	3/20/2025	1	Combo Fountain	In room 119 speech/ot/pt	WF-03202024-014922	1/3/2025	FT-FY25-11082024-014922-A	<2	FT-FY25-11082024-014922-B	<2
WS-014924	3/20/2024	3/20/2025	1	Combo Fountain	In room 106 speech/ot/pt	WF-03202024-014924	1/3/2025	FT-FY25-11082024-014924-A	<2	FT-FY25-11082024-014924-B	<2
WS-014925	3/20/2024	3/20/2025	1	Break Room	In room 103 teacher collaboration	WF-03202024-014925	1/3/2025	FT-FY25-11082024-014925-A	<2	FT-FY25-11082024-014925-B	<2
WS-014927	3/20/2024	3/20/2025	1	Health Suite	In room 127 treatment	WF-03202024-014927	1/3/2025	FT-FY25-11082024-014927-A	<2	FT-FY25-11082024-014927-B	<2
WS-014928	3/20/2024	3/20/2025	1	Combo Fountain	In room 127 treatment	WF-03202024-014928	1/3/2025	FT-FY25-11082024-014928-A	<2	FT-FY25-11082024-014928-B	<2
WS-014929	3/20/2024	3/20/2025	1	Bottle Filler	In hallway adjacent to stair D level 1	WF-03202024-014929	1/3/2025	FT-FY25-11082024-014929-A	<2	FT-FY25-11082024-014929-B	<2
WS-014931	3/20/2024	3/20/2025	1	Cooler	In hallway adjacent to stair D level 1 Low Right	WF-03202024-014931	1/3/2025	FT-FY25-11082024-014931-A	<2	FT-FY25-11082024-014931-B	<2
WS-014963	3/20/2024	3/20/2025	2	Combo Fountain	In room 219 classroom	WF-03202024-014963	1/3/2025	FT-FY25-11082024-014963-A	<2	FT-FY25-11082024-014963-B	<2
WS-014964	3/20/2024	3/20/2025	2	Break Room	In room 222	WF-03202024-014964	1/3/2025	FT-FY25-11082024-014964-A	<2	FT-FY25-11082024-014964-B	<2
WS-014966	3/20/2024	3/20/2025	3	Combo Fountain	In room 305 classroom	WF-03202024-014966	1/3/2025	FT-FY25-11082024-014966-A	<2	FT-FY25-11082024-014966-B	<2
WS-014967	3/20/2024	3/20/2025	3	Bottle Filler	In hallway across from stair B level 3	WF-03202024-014967	1/3/2025	FT-FY25-11082024-014967-A	<2	FT-FY25-11082024-014967-B	<2
WS-014975	3/20/2024	3/20/2025	1	Bottle Filler	In room 113 reading room	WF-03202024-014975	1/3/2025	FT-FY25-11082024-014975-A	<2	FT-FY25-11082024-014975-B	<2
WS-014976	3/20/2024	3/20/2025	1	Cooler	In room 113 reading room High Left	WF-03202024-014976	1/3/2025	FT-FY25-11082024-014976-A	<2	FT-FY25-11082024-014976-B	<2
WS-014977	3/20/2024	3/20/2025	1	Cooler	In room 113 reading room Low Right	WF-03202024-014977	1/3/2025	FT-FY25-11082024-014977-A	<2	FT-FY25-11082024-014977-B	<2
WS-014978	3/20/2024	3/20/2025	2	Bottle Filler	In hallway adjacent to room 203	WF-03202024-014978	1/3/2025	FT-FY25-11082024-014978-A	<2	FT-FY25-11082024-014978-B	<2
WS-014982	3/20/2024	3/20/2025	Basement	Combo Fountain	In classroom L48 instrumental	WF-03202024-014982	1/3/2025	FT-FY25-11082024-014982-A	<2	FT-FY25-11082024-014982-B	<2
WS-014984	3/20/2024	3/20/2025	Basement	Combo Fountain	In classroom L43	WF-03202024-014984	1/3/2025	FT-FY25-11082024-014984-A	<2	FT-FY25-11082024-014984-B	<2
WS-014987	3/20/2024	3/20/2025	Basement	Combo Fountain	In classroom L39	WF-03202024-014987	1/3/2025	FT-FY25-11082024-014987-A	<2	FT-FY25-11082024-014987-B	<2
WS-014988	3/20/2024	3/20/2025	1	Bottle Filler	In gym on boy's locker room side	WF-03202024-014988	1/3/2025	FT-FY25-11082024-014988-A	<2	FT-FY25-11082024-014988-B	<2
WS-014989	3/20/2024	3/20/2025	1	Cooler	In gym on boy's locker room side High Left	WF-03202024-014989	1/3/2025	FT-FY25-11082024-014989-A	<2	FT-FY25-11082024-014989-B	<2
WS-014990	3/20/2024	3/20/2025	1	Cooler	In gym on boy's locker room side Low Right	WF-03202024-014990	1/3/2025	FT-FY25-11082024-014990-A	<2	FT-FY25-11082024-014990-B	<2
WS-014991	3/20/2024	3/20/2025	1	Bottle Filler	In gym on girls's locker room side	WF-03202024-014991	1/3/2025	FT-FY25-11082024-014991-A	<2	FT-FY25-11082024-014991-B	<2
WS-014992	3/20/2024	3/20/2025	1	Cooler	In gym on girls's locker room side High Left	WF-03202024-014992	1/3/2025	FT-FY25-11082024-014992-A	<2	FT-FY25-11082024-014992-B	<2
WS-014993	3/20/2024	3/20/2025	1	Cooler	In gym on girls's locker room side Low Right	WF-03202024-014993	1/3/2025	FT-FY25-11082024-014993-A	<2	FT-FY25-11082024-014993-B	<2

WS-014994	3/20/2024	3/20/2025	Basement	Bottle Filler	In cafeteria		WF-03202024-014994	1/3/2025	FT-FY25-11082024-014994-A	<2	FT-FY25-11082024-014994-B	<2
WS-014995	3/20/2024	3/20/2025	Basement	Cooler	In cafeteria	High Left	WF-03202024-014995	1/3/2025	FT-FY25-11082024-014995-A	<2	FT-FY25-11082024-014995-B	<2
WS-014996	3/20/2024	3/20/2025	Basement	Cooler	In cafeteria	Low Right	WF-03202024-014996	1/3/2025	FT-FY25-11082024-014996-A	<2	FT-FY25-11082024-014996-B	<2

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014902	12/23/2024	12/23/2025	Basement	Food Prep Sink	In kitchen third clockwise from entry	WF-12232024-014902	1/3/2025	FT-FY25-11082024-014902-A	<2	FT-FY25-11082024-014902-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.