



Jefferson Middle School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014909	4/12/2021	4/12/2022	Basement	Bottle Filler	In hallway adjacent to room L35 MDF	WF-04122021-014909	3/9/2022	FT-FY22-02092022-014909-A	<1	FT-FY22-02092022-014909-B	<1
WS-014910	4/12/2021	4/12/2022	Basement	Cooler	In hallway adjacent to room L35 MDF High Left	WF-04122021-014910	3/9/2022	FT-FY22-02092022-014910-A	<1	FT-FY22-02092022-014910-B	<1
WS-014911	4/12/2021	4/12/2022	Basement	Cooler	In hallway adjacent to room L35 MDF Low Right	WF-04122021-014911	3/9/2022	FT-FY22-02092022-014911-A	<1	FT-FY22-02092022-014911-B	<1
WS-014912	4/12/2021	4/12/2022	Basement	Break Room	In room L36 teacher collaboration	WF-04122021-014912	3/9/2022	FT-FY22-02092022-014912-A	<1	FT-FY22-02092022-014912-B	<1
WS-014913	4/12/2021	4/12/2022	Basement	Break Room	In room L16 staff lounge	WF-04122021-014913	3/9/2022	FT-FY22-02092022-014913-A	<1	FT-FY22-02092022-014913-B	<1
WS-014914	4/12/2021	4/12/2022	Basement	Combo Fountain	In room L16 staff lounge	WF-04122021-014914	3/9/2022	FT-FY22-02092022-014914-A	<1	FT-FY22-02092022-014914-B	<1
WS-014916	4/12/2021	4/12/2022	1	Combo Fountain	In room 113 reading in 114 office/workroom	WF-04122021-014916	3/9/2022	FT-FY22-02092022-014916-A	<1	FT-FY22-02092022-014916-B	<1
WS-014917	4/12/2021	4/12/2022	1	Combo Fountain	In room 111 reading in 110 makerspace	WF-04122021-014917	3/9/2022	FT-FY22-02092022-014917-A	<1	FT-FY22-02092022-014917-B	<1
WS-014920	4/12/2021	4/12/2022	1	Combo Fountain	In room 108 speech/ot/pt	WF-04122021-014920	3/9/2022	FT-FY22-02092022-014920-A	1.3	FT-FY22-02092022-014920-B	<1
WS-014922	4/12/2021	4/12/2022	1	Combo Fountain	In room 119 speech/ot/pt	WF-04122021-014922	3/9/2022	FT-FY22-02092022-014922-A	<1	FT-FY22-02092022-014922-B	<1
WS-014924	4/12/2021	4/12/2022	1	Combo Fountain	In room 106 speech/ot/pt	WF-04122021-014924	3/9/2022	FT-FY22-02092022-014924-A	<1	FT-FY22-02092022-014924-B	<1
WS-014925	4/12/2021	4/12/2022	1	Break Room	In room 103 teacher collaboration	WF-04122021-014925	3/9/2022	FT-FY22-02092022-014925-A	<1	FT-FY22-02092022-014925-B	<1
WS-014927	4/12/2021	4/12/2022	1	Health Suite	In room 127 treatment	WF-04122021-014927	3/9/2022	FT-FY22-02092022-014927-A	<1	FT-FY22-02092022-014927-B	<1
WS-014928	4/12/2021	4/12/2022	1	Combo Fountain	In room 127 treatment	WF-04122021-014928	3/9/2022	FT-FY22-02092022-014928-A	1.7	FT-FY22-02092022-014928-B	<1
WS-014929	4/12/2021	4/12/2022	1	Bottle Filler	In hallway adjacent to stair D level 1	WF-04122021-014929	3/9/2022	FT-FY22-02092022-014929-A	<1	FT-FY22-02092022-014929-B	<1
WS-014930	4/12/2021	4/12/2022	1	Cooler	In hallway adjacent to stair D level 1 High Left	WF-04122021-014930	3/9/2022	FT-FY22-02092022-014930-A	<1	FT-FY22-02092022-014930-B	<1
WS-014963	4/12/2021	4/12/2022	2	Combo Fountain	In room 219 classroom	WF-04122021-014963	3/9/2022	FT-FY22-02092022-014963-A	<1	FT-FY22-02092022-014963-B	<1
WS-014964	8/18/2021	8/18/2022	2	Break Room	In room 222	WF-08182021-014964	3/9/2022	FT-FY22-02092022-014964-A	<1	FT-FY22-02092022-014964-B	<1
WS-014966	4/12/2021	4/12/2022	3	Combo Fountain	In room 305 classroom	WF-04122021-014966	3/9/2022	FT-FY22-02092022-014966-A	<1	FT-FY22-02092022-014966-B	<1
WS-014967	4/12/2021	4/12/2022	3	Bottle Filler	In hallway across from stair B level 3	WF-04122021-014967	3/9/2022	FT-FY22-02092022-014967-A	<1	FT-FY22-02092022-014967-B	<1
WS-014968	4/12/2021	4/12/2022	3	Cooler	In hallway across from stair B level 3 High Left	WF-04122021-014968	3/9/2022	FT-FY22-02092022-014968-A	<1	FT-FY22-02092022-014968-B	<1
WS-014975	4/12/2021	4/12/2022	1	Bottle Filler	In room 113 reading room	WF-04122021-014975	3/9/2022	FT-FY22-02092022-014975-A	<1	FT-FY22-02092022-014975-B	<1
WS-014976	4/12/2021	4/12/2022	1	Cooler	In room 113 reading room High Left	WF-04122021-014976	3/9/2022	FT-FY22-02092022-014976-A	<1	FT-FY22-02092022-014976-B	<1
WS-014977	4/12/2021	4/12/2022	1	Cooler	In room 113 reading room Low Right	WF-04122021-014977	3/9/2022	FT-FY22-02092022-014977-A	<1	FT-FY22-02092022-014977-B	<1
WS-014978	4/12/2021	4/12/2022	2	Bottle Filler	In hallway adjacent to room 203	WF-04122021-014978	3/9/2022	FT-FY22-02092022-014978-A	<1	FT-FY22-02092022-014978-B	<1
WS-014979	4/12/2021	4/12/2022	2	Cooler	In hallway adjacent to room 203 High Left	WF-04122021-014979	3/9/2022	FT-FY22-02092022-014979-A	<1	FT-FY22-02092022-014979-B	<1
WS-014980	4/12/2021	4/12/2022	2	Cooler	In hallway adjacent to room 203 Low Right	WF-04122021-014980	3/9/2022	FT-FY22-02092022-014980-A	<1	FT-FY22-02092022-014980-B	<1
WS-014982	4/12/2021	4/12/2022	Basement	Combo Fountain	In classroom L48 instrumental	WF-04122021-014982	3/9/2022	FT-FY22-02092022-014982-A	<1	FT-FY22-02092022-014982-B	<1
WS-014984	4/12/2021	4/12/2022	Basement	Combo Fountain	In classroom L43	WF-04122021-014984	3/9/2022	FT-FY22-02092022-014984-A	<1	FT-FY22-02092022-014984-B	<1
WS-014987	4/12/2021	4/12/2022	Basement	Combo Fountain	In classroom L39	WF-04122021-014987	3/9/2022	FT-FY22-02092022-014987-A	<1	FT-FY22-02092022-014987-B	<1
WS-014988	4/12/2021	4/12/2022	1	Bottle Filler	In gym on boy's locker room side	WF-04122021-014988	3/9/2022	FT-FY22-02092022-014988-A	<1	FT-FY22-02092022-014988-B	<1
WS-014989	4/12/2021	4/12/2022	1	Cooler	In gym on boy's locker room side High Left	WF-04122021-014989	3/9/2022	FT-FY22-02092022-014989-A	<1	FT-FY22-02092022-014989-B	<1
WS-014990	4/12/2021	4/12/2022	1	Cooler	In gym on boy's locker room side Low Right	WF-04122021-014990	3/9/2022	FT-FY22-02092022-014990-A	<1	FT-FY22-02092022-014990-B	<1
WS-014991	4/12/2021	4/12/2022	1	Bottle Filler	In gym on girls's locker room side	WF-04122021-014991	3/9/2022	FT-FY22-02092022-014991-A	<1	FT-FY22-02092022-014991-B	<1

WS-014993	4/12/2021	4/12/2022	1	Cooler	In gym on girls's locker room side	Low Right	WF-04122021-014993	3/9/2022	FT-FY22-02092022-014993-A	<1	FT-FY22-02092022-014993-B	<1
-----------	-----------	-----------	---	--------	------------------------------------	-----------	--------------------	----------	---------------------------	----	---------------------------	----

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014902	2/7/2022	2/7/2023	Basement	Food Prep Sink	In kitchen third clockwise from entry	WF-02072022-014902	3/9/2022	FT-FY22-02092022-014902-A	<1	FT-FY22-02092022-014902-B	<1