



Jefferson Middle School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014909	8/12/2020	8/12/2021	Basement	Bottle Filler	In hallway adjacent to room L35 MDF	WF-08122020-014909	4/12/2021	FT-FY21-042021-014909-A	<1	FT-FY21-042021-014909-B	<1
WS-014910	8/12/2020	8/12/2021	Basement	Cooler	In hallway adjacent to room L35 MDF High Left	WF-08122020-014910	4/12/2021	FT-FY21-042021-014910-A	<1	FT-FY21-042021-014910-B	<1
WS-014911	8/12/2020	8/12/2021	Basement	Cooler	In hallway adjacent to room L35 MDF Low Right	WF-08122020-014911	4/12/2021	FT-FY21-042021-014911-A	<1	FT-FY21-042021-014911-B	<1
WS-014912	5/13/2020	5/13/2021	Basement	Break Room	In room L36 teacher collaboration	WF-05132020-014912	4/12/2021	FT-FY21-042021-014912-A	<1	FT-FY21-042021-014912-B	<1
WS-014913	5/13/2020	5/13/2021	Basement	Break Room	In room L16 staff lounge	WF-05132020-014913	4/12/2021	FT-FY21-042021-014913-A	<1	FT-FY21-042021-014913-B	<1
WS-014914	5/13/2020	5/13/2021	Basement	Combo Fountain	In room L16 staff lounge	WF-05132020-014914	4/12/2021	FT-FY21-042021-014914-A	<1	FT-FY21-042021-014914-B	<1
WS-014916	5/13/2020	5/13/2021	1	Combo Fountain	In room 113 reading in 114 office/workroom	WF-05132020-014916	4/12/2021	FT-FY21-042021-014916-A	<1	FT-FY21-042021-014916-B	<1
WS-014917	5/13/2020	5/13/2021	1	Combo Fountain	In room 111 reading in 110 makerspace	WF-05132020-014917	4/12/2021	FT-FY21-042021-014917-A	<1	FT-FY21-042021-014917-B	<1
WS-014920	5/13/2020	5/13/2021	1	Combo Fountain	In room 108 speech/ot/pt	WF-05132020-014920	4/12/2021	FT-FY21-042021-014920-A	<1	FT-FY21-042021-014920-B	<1
WS-014922	5/13/2020	5/13/2021	1	Combo Fountain	In room 119 speech/ot/pt	WF-05132020-014922	4/12/2021	FT-FY21-042021-014922-A	<1	FT-FY21-042021-014922-B	<1
WS-014924	5/13/2020	5/13/2021	1	Combo Fountain	In room 106 speech/ot/pt	WF-05132020-014924	4/12/2021	FT-FY21-042021-014924-A	<1	FT-FY21-042021-014924-B	<1
WS-014925	5/13/2020	5/13/2021	1	Break Room	In room 103 teacher collaboration	WF-05132020-014925	4/12/2021	FT-FY21-042021-014925-A	<1	FT-FY21-042021-014925-B	<1
WS-014927	5/13/2020	5/13/2021	1	Health Suite	In room 127 treatment	WF-05132020-014927	4/12/2021	FT-FY21-042021-014927-A	<1	FT-FY21-042021-014927-B	<1
WS-014928	5/13/2020	5/13/2021	1	Combo Fountain	In room 127 treatment	WF-05132020-014928	4/12/2021	FT-FY21-042021-014928-A	<1	FT-FY21-042021-014928-B	<1
WS-014929	5/13/2020	5/13/2021	1	Bottle Filler	In hallway adjacent to stair D level 1	WF-05132020-014929	4/12/2021	FT-FY21-042021-014929-A	<1	FT-FY21-042021-014929-B	<1
WS-014930	5/13/2020	5/13/2021	1	Cooler	In hallway adjacent to stair D level 1 High Left	WF-05132020-014930	4/12/2021	FT-FY21-042021-014930-A	<1	FT-FY21-042021-014930-B	<1
WS-014931	5/13/2020	5/13/2021	1	Cooler	In hallway adjacent to stair D level 1 Low Right	WF-05132020-014931	4/12/2021	FT-FY21-042021-014931-A	<1	FT-FY21-042021-014931-B	<1
WS-014963	5/13/2020	5/13/2021	2	Combo Fountain	In room 219 classroom	WF-05132020-014963	4/12/2021	FT-FY21-042021-014963-A	<1	FT-FY21-042021-014963-B	<1
WS-014964	5/13/2020	5/13/2021	2	Break Room	In room 222	WF-05132020-014964	4/12/2021	FT-FY21-042021-014964-A	<1	FT-FY21-042021-014964-B	<1
WS-014966	5/13/2020	5/13/2021	3	Combo Fountain	In room 305 classroom	WF-05132020-014966	4/12/2021	FT-FY21-042021-014966-A	<1	FT-FY21-042021-014966-B	<1
WS-014967	8/12/2020	8/12/2021	3	Bottle Filler	In hallway across from stair B level 3	WF-08122020-014967	4/12/2021	FT-FY21-042021-014967-A	<1	FT-FY21-042021-014967-B	<1
WS-014968	8/12/2020	8/12/2021	3	Cooler	In hallway across from stair B level 3 High Left	WF-08122020-014968	4/12/2021	FT-FY21-042021-014968-A	<1	FT-FY21-042021-014968-B	<1
WS-014969	8/12/2020	8/12/2021	3	Cooler	In hallway across from stair B level 3 Low Right	WF-08122020-014969	4/12/2021	FT-FY21-042021-014969-A	1.0	FT-FY21-042021-014969-B	<1
WS-014975	5/13/2020	5/13/2021	1	Bottle Filler	In room 113 reading room	WF-05132020-014975	4/12/2021	FT-FY21-042021-014975-A	<1	FT-FY21-042021-014975-B	<1
WS-014976	5/13/2020	5/13/2021	1	Cooler	In room 113 reading room High Left	WF-05132020-014976	4/12/2021	FT-FY21-042021-014976-A	<1	FT-FY21-042021-014976-B	<1
WS-014977	5/13/2020	5/13/2021	1	Cooler	In room 113 reading room Low Right	WF-05132020-014977	4/12/2021	FT-FY21-042021-014977-A	<1	FT-FY21-042021-014977-B	<1
WS-014979	8/12/2020	8/12/2021	2	Cooler	In hallway adjacent to room 203 High Left	WF-08122020-014979	4/12/2021	FT-FY21-042021-014979-A	<1	FT-FY21-042021-014979-B	<1
WS-014980	8/12/2020	8/12/2021	2	Cooler	In hallway adjacent to room 203 Low Right	WF-08122020-014980	4/12/2021	FT-FY21-042021-014980-A	<1	FT-FY21-042021-014980-B	<1
WS-014982	8/11/2020	8/11/2021	Basement	Combo Fountain	In classroom L48 instrumental	WF-08112020-014982	4/12/2021	FT-FY21-042021-014982-A	<1	FT-FY21-042021-014982-B	<1
WS-014984	8/11/2020	8/11/2021	Basement	Combo Fountain	In classroom L43	WF-08112020-014984	4/12/2021	FT-FY21-042021-014984-A	<1	FT-FY21-042021-014984-B	<1
WS-014987	8/11/2020	8/11/2021	Basement	Combo Fountain	In classroom L39	WF-08112020-014987	4/12/2021	FT-FY21-042021-014987-A	<1	FT-FY21-042021-014987-B	<1
WS-014988	8/11/2020	8/11/2021	1	Bottle Filler	In gym on boy's locker room side	WF-08112020-014988	4/12/2021	FT-FY21-042021-014988-A	<1	FT-FY21-042021-014988-B	<1

WS-014989	8/11/2020	8/11/2021	1	Cooler	In gym on boy's locker room side	High Left	WF-08112020-014989	4/12/2021	FT-FY21-042021-014989-A	<1	FT-FY21-042021-014989-B	<1
WS-014990	8/11/2020	8/11/2021	1	Cooler	In gym on boy's locker room side	Low Right	WF-08112020-014990	4/12/2021	FT-FY21-042021-014990-A	<1	FT-FY21-042021-014990-B	<1
WS-014991	8/11/2020	8/11/2021	1	Bottle Filler	In gym on girls's locker room side		WF-08112020-014991	4/12/2021	FT-FY21-042021-014991-A	<1	FT-FY21-042021-014991-B	<1
WS-014992	8/11/2020	8/11/2021	1	Cooler	In gym on girls's locker room side	High Left	WF-08112020-014992	4/12/2021	FT-FY21-042021-014992-A	<1	FT-FY21-042021-014992-B	<1
WS-014993	8/11/2020	8/11/2021	1	Cooler	In gym on girls's locker room side	Low Right	WF-08112020-014993	4/12/2021	FT-FY21-042021-014993-A	<1	FT-FY21-042021-014993-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-014902	2/17/2021	2/17/2022	Basement	Food Prep Sink	In kitchen third clockwise from entry	WF-02172021-014902	4/12/2021	FT-FY21-042021-014902-A	<1	FT-FY21-042021-014902-B	<1	

FY21 Filter Test

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-014978	8/12/2020	8/12/2021	2	Bottle Filler	In hallway adjacent to room 203	WF-08122020-014978	4/12/2021	FT-FY21-042021-014978-A	15.0	FT-FY21-042021-014978-B	<1	

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-014978	4/12/2021	4/12/2022	2	Bottle Filler	In hallway adjacent to room 203	WF-04122021-014978	5/4/2021	FT-FY21-042021-014978-A	<1	FT-FY21-042021-014978-B	<1	