



Jefferson Middle School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014909	3/27/2023	3/27/2024	Basement	Bottle Filler	In hallway adjacent to room L35 MDF	WF-03272023-014909	12/30/2023	FT-FY24-11012023-014909-A	<1	FT-FY24-11012023-014909-B	<1
WS-014910	3/27/2023	3/27/2024	Basement	Cooler	In hallway adjacent to room L35 MDF High Left	WF-03272023-014910	12/30/2023	FT-FY24-11012023-014910-A	<1	FT-FY24-11012023-014910-B	<1
WS-014911	3/27/2023	3/27/2024	Basement	Cooler	In hallway adjacent to room L35 MDF Low Right	WF-03272023-014911	12/30/2023	FT-FY24-11012023-014911-A	<1	FT-FY24-11012023-014911-B	<1
WS-014912	3/27/2023	3/27/2024	Basement	Break Room	In room L36 teacher collaboration	WF-03272023-014912	12/30/2023	FT-FY24-11012023-014912-A	<1	FT-FY24-11012023-014912-B	<1
WS-014913	3/27/2023	3/27/2024	Basement	Break Room	In room L16 staff lounge	WF-03272023-014913	12/30/2023	FT-FY24-11012023-014913-A	<1	FT-FY24-11012023-014913-B	<1
WS-014914	3/27/2023	3/27/2024	Basement	Combo Fountain	In room L16 staff lounge	WF-03272023-014914	12/30/2023	FT-FY24-11012023-014914-A	2.4	FT-FY24-11012023-014914-B	<1
WS-014916	3/27/2023	3/27/2024	1	Combo Fountain	In room 113 reading in 114 office/workroom	WF-03272023-014916	12/30/2023	FT-FY24-11012023-014916-A	<1	FT-FY24-11012023-014916-B	<1
WS-014917	3/27/2023	3/27/2024	1	Combo Fountain	In room 111 reading in 110 makerspace	WF-03272023-014917	12/30/2023	FT-FY24-11012023-014917-A	1.5	FT-FY24-11012023-014917-B	<1
WS-014920	3/27/2023	3/27/2024	1	Combo Fountain	In room 108 speech/ot/pt	WF-03272023-014920	12/30/2023	FT-FY24-11012023-014920-A	1.8	FT-FY24-11012023-014920-B	<1
WS-014922	3/27/2023	3/27/2024	1	Combo Fountain	In room 119 speech/ot/pt	WF-03272023-014922	12/30/2023	FT-FY24-11012023-014922-A	<1	FT-FY24-11012023-014922-B	<1
WS-014924	3/27/2023	3/27/2024	1	Combo Fountain	In room 106 speech/ot/pt	WF-03272023-014924	12/30/2023	FT-FY24-11012023-014924-A	1.3	FT-FY24-11012023-014924-B	<1
WS-014925	3/27/2023	3/27/2024	1	Break Room	In room 103 teacher collaboration	WF-03272023-014925	12/30/2023	FT-FY24-11012023-014925-A	<1	FT-FY24-11012023-014925-B	<1
WS-014927	3/27/2023	3/27/2024	1	Health Suite	In room 127 treatment	WF-03272023-014927	12/30/2023	FT-FY24-11012023-014927-A	<1	FT-FY24-11012023-014927-B	<1
WS-014928	3/27/2023	3/27/2024	1	Combo Fountain	In room 127 treatment	WF-03272023-014928	12/30/2023	FT-FY24-11012023-014928-A	4.6	FT-FY24-11012023-014928-B	<1
WS-014929	3/27/2023	3/27/2024	1	Bottle Filler	In hallway adjacent to stair D level 1	WF-03272023-014929	12/30/2023	FT-FY24-11012023-014929-A	<1	FT-FY24-11012023-014929-B	<1
WS-014930	3/27/2023	3/27/2024	1	Cooler	In hallway adjacent to stair D level 1 High Left	WF-03272023-014930	12/30/2023	FT-FY24-11012023-014930-A	<1	FT-FY24-11012023-014930-B	<1
WS-014931	3/27/2023	3/27/2024	1	Cooler	In hallway adjacent to stair D level 1 Low Right	WF-03272023-014931	12/30/2023	FT-FY24-11012023-014931-A	<1	FT-FY24-11012023-014931-B	<1
WS-014963	3/27/2023	3/27/2024	2	Combo Fountain	In room 219 classroom	WF-03272023-014963	12/30/2023	FT-FY24-11012023-014963-A	2.1	FT-FY24-11012023-014963-B	<1
WS-014964	3/27/2023	3/27/2024	2	Break Room	In room 222	WF-03272023-014964	12/30/2023	FT-FY24-11012023-014964-A	<1	FT-FY24-11012023-014964-B	<1
WS-014967	3/27/2023	3/27/2024	3	Bottle Filler	In hallway across from stair B level 3	WF-03272023-014967	12/30/2023	FT-FY24-11012023-014967-A	<1	FT-FY24-11012023-014967-B	<1
WS-014968	3/27/2023	3/27/2024	3	Cooler	In hallway across from stair B level 3 High Left	WF-03272023-014968	12/30/2023	FT-FY24-11012023-014968-A	<1	FT-FY24-11012023-014968-B	<1
WS-014969	3/27/2023	3/27/2024	3	Cooler	In hallway across from stair B level 3 Low Right	WF-03272023-014969	12/30/2023	FT-FY24-11012023-014969-A	<1	FT-FY24-11012023-014969-B	<1
WS-014975	3/27/2023	3/27/2024	1	Bottle Filler	In room 113 reading room	WF-03272023-014975	12/30/2023	FT-FY24-11012023-014975-A	<1	FT-FY24-11012023-014975-B	<1
WS-014976	3/27/2023	3/27/2024	1	Cooler	In room 113 reading room High Left	WF-03272023-014976	12/30/2023	FT-FY24-11012023-014976-A	<1	FT-FY24-11012023-014976-B	<1
WS-014977	3/27/2023	3/27/2024	1	Cooler	In room 113 reading room Low Right	WF-03272023-014977	12/30/2023	FT-FY24-11012023-014977-A	<1	FT-FY24-11012023-014977-B	<1
WS-014978	3/27/2023	3/27/2024	2	Bottle Filler	In hallway adjacent to room 203	WF-03272023-014978	12/30/2023	FT-FY24-11012023-014978-A	<1	FT-FY24-11012023-014978-B	<1
WS-014980	3/27/2023	3/27/2024	2	Cooler	In hallway adjacent to room 203 Low Right	WF-03272023-014980	12/30/2023	FT-FY24-11012023-014980-A	<1	FT-FY24-11012023-014980-B	<1
WS-014982	3/27/2023	3/27/2024	Basement	Combo Fountain	In classroom L48 instrumental	WF-03272023-014982	12/30/2023	FT-FY24-11012023-014982-A	1.6	FT-FY24-11012023-014982-B	<1
WS-014984	3/27/2023	3/27/2024	Basement	Combo Fountain	In classroom L43	WF-03272023-014984	12/30/2023	FT-FY24-11012023-014984-A	<1	FT-FY24-11012023-014984-B	<1
WS-014987	3/27/2023	3/27/2024	Basement	Combo Fountain	In classroom L39	WF-03272023-014987	12/30/2023	FT-FY24-11012023-014987-A	<1	FT-FY24-11012023-014987-B	<1
WS-014988	3/27/2023	3/27/2024	1	Bottle Filler	In gym on boy's locker room side	WF-03272023-014988	12/30/2023	FT-FY24-11012023-014988-A	<1	FT-FY24-11012023-014988-B	<1
WS-014989	3/27/2023	3/27/2024	1	Cooler	In gym on boy's locker room side High Left	WF-03272023-014989	12/30/2023	FT-FY24-11012023-014989-A	<1	FT-FY24-11012023-014989-B	<1
WS-014990	3/27/2023	3/27/2024	1	Cooler	In gym on boy's locker room side Low Right	WF-03272023-014990	12/30/2023	FT-FY24-11012023-014990-A	<1	FT-FY24-11012023-014990-B	<1
WS-014991	3/27/2023	3/27/2024	1	Bottle Filler	In gym on girls's locker room side	WF-03272023-014991	12/30/2023	FT-FY24-11012023-014991-A	<1	FT-FY24-11012023-014991-B	<1
WS-014992	3/27/2023	3/27/2024	1	Cooler	In gym on girls's locker room side High Left	WF-03272023-014992	12/30/2023	FT-FY24-11012023-014992-A	<1	FT-FY24-11012023-014992-B	<1

WS-014993	3/27/2023	3/27/2024	1	Cooler	In gym on girls's locker room side	Low Right	WF-03272023-014993	12/30/2023	FT-FY24-11012023-014993-A	<1	FT-FY24-11012023-014993-B	<1
WS-014994	3/27/2023	3/27/2024	Basement	Bottle Filler	In cafeteria		WF-03272023-014994	12/30/2023	FT-FY24-11292023-014994-A	<1	FT-FY24-11292023-014994-B	<1
WS-014995	3/27/2023	3/27/2024	Basement	Cooler	In cafeteria	High Left	WF-03272023-014995	12/30/2023	FT-FY24-11292023-014995-A	<1	FT-FY24-11292023-014995-B	<1
WS-014996	3/27/2023	3/27/2024	Basement	Cooler	In cafeteria	Low Right	WF-03272023-014996	12/30/2023	FT-FY24-11292023-014996-A	<1	FT-FY24-11292023-014996-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014902	1/9/2023	1/9/2024	Basement	Food Prep Sink	In kitchen third clockwise from entry	WF-01092023-014902	12/30/2023	FT-FY24-11012023-014902-A	<1	FT-FY24-11012023-014902-B	<1

FY24 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014966	3/27/2023	3/27/2024	3	Combo Fountain	In room 305 classroom	WF-03272023-014966	12/30/2023	FT-FY24-11012023-014966-A	6.7	FT-FY24-11012023-014966-B	<1