



Jelleff RC Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 006140	3/19/2019	3/19/2020	1	Food Prep Sink	In kitchen Left	WF-03192019-006140	2/7/2020	FT-FY20-012020-006140-A	<1	FT-FY20-012020-006140-B	<1
WS- 006141	3/19/2019	3/19/2020	1	Food Prep Sink	In kitchen Right	WF-03192019-006141	2/7/2020	FT-FY20-012020-006141-A	<1	FT-FY20-012020-006141-B	<1
WS- 006142	3/19/2019	3/19/2020	1	Cooler	In hallway adjacent to boys' restroom	WF-03192019-006142	2/7/2020	FT-FY20-012020-006142-A	<1	FT-FY20-012020-006142-B	<1
WS- 006143	3/19/2019	3/19/2020	2	Cooler	In hallway adjacent to boys' locker room	WF-03192019-006143	2/7/2020	FT-FY20-012020-006143-A	<1	FT-FY20-012020-006143-B	<1