



Jelleff RC Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 006142	3/8/2021	3/8/2022	1	Cooler	In hallway adjacent to boys' restroom	WF-03082021-006142	3/23/2021	FT-FY21-032021-006142-A	<1	FT-FY21-032021-006142-B	<1
WS- 006143	3/8/2021	3/8/2022	2	Cooler	In hallway adjacent to boys' locker room	WF-03082021-006143	3/23/2021	FT-FY21-032021-006143-A	<1	FT-FY21-032021-006143-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 006140	1/6/2021	1/6/2022	1	Food Prep Sink	In kitchen (water source) Left	WF-01062021-006140	3/23/2021	FT-FY21-032021-006140-A	<1	FT-FY21-032021-006140-B	<1
WS- 006141	1/6/2021	1/6/2022	1	Food Prep Sink	In kitchen Right	WF-01062021-006141	3/23/2021	FT-FY21-032021-006141-A	<1	FT-FY21-032021-006141-B	<1