



# JELLEFF REC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	JELLEFF RECREATION CENTER	WS- 006140	9/21/2016	1	Food Prep Sink	In kitchen (water source) Left	FT-82016-006140-A	< 1	FT-82016-006140-B	< 1
2	JELLEFF RECREATION CENTER	WS- 006141	9/21/2016	1	Food Prep Sink	In kitchen Right	FT-82016-006141-A	< 1	FT-82016-006141-B	< 1
3	JELLEFF RECREATION CENTER	WS- 006142	9/21/2016	1	Cooler	In hallway adjacent to boys' restroom	FT-82016-006142-A	< 1	FT-82016-006142-B	< 1
4	JELLEFF RECREATION CENTER	WS- 006143	9/21/2016	2	Cooler	In hallway adjacent to boys' locker room	FT-82016-006143-A	< 1	FT-82016-006143-B	< 1
5	JELLEFF RECREATION CENTER	WS- 006144	9/21/2016	Ground Floor	Exterior Fountain	Exterior, adjacent to pool area Low	FT-82016-006144-A	< 1	FT-82016-006144-B	< 1
6	JELLEFF RECREATION CENTER	WS- 006145	9/21/2016	Ground Floor	Exterior Fountain	Exterior, adjacent to pool area High	FT-82016-006145-A	< 1	FT-82016-006145-B	< 1