



John Lewis Elementary School Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 000436	5/7/2024	5/7/2025	1	Combo Fountain	In resource room 110P	WF-05072024-000436	12/5/2024	FT-FY25-10312024-000436-A	<2	FT-FY25-10312024-000436-B	<2	
WS- 000437	5/7/2024	5/7/2025	1	Break Room	In workroom 119	WF-05072024-000437	12/5/2024	FT-FY25-10312024-000437-A	<2	FT-FY25-10312024-000437-B	<2	
WS- 000438	5/7/2024	5/7/2025	1	Health Suite	In health suite treatment room 133	WF-05072024-000438	12/5/2024	FT-FY25-10312024-000438-A	<2	FT-FY25-10312024-000438-B	<2	
WS- 000439	5/7/2024	5/7/2025	1	Combo Fountain	In health suite treatment room 133	WF-05072024-000439	12/5/2024	FT-FY25-10312024-000439-A	<2	FT-FY25-10312024-000439-B	<2	
WS- 000443	5/7/2024	5/7/2025	1	Combo Fountain	In classroom 150	WF-05072024-000443	12/5/2024	FT-FY25-10312024-000443-A	<2	FT-FY25-10312024-000443-B	<2	
WS- 000444	9/23/2024	9/23/2025	1	Bathroom	In classroom 150 (bathroom)	WF-09232024-000444	12/5/2024	FT-FY25-10312024-000444-A	<2	FT-FY25-10312024-000444-B	<2	
WS- 000446	5/7/2024	5/7/2025	1	Combo Fountain	In classroom 151	WF-05072024-000446	12/5/2024	FT-FY25-10312024-000446-A	<2	FT-FY25-10312024-000446-B	<2	
WS- 000447	9/23/2024	9/23/2025	1	Bathroom	In classroom 151 (bathroom)	WF-09232024-000447	12/5/2024	FT-FY25-10312024-000447-A	<2	FT-FY25-10312024-000447-B	<2	
WS- 000449	5/7/2024	5/7/2025	1	Combo Fountain	In classroom 154	WF-05072024-000449	12/5/2024	FT-FY25-10312024-000449-A	<2	FT-FY25-10312024-000449-B	<2	
WS- 000450	9/23/2024	9/23/2025	1	Bathroom	In classroom 154 (bathroom)	WF-09232024-000450	12/5/2024	FT-FY25-10312024-000450-A	<2	FT-FY25-10312024-000450-B	<2	
WS- 000452	5/7/2024	5/7/2025	1	Combo Fountain	In classroom 155	WF-05072024-000452	12/5/2024	FT-FY25-10312024-000452-A	<2	FT-FY25-10312024-000452-B	<2	
WS- 000453	9/23/2024	9/23/2025	1	Bathroom	In classroom 155 (bathroom)	WF-09232024-000453	12/5/2024	FT-FY25-10312024-000453-A	<2	FT-FY25-10312024-000453-B	<2	
WS- 000455	5/7/2024	5/7/2025	1	Combo Fountain	In classroom 160	WF-05072024-000455	12/5/2024	FT-FY25-10312024-000455-A	<2	FT-FY25-10312024-000455-B	<2	
WS- 000456	9/23/2024	9/23/2025	1	Bathroom	In classroom 160 (bathroom)	WF-09232024-000456	12/5/2024	FT-FY25-10312024-000456-A	<2	FT-FY25-10312024-000456-B	<2	
WS- 000458	5/7/2024	5/7/2025	1	Combo Fountain	In classroom 161	WF-05072024-000458	12/5/2024	FT-FY25-10312024-000458-A	<2	FT-FY25-10312024-000458-B	<2	
WS- 000459	9/23/2024	9/23/2025	1	Bathroom	In classroom 161 (bathroom)	WF-09232024-000459	12/5/2024	FT-FY25-10312024-000459-A	<2	FT-FY25-10312024-000459-B	<2	
WS- 000467	5/7/2024	5/7/2025	1	Combo Fountain	In classroom 164	WF-05072024-000467	12/5/2024	FT-FY25-10312024-000467-A	<2	FT-FY25-10312024-000467-B	<2	
WS- 000468	9/23/2024	9/23/2025	1	Bathroom	In classroom 164 (bathroom)	WF-09232024-000468	12/5/2024	FT-FY25-10312024-000468-A	<2	FT-FY25-10312024-000468-B	<2	
WS- 000473	5/7/2024	5/7/2025	1	Combo Fountain	In classroom 165	WF-05072024-000473	12/5/2024	FT-FY25-10312024-000473-A	<2	FT-FY25-10312024-000473-B	<2	
WS- 000474	9/23/2024	9/23/2025	1	Bathroom	In classroom 165 (bathroom)	WF-09232024-000474	12/5/2024	FT-FY25-10312024-000474-A	<2	FT-FY25-10312024-000474-B	<2	
WS- 000475	5/7/2024	5/7/2025	1	Bottle Filler	In hallway across from room 144	WF-05072024-000475	12/5/2024	FT-FY25-10312024-000475-A	<2	FT-FY25-10312024-000475-B	<2	
WS- 000476	5/7/2024	5/7/2025	1	Cooler	In hallway across from room 144	High Left	WF-05072024-000476	12/5/2024	FT-FY25-10312024-000476-A	<2	FT-FY25-10312024-000476-B	<2
WS- 000477	5/7/2024	5/7/2025	1	Cooler	In hallway across from room 144	Low Right	WF-05072024-000477	12/5/2024	FT-FY25-10312024-000477-A	<2	FT-FY25-10312024-000477-B	<2
WS- 000478	5/7/2024	5/7/2025	1	Break Room	In teacher collaboration room 144	WF-05072024-000478	12/5/2024	FT-FY25-10312024-000478-A	<2	FT-FY25-10312024-000478-B	<2	
WS- 000479	5/7/2024	5/7/2025	1	Combo Fountain	In teacher collaboration room 144	WF-05072024-000479	12/5/2024	FT-FY25-10312024-000479-A	<2	FT-FY25-10312024-000479-B	<2	
WS- 000481	5/7/2024	5/7/2025	1	Combo Fountain	In OT/PT room 170	WF-05072024-000481	12/5/2024	FT-FY25-10312024-000481-A	<2	FT-FY25-10312024-000481-B	<2	
WS- 000483	5/7/2024	5/7/2025	1	Combo Fountain	In classroom 171	WF-05072024-000483	12/5/2024	FT-FY25-10312024-000483-A	<2	FT-FY25-10312024-000483-B	<2	
WS- 000485	5/7/2024	5/7/2025	1	Combo Fountain	In classroom 174	WF-05072024-000485	12/5/2024	FT-FY25-10312024-000485-A	<2	FT-FY25-10312024-000485-B	<2	
WS- 000487	5/7/2024	5/7/2025	1	Combo Fountain	In classroom 175	WF-05072024-000487	12/5/2024	FT-FY25-10312024-000487-A	<2	FT-FY25-10312024-000487-B	<2	
WS- 000566	5/7/2024	5/7/2025	1	Combo Fountain	In classroom 180	WF-05072024-000566	12/5/2024	FT-FY25-10312024-000566-A	<2	FT-FY25-10312024-000566-B	<2	
WS- 000567	9/23/2024	9/23/2025	1	Bathroom	In classroom 180 (bathroom)	WF-09232024-000567	12/5/2024	FT-FY25-10312024-000567-A	<2	FT-FY25-10312024-000567-B	<2	
WS- 000569	5/7/2024	5/7/2025	1	Combo Fountain	In classroom 181	WF-05072024-000569	12/5/2024	FT-FY25-10312024-000569-A	<2	FT-FY25-10312024-000569-B	<2	
WS- 000572	9/23/2024	9/23/2025	1	Bathroom	In classroom 181 (bathroom)	WF-09232024-000572	12/5/2024	FT-FY25-10312024-000572-A	<2	FT-FY25-10312024-000572-B	<2	

WS-000574	5/7/2024	5/7/2025	1	Combo Fountain	In classroom 184		WF-05072024-000574	12/5/2024	FT-FY25-10312024-000574-A	<2	FT-FY25-10312024-000574-B	<2
WS-000575	9/23/2024	9/23/2025	1	Bathroom	In classroom 184 (bathroom)		WF-09232024-000575	12/5/2024	FT-FY25-10312024-000575-A	<2	FT-FY25-10312024-000575-B	<2
WS-000577	5/7/2024	5/7/2025	1	Combo Fountain	In classroom 185		WF-05072024-000577	12/5/2024	FT-FY25-10312024-000577-A	<2	FT-FY25-10312024-000577-B	<2
WS-000578	9/23/2024	9/23/2025	1	Bathroom	In classroom 185 (bathroom)		WF-09232024-000578	12/5/2024	FT-FY25-10312024-000578-A	<2	FT-FY25-10312024-000578-B	<2
WS-000579	5/7/2024	5/7/2025	2	Bottle Filler	In gym		WF-05072024-000579	12/5/2024	FT-FY25-10312024-000579-A	<2	FT-FY25-10312024-000579-B	<2
WS-000582	5/7/2024	5/7/2025	2	Cooler	In gym	High Left	WF-05072024-000582	12/5/2024	FT-FY25-10312024-000582-A	<2	FT-FY25-10312024-000582-B	<2
WS-000584	5/7/2024	5/7/2025	2	Break Room	In wellness/lactation room 221		WF-05072024-000584	12/5/2024	FT-FY25-10312024-000584-A	<2	FT-FY25-10312024-000584-B	<2
WS-000585	5/7/2024	5/7/2025	2	Break Room	In teachers lounge 227		WF-05072024-000585	12/5/2024	FT-FY25-10312024-000585-A	<2	FT-FY25-10312024-000585-B	<2
WS-000586	5/7/2024	5/7/2025	2	Bottle Filler	In hallway adjacent to room 228T		WF-05072024-000586	12/5/2024	FT-FY25-10312024-000586-A	<2	FT-FY25-10312024-000586-B	<2
WS-000587	5/7/2024	5/7/2025	2	Cooler	In hallway adjacent to room 228T	High Left	WF-05072024-000587	12/5/2024	FT-FY25-10312024-000587-A	<2	FT-FY25-10312024-000587-B	<2
WS-000590	5/7/2024	5/7/2025	2	Combo Fountain	In classroom 250		WF-05072024-000590	12/5/2024	FT-FY25-10312024-000590-A	<2	FT-FY25-10312024-000590-B	<2
WS-000592	5/7/2024	5/7/2025	2	Combo Fountain	In classroom 251	High Left	WF-05072024-000592	12/5/2024	FT-FY25-10312024-000592-A	<2	FT-FY25-10312024-000592-B	<2
WS-000594	5/7/2024	5/7/2025	2	Combo Fountain	In classroom 251	Low Right	WF-05072024-000594	12/5/2024	FT-FY25-10312024-000594-A	<2	FT-FY25-10312024-000594-B	<2
WS-000596	5/7/2024	5/7/2025	2	Combo Fountain	In classroom 254		WF-05072024-000596	12/5/2024	FT-FY25-10312024-000596-A	<2	FT-FY25-10312024-000596-B	<2
WS-000598	5/7/2024	5/7/2025	2	Combo Fountain	In classroom 255		WF-05072024-000598	12/5/2024	FT-FY25-10312024-000598-A	<2	FT-FY25-10312024-000598-B	<2
WS-000600	5/7/2024	5/7/2025	2	Combo Fountain	In classroom 260		WF-05072024-000600	12/5/2024	FT-FY25-10312024-000600-A	<2	FT-FY25-10312024-000600-B	<2
WS-000668	5/7/2024	5/7/2025	2	Combo Fountain	In classroom 261		WF-05072024-000668	12/5/2024	FT-FY25-10312024-000668-A	<2	FT-FY25-10312024-000668-B	<2
WS-000670	5/7/2024	5/7/2025	2	Break Room	In teacher collaboration room 263		WF-05072024-000670	12/5/2024	FT-FY25-10312024-000670-A	<2	FT-FY25-10312024-000670-B	<2
WS-000672	5/7/2024	5/7/2025	2	Combo Fountain	In classroom 264		WF-05072024-000672	12/5/2024	FT-FY25-10312024-000672-A	<2	FT-FY25-10312024-000672-B	<2
WS-000674	5/7/2024	5/7/2025	2	Combo Fountain	In classroom 265		WF-05072024-000674	12/5/2024	FT-FY25-10312024-000674-A	<2	FT-FY25-10312024-000674-B	<2
WS-000676	5/7/2024	5/7/2025	2	Combo Fountain	In classroom 202		WF-05072024-000676	12/5/2024	FT-FY25-10312024-000676-A	<2	FT-FY25-10312024-000676-B	<2
WS-000677	5/7/2024	5/7/2025	2	Bottle Filler	In hallway across from cafeteria entrance		WF-05072024-000677	12/5/2024	FT-FY25-10312024-000677-A	<2	FT-FY25-10312024-000677-B	<2
WS-000678	5/7/2024	5/7/2025	2	Cooler	In hallway across from cafeteria entrance	High Left	WF-05072024-000678	12/5/2024	FT-FY25-10312024-000678-A	<2	FT-FY25-10312024-000678-B	<2
WS-000679	5/7/2024	5/7/2025	2	Cooler	In hallway across from cafeteria entrance	Low Right	WF-05072024-000679	12/5/2024	FT-FY25-10312024-000679-A	<2	FT-FY25-10312024-000679-B	<2
WS-000680	5/7/2024	5/7/2025	2	Bottle Filler	In cafeteria		WF-05072024-000680	12/5/2024	FT-FY25-10312024-000680-A	<2	FT-FY25-10312024-000680-B	<2
WS-000681	5/7/2024	5/7/2025	2	Cooler	In cafeteria	High Left	WF-05072024-000681	12/5/2024	FT-FY25-10312024-000681-A	<2	FT-FY25-10312024-000681-B	<2
WS-000682	5/7/2024	5/7/2025	2	Cooler	In cafeteria	Low Right	WF-05072024-000682	12/5/2024	FT-FY25-10312024-000682-A	<2	FT-FY25-10312024-000682-B	<2
WS-000692	5/7/2024	5/7/2025	2	Combo Fountain	In classroom 270	High Right	WF-05072024-000692	12/5/2024	FT-FY25-10312024-000692-A	<2	FT-FY25-10312024-000692-B	<2
WS-000694	5/7/2024	5/7/2025	2	Combo Fountain	In classroom 271		WF-05072024-000694	12/5/2024	FT-FY25-10312024-000694-A	<2	FT-FY25-10312024-000694-B	<2
WS-000696	5/7/2024	5/7/2025	2	Combo Fountain	In classroom 274		WF-05072024-000696	12/5/2024	FT-FY25-10312024-000696-A	<2	FT-FY25-10312024-000696-B	<2
WS-000698	5/7/2024	5/7/2025	2	Combo Fountain	In classroom 275		WF-05072024-000698	12/5/2024	FT-FY25-10312024-000698-A	<2	FT-FY25-10312024-000698-B	<2
WS-000700	5/7/2024	5/7/2025	2	Combo Fountain	In classroom 280		WF-05072024-000700	12/5/2024	FT-FY25-10312024-000700-A	<2	FT-FY25-10312024-000700-B	<2
WS-000702	5/7/2024	5/7/2025	2	Combo Fountain	In classroom 281		WF-05072024-000702	12/5/2024	FT-FY25-10312024-000702-A	<2	FT-FY25-10312024-000702-B	<2
WS-000703	5/7/2024	5/7/2025	2	Break Room	In teacher collaboration room 283		WF-05072024-000703	12/5/2024	FT-FY25-10312024-000703-A	<2	FT-FY25-10312024-000703-B	<2
WS-000705	5/7/2024	5/7/2025	2	Combo Fountain	In classroom 284		WF-05072024-000705	12/5/2024	FT-FY25-10312024-000705-A	<2	FT-FY25-10312024-000705-B	<2
WS-000707	5/7/2024	5/7/2025	2	Combo Fountain	In classroom 285		WF-05072024-000707	12/5/2024	FT-FY25-10312024-000707-A	<2	FT-FY25-10312024-000707-B	<2
WS-000709	5/7/2024	5/7/2025	2	Combo Fountain	In classroom 270	Low Left	WF-05072024-000709	12/5/2024	FT-FY25-10312024-000709-A	<2	FT-FY25-10312024-000709-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000689	12/11/2023	12/11/2024	2	Food Prep Sink	In kitchen 7th clockwise from entry	WF-12112023-000689	12/5/2024	FT-FY25-10312024-000689-A	<2	FT-FY25-10312024-000689-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.