



John Lewis Elementary School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 000436	5/25/2022	5/25/2023	1	Combo Fountain	In resource room 110P	WF-05252022-000436	1/11/2023	FT-FY23-11182022-000436-A	1.0	FT-FY23-11182022-000436-B	<1	
WS- 000437	5/25/2022	5/25/2023	1	Break Room	In workroom 119	WF-05252022-000437	1/11/2023	FT-FY23-11182022-000437-A	<1	FT-FY23-11182022-000437-B	<1	
WS- 000438	5/25/2022	5/25/2023	1	Health Suite	In health suite treatment room 133	WF-05252022-000438	1/11/2023	FT-FY23-11182022-000438-A	<1	FT-FY23-11182022-000438-B	<1	
WS- 000439	5/25/2022	5/25/2023	1	Combo Fountain	In health suite treatment room 133	WF-05252022-000439	1/11/2023	FT-FY23-11182022-000439-A	<1	FT-FY23-11182022-000439-B	<1	
WS- 000441	5/25/2022	5/25/2023	1	Combo Fountain	In reading room 120	WF-05252022-000441	1/11/2023	FT-FY23-11182022-000441-A	<1	FT-FY23-11182022-000441-B	<1	
WS- 000443	5/25/2022	5/25/2023	1	Combo Fountain	In classroom 150	WF-05252022-000443	1/11/2023	FT-FY23-11182022-000443-A	<1	FT-FY23-11182022-000443-B	<1	
WS- 000444	10/5/2022	10/5/2023	1	Bathroom	In classroom 150 (bathroom)	WF-10052022-000444	1/11/2023	FT-FY23-11182022-000444-A	<1	FT-FY23-11182022-000444-B	<1	
WS- 000447	10/5/2022	10/5/2023	1	Bathroom	In classroom 151 (bathroom)	WF-10052022-000447	1/11/2023	FT-FY23-11182022-000447-A	<1	FT-FY23-11182022-000447-B	<1	
WS- 000449	5/25/2022	5/25/2023	1	Combo Fountain	In classroom 154	WF-05252022-000449	1/11/2023	FT-FY23-11182022-000449-A	<1	FT-FY23-11182022-000449-B	<1	
WS- 000450	10/5/2022	10/5/2023	1	Bathroom	In classroom 154 (bathroom)	WF-10052022-000450	1/11/2023	FT-FY23-11182022-000450-A	<1	FT-FY23-11182022-000450-B	<1	
WS- 000452	5/25/2022	5/25/2023	1	Combo Fountain	In classroom 155	WF-05252022-000452	1/11/2023	FT-FY23-11182022-000452-A	<1	FT-FY23-11182022-000452-B	<1	
WS- 000453	10/5/2022	10/5/2023	1	Bathroom	In classroom 155 (bathroom)	WF-10052022-000453	1/11/2023	FT-FY23-11182022-000453-A	<1	FT-FY23-11182022-000453-B	<1	
WS- 000455	5/25/2022	5/25/2023	1	Combo Fountain	In classroom 160	WF-05252022-000455	1/11/2023	FT-FY23-11182022-000455-A	<1	FT-FY23-11182022-000455-B	<1	
WS- 000456	10/5/2022	10/5/2023	1	Bathroom	In classroom 160 (bathroom)	WF-10052022-000456	1/11/2023	FT-FY23-11182022-000456-A	<1	FT-FY23-11182022-000456-B	<1	
WS- 000467	5/25/2022	5/25/2023	1	Combo Fountain	In classroom 164	WF-05252022-000467	1/11/2023	FT-FY23-11182022-000467-A	<1	FT-FY23-11182022-000467-B	<1	
WS- 000468	10/5/2022	10/5/2023	1	Bathroom	In classroom 164 (bathroom)	WF-10052022-000468	1/11/2023	FT-FY23-11182022-000468-A	<1	FT-FY23-11182022-000468-B	<1	
WS- 000473	5/25/2022	5/25/2023	1	Combo Fountain	In classroom 165	WF-05252022-000473	1/11/2023	FT-FY23-11182022-000473-A	<1	FT-FY23-11182022-000473-B	<1	
WS- 000474	10/5/2022	10/5/2023	1	Bathroom	In classroom 165 (bathroom)	WF-10052022-000474	1/11/2023	FT-FY23-11182022-000474-A	<1	FT-FY23-11182022-000474-B	<1	
WS- 000478	5/25/2022	5/25/2023	1	Break Room	In teacher collaboration room 144	WF-05252022-000478	1/11/2023	FT-FY23-11182022-000478-A	<1	FT-FY23-11182022-000478-B	<1	
WS- 000479	5/25/2022	5/25/2023	1	Combo Fountain	In teacher collaboration room 144	WF-05252022-000479	1/11/2023	FT-FY23-11182022-000479-A	<1	FT-FY23-11182022-000479-B	<1	
WS- 000483	5/25/2022	5/25/2023	1	Combo Fountain	In classroom 171	WF-05252022-000483	1/11/2023	FT-FY23-11182022-000483-A	<1	FT-FY23-11182022-000483-B	<1	
WS- 000566	5/25/2022	5/25/2023	1	Combo Fountain	In classroom 180	WF-05252022-000566	1/11/2023	FT-FY23-11182022-000566-A	<1	FT-FY23-11182022-000566-B	<1	
WS- 000567	10/5/2022	10/5/2023	1	Bathroom	In classroom 180 (bathroom)	WF-10052022-000567	1/11/2023	FT-FY23-11182022-000567-A	<1	FT-FY23-11182022-000567-B	<1	
WS- 000569	5/25/2022	5/25/2023	1	Combo Fountain	In classroom 181	WF-05252022-000569	1/11/2023	FT-FY23-11182022-000569-A	1.8	FT-FY23-11182022-000569-B	<1	
WS- 000572	10/5/2022	10/5/2023	1	Bathroom	In classroom 181 (bathroom)	WF-10052022-000572	1/11/2023	FT-FY23-11182022-000572-A	<1	FT-FY23-11182022-000572-B	<1	
WS- 000574	5/25/2022	5/25/2023	1	Combo Fountain	In classroom 184	WF-05252022-000574	1/11/2023	FT-FY23-11182022-000574-A	<1	FT-FY23-11182022-000574-B	<1	
WS- 000575	10/5/2022	10/5/2023	1	Bathroom	In classroom 184 (bathroom)	WF-10052022-000575	1/11/2023	FT-FY23-11182022-000575-A	<1	FT-FY23-11182022-000575-B	<1	
WS- 000577	5/25/2022	5/25/2023	1	Combo Fountain	In classroom 185	WF-05252022-000577	1/11/2023	FT-FY23-11182022-000577-A	<1	FT-FY23-11182022-000577-B	<1	
WS- 000578	10/5/2022	10/5/2023	1	Bathroom	In classroom 185 (bathroom)	WF-10052022-000578	1/11/2023	FT-FY23-11182022-000578-A	<1	FT-FY23-11182022-000578-B	<1	
WS- 000579	5/25/2022	5/25/2023	2	Bottle Filler	In gym	WF-05252022-000579	1/11/2023	FT-FY23-11182022-000579-A	<1	FT-FY23-11182022-000579-B	<1	
WS- 000584	5/25/2022	5/25/2023	2	Break Room	In wellness/lactation room 221	WF-05252022-000584	1/11/2023	FT-FY23-11182022-000584-A	<1	FT-FY23-11182022-000584-B	<1	
WS- 000586	5/25/2022	5/25/2023	2	Bottle Filler	In hallway adjacent to room 228T	WF-05252022-000586	1/11/2023	FT-FY23-11182022-000586-A	<1	FT-FY23-11182022-000586-B	<1	
WS- 000587	5/25/2022	5/25/2023	2	Cooler	In hallway adjacent to room 228T	High Left	WF-05252022-000587	1/11/2023	FT-FY23-11182022-000587-A	<1	FT-FY23-11182022-000587-B	<1
WS- 000590	5/25/2022	5/25/2023	2	Combo Fountain	In classroom 250	WF-05252022-000590	1/11/2023	FT-FY23-11182022-000590-A	<1	FT-FY23-11182022-000590-B	<1	
WS- 000592	5/25/2022	5/25/2023	2	Combo Fountain	In classroom 251	High Left	WF-05252022-000592	1/11/2023	FT-FY23-11182022-000592-A	<1	FT-FY23-11182022-000592-B	<1

WS- 000594	5/25/2022	5/25/2023	2	Combo Fountain	In classroom 251	Low Right	WF-05252022-000594	1/11/2023	FT-FY23-11182022-000594-A	<1	FT-FY23-11182022-000594-B	<1
WS- 000596	5/25/2022	5/25/2023	2	Combo Fountain	In classroom 254		WF-05252022-000596	1/11/2023	FT-FY23-11182022-000596-A	<1	FT-FY23-11182022-000596-B	<1
WS- 000598	5/25/2022	5/25/2023	2	Combo Fountain	In classroom 255		WF-05252022-000598	1/11/2023	FT-FY23-11182022-000598-A	<1	FT-FY23-11182022-000598-B	<1
WS- 000668	5/25/2022	5/25/2023	2	Combo Fountain	In classroom 261		WF-05252022-000668	1/11/2023	FT-FY23-11182022-000668-A	<1	FT-FY23-11182022-000668-B	<1
WS- 000670	5/25/2022	5/25/2023	2	Break Room	In teacher collaboration room 263		WF-05252022-000670	1/11/2023	FT-FY23-11182022-000670-A	<1	FT-FY23-11182022-000670-B	<1
WS- 000672	5/25/2022	5/25/2023	2	Combo Fountain	In classroom 264		WF-05252022-000672	1/11/2023	FT-FY23-11182022-000672-A	<1	FT-FY23-11182022-000672-B	<1
WS- 000674	5/25/2022	5/25/2023	2	Combo Fountain	In classroom 265		WF-05252022-000674	1/11/2023	FT-FY23-11182022-000674-A	<1	FT-FY23-11182022-000674-B	<1
WS- 000676	5/25/2022	5/25/2023	2	Combo Fountain	In classroom 202		WF-05252022-000676	1/11/2023	FT-FY23-11182022-000676-A	<1	FT-FY23-11182022-000676-B	<1
WS- 000677	5/25/2022	5/25/2023	2	Bottle Filler	In hallway across from cafeteria entrance		WF-05252022-000677	1/11/2023	FT-FY23-11182022-000677-A	<1	FT-FY23-11182022-000677-B	<1
WS- 000678	5/25/2022	5/25/2023	2	Cooler	In hallway across from cafeteria entrance	High Left	WF-05252022-000678	1/11/2023	FT-FY23-11182022-000678-A	<1	FT-FY23-11182022-000678-B	<1
WS- 000679	5/25/2022	5/25/2023	2	Cooler	In hallway across from cafeteria entrance	Low Right	WF-05252022-000679	1/11/2023	FT-FY23-11182022-000679-A	<1	FT-FY23-11182022-000679-B	<1
WS- 000680	5/25/2022	5/25/2023	2	Bottle Filler	In cafeteria		WF-05252022-000680	1/11/2023	FT-FY23-11182022-000680-A	<1	FT-FY23-11182022-000680-B	<1
WS- 000692	5/25/2022	5/25/2023	2	Combo Fountain	In classroom 270	High Right	WF-05252022-000692	1/11/2023	FT-FY23-11182022-000692-A	<1	FT-FY23-11182022-000692-B	<1
WS- 000696	5/25/2022	5/25/2023	2	Combo Fountain	In classroom 274		WF-05252022-000696	1/11/2023	FT-FY23-11182022-000696-A	<1	FT-FY23-11182022-000696-B	<1
WS- 000698	5/25/2022	5/25/2023	2	Combo Fountain	In classroom 275		WF-05252022-000698	1/11/2023	FT-FY23-11182022-000698-A	<1	FT-FY23-11182022-000698-B	<1
WS- 000700	5/25/2022	5/25/2023	2	Combo Fountain	In classroom 280		WF-05252022-000700	1/11/2023	FT-FY23-11182022-000700-A	<1	FT-FY23-11182022-000700-B	<1
WS- 000702	5/25/2022	5/25/2023	2	Combo Fountain	In classroom 281		WF-05252022-000702	1/11/2023	FT-FY23-11182022-000702-A	<1	FT-FY23-11182022-000702-B	<1
WS- 000703	5/25/2022	5/25/2023	2	Break Room	In teacher collaboration room 283		WF-05252022-000703	1/11/2023	FT-FY23-11182022-000703-A	<1	FT-FY23-11182022-000703-B	<1
WS- 000705	5/25/2022	5/25/2023	2	Combo Fountain	In classroom 284		WF-05252022-000705	1/11/2023	FT-FY23-11182022-000705-A	<1	FT-FY23-11182022-000705-B	<1
WS- 000707	5/25/2022	5/25/2023	2	Combo Fountain	In classroom 285		WF-05252022-000707	1/11/2023	FT-FY23-11182022-000707-A	<1	FT-FY23-11182022-000707-B	<1
WS- 000709	5/25/2022	5/25/2023	2	Combo Fountain	In classroom 270	Low Left	WF-05252022-000709	1/11/2023	FT-FY23-11182022-000709-A	<1	FT-FY23-11182022-000709-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 000689	2/23/2022	2/23/2023	2	Food Prep Sink	In kitchen 7th clockwise from entry	WF-02232022-000689	1/11/2023	FT-FY23-11182022-000689-A	<1	FT-FY23-11182022-000689-B	<1	