



John Lewis School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-000436	5/16/2023	5/16/2024	1	Combo Fountain	In resource room 110P	WF-05162023-000436	11/27/2023	FT-FY24-10102023-000436-A	<1	FT-FY24-10102023-000436-B	<1	
WS-000437	5/16/2023	5/16/2024	1	Break Room	In workroom 119	WF-05162023-000437	11/27/2023	FT-FY24-10102023-000437-A	<1	FT-FY24-10102023-000437-B	<1	
WS-000438	5/16/2023	5/16/2024	1	Health Suite	In health suite treatment room 133	WF-05162023-000438	11/27/2023	FT-FY24-10102023-000438-A	<1	FT-FY24-10102023-000438-B	<1	
WS-000439	5/16/2023	5/16/2024	1	Combo Fountain	In health suite treatment room 133	WF-05162023-000439	11/27/2023	FT-FY24-10102023-000439-A	<1	FT-FY24-10102023-000439-B	<1	
WS-000441	5/16/2023	5/16/2024	1	Combo Fountain	In reading room 120	WF-05162023-000441	11/27/2023	FT-FY24-10102023-000441-A	<1	FT-FY24-10102023-000441-B	<1	
WS-000443	5/16/2023	5/16/2024	1	Combo Fountain	In classroom 150	WF-05162023-000443	11/27/2023	FT-FY24-10102023-000443-A	<1	FT-FY24-10102023-000443-B	<1	
WS-000444	9/27/2023	9/27/2024	1	Bathroom	In classroom 150 (bathroom)	WF-09272023-000444	11/27/2023	FT-FY24-10102023-000444-A	<1	FT-FY24-10102023-000444-B	<1	
WS-000446	5/16/2023	5/16/2024	1	Combo Fountain	In classroom 151	WF-05162023-000446	11/27/2023	FT-FY24-10102023-000446-A	<1	FT-FY24-10102023-000446-B	<1	
WS-000447	9/27/2023	9/27/2024	1	Bathroom	In classroom 151 (bathroom)	WF-09272023-000447	11/27/2023	FT-FY24-10102023-000447-A	<1	FT-FY24-10102023-000447-B	<1	
WS-000449	5/16/2023	5/16/2024	1	Combo Fountain	In classroom 154	WF-05162023-000449	11/27/2023	FT-FY24-10102023-000449-A	<1	FT-FY24-10102023-000449-B	<1	
WS-000450	9/27/2023	9/27/2024	1	Bathroom	In classroom 154 (bathroom)	WF-09272023-000450	11/27/2023	FT-FY24-10102023-000450-A	<1	FT-FY24-10102023-000450-B	3.4	
WS-000452	5/16/2023	5/16/2024	1	Combo Fountain	In classroom 155	WF-05162023-000452	11/27/2023	FT-FY24-10102023-000452-A	1.4	FT-FY24-10102023-000452-B	<1	
WS-000453	9/27/2023	9/27/2024	1	Bathroom	In classroom 155 (bathroom)	WF-09272023-000453	11/27/2023	FT-FY24-10102023-000453-A	<1	FT-FY24-10102023-000453-B	<1	
WS-000455	5/16/2023	5/16/2024	1	Combo Fountain	In classroom 160	WF-05162023-000455	11/27/2023	FT-FY24-10102023-000455-A	<1	FT-FY24-10102023-000455-B	1.1	
WS-000456	9/27/2023	9/27/2024	1	Bathroom	In classroom 160 (bathroom)	WF-09272023-000456	11/27/2023	FT-FY24-10102023-000456-A	<1	FT-FY24-10102023-000456-B	<1	
WS-000458	5/16/2023	5/16/2024	1	Combo Fountain	In classroom 161	WF-05162023-000458	11/27/2023	FT-FY24-10102023-000458-A	<1	FT-FY24-10102023-000458-B	<1	
WS-000459	9/27/2023	9/27/2024	1	Bathroom	In classroom 161 (bathroom)	WF-09272023-000459	11/27/2023	FT-FY24-10102023-000459-A	<1	FT-FY24-10102023-000459-B	<1	
WS-000467	5/16/2023	5/16/2024	1	Combo Fountain	In classroom 164	WF-05162023-000467	11/27/2023	FT-FY24-10102023-000467-A	<1	FT-FY24-10102023-000467-B	1.6	
WS-000468	9/27/2023	9/27/2024	1	Bathroom	In classroom 164 (bathroom)	WF-09272023-000468	11/27/2023	FT-FY24-10102023-000468-A	1.7	FT-FY24-10102023-000468-B	1.3	
WS-000473	5/16/2023	5/16/2024	1	Combo Fountain	In classroom 165	WF-05162023-000473	11/27/2023	FT-FY24-10102023-000473-A	<1	FT-FY24-10102023-000473-B	<1	
WS-000474	9/27/2023	9/27/2024	1	Bathroom	In classroom 165 (bathroom)	WF-09272023-000474	11/27/2023	FT-FY24-10102023-000474-A	<1	FT-FY24-10102023-000474-B	<1	
WS-000475	5/16/2023	5/16/2024	1	Bottle Filler	In hallway across from room 144	WF-05162023-000475	11/27/2023	FT-FY24-10102023-000475-A	<1	FT-FY24-10102023-000475-B	<1	
WS-000476	5/16/2023	5/16/2024	1	Cooler	In hallway across from room 144	High Left	WF-05162023-000476	11/27/2023	FT-FY24-10102023-000476-A	<1	FT-FY24-10102023-000476-B	<1
WS-000477	5/16/2023	5/16/2024	1	Cooler	In hallway across from room 144	Low Right	WF-05162023-000477	11/27/2023	FT-FY24-10102023-000477-A	<1	FT-FY24-10102023-000477-B	3.1
WS-000478	5/16/2023	5/16/2024	1	Break Room	In teacher collaboration room 144	WF-05162023-000478	11/27/2023	FT-FY24-10102023-000478-A	<1	FT-FY24-10102023-000478-B	1.7	
WS-000479	5/16/2023	5/16/2024	1	Combo Fountain	In teacher collaboration room 144	WF-05162023-000479	11/27/2023	FT-FY24-10102023-000479-A	<1	FT-FY24-10102023-000479-B	1.8	
WS-000481	5/16/2023	5/16/2024	1	Combo Fountain	In OT/PT room 170	WF-05162023-000481	11/27/2023	FT-FY24-10102023-000481-A	1.1	FT-FY24-10102023-000481-B	<1	
WS-000483	5/16/2023	5/16/2024	1	Combo Fountain	In classroom 171	WF-05162023-000483	11/27/2023	FT-FY24-10102023-000483-A	<1	FT-FY24-10102023-000483-B	<1	
WS-000485	5/16/2023	5/16/2024	1	Combo Fountain	In classroom 174	WF-05162023-000485	11/27/2023	FT-FY24-10102023-000485-A	<1	FT-FY24-10102023-000485-B	<1	
WS-000487	5/16/2023	5/16/2024	1	Combo Fountain	In classroom 175	WF-05162023-000487	11/27/2023	FT-FY24-10102023-000487-A	<1	FT-FY24-10102023-000487-B	<1	
WS-000566	5/16/2023	5/16/2024	1	Combo Fountain	In classroom 180	WF-05162023-000566	11/27/2023	FT-FY24-10102023-000566-A	1.2	FT-FY24-10102023-000566-B	1.2	
WS-000567	9/27/2023	9/27/2024	1	Bathroom	In classroom 180 (bathroom)	WF-09272023-000567	11/27/2023	FT-FY24-10102023-000567-A	<1	FT-FY24-10102023-000567-B	<1	
WS-000569	5/16/2023	5/16/2024	1	Combo Fountain	In classroom 181	WF-05162023-000569	11/27/2023	FT-FY24-10102023-000569-A	1.6	FT-FY24-10102023-000569-B	1.0	
WS-000572	9/27/2023	9/27/2024	1	Bathroom	In classroom 181 (bathroom)	WF-09272023-000572	11/27/2023	FT-FY24-10102023-000572-A	<1	FT-FY24-10102023-000572-B	<1	
WS-000574	5/16/2023	5/16/2024	1	Combo Fountain	In classroom 184	WF-05162023-000574	11/27/2023	FT-FY24-10102023-000574-A	<1	FT-FY24-10102023-000574-B	<1	

WS-000575	9/27/2023	9/27/2024	1	Bathroom	In classroom 184 (bathroom)		WF-09272023-000575	11/27/2023	FT-FY24-10102023-000575-A	<1	FT-FY24-10102023-000575-B	<1
WS-000577	5/16/2023	5/16/2024	1	Combo Fountain	In classroom 185		WF-05162023-000577	11/27/2023	FT-FY24-10102023-000577-A	<1	FT-FY24-10102023-000577-B	<1
WS-000578	9/27/2023	9/27/2024	1	Bathroom	In classroom 185 (bathroom)		WF-09272023-000578	11/27/2023	FT-FY24-10102023-000578-A	<1	FT-FY24-10102023-000578-B	3.1
WS-000579	5/16/2023	5/16/2024	2	Bottle Filler	In gym		WF-05162023-000579	11/27/2023	FT-FY24-10102023-000579-A	1.1	FT-FY24-10102023-000579-B	<1
WS-000582	5/16/2023	5/16/2024	2	Cooler	In gym	High Left	WF-05162023-000582	11/27/2023	FT-FY24-10102023-000582-A	<1	FT-FY24-10102023-000582-B	<1
WS-000584	5/16/2023	5/16/2024	2	Break Room	In wellness/lactation room 221		WF-05162023-000584	11/27/2023	FT-FY24-10102023-000584-A	<1	FT-FY24-10102023-000584-B	<1
WS-000585	5/16/2023	5/16/2024	2	Break Room	In teachers lounge 227		WF-05162023-000585	11/27/2023	FT-FY24-10102023-000585-A	<1	FT-FY24-10102023-000585-B	<1
WS-000586	5/16/2023	5/16/2024	2	Bottle Filler	In hallway adjacent to room 228T		WF-05162023-000586	11/27/2023	FT-FY24-10102023-000586-A	<1	FT-FY24-10102023-000586-B	<1
WS-000587	5/16/2023	5/16/2024	2	Cooler	In hallway adjacent to room 228T	High Left	WF-05162023-000587	11/27/2023	FT-FY24-10102023-000587-A	<1	FT-FY24-10102023-000587-B	4.3
WS-000588	5/16/2023	5/16/2024	2	Cooler	In hallway adjacent to room 228T	Low Right	WF-05162023-000588	11/27/2023	FT-FY24-10102023-000588-A	<1	FT-FY24-10102023-000588-B	<1
WS-000590	5/16/2023	5/16/2024	2	Combo Fountain	In classroom 250		WF-05162023-000590	11/27/2023	FT-FY24-10102023-000590-A	<1	FT-FY24-10102023-000590-B	1.0
WS-000592	5/16/2023	5/16/2024	2	Combo Fountain	In classroom 251	High Left	WF-05162023-000592	11/27/2023	FT-FY24-10102023-000592-A	<1	FT-FY24-10102023-000592-B	2.2
WS-000594	5/16/2023	5/16/2024	2	Combo Fountain	In classroom 251	Low Right	WF-05162023-000594	11/27/2023	FT-FY24-10102023-000594-A	<1	FT-FY24-10102023-000594-B	<1
WS-000596	5/16/2023	5/16/2024	2	Combo Fountain	In classroom 254		WF-05162023-000596	11/27/2023	FT-FY24-10102023-000596-A	<1	FT-FY24-10102023-000596-B	<1
WS-000598	5/16/2023	5/16/2024	2	Combo Fountain	In classroom 255		WF-05162023-000598	11/27/2023	FT-FY24-10102023-000598-A	<1	FT-FY24-10102023-000598-B	<1
WS-000600	5/16/2023	5/16/2024	2	Combo Fountain	In classroom 260		WF-05162023-000600	11/27/2023	FT-FY24-10102023-000600-A	<1	FT-FY24-10102023-000600-B	<1
WS-000668	5/16/2023	5/16/2024	2	Combo Fountain	In classroom 261		WF-05162023-000668	11/27/2023	FT-FY24-10102023-000668-A	<1	FT-FY24-10102023-000668-B	<1
WS-000670	5/16/2023	5/16/2024	2	Break Room	In teacher collaboration room 263		WF-05162023-000670	11/27/2023	FT-FY24-10102023-000670-A	<1	FT-FY24-10102023-000670-B	<1
WS-000672	5/16/2023	5/16/2024	2	Combo Fountain	In classroom 264		WF-05162023-000672	11/27/2023	FT-FY24-10102023-000672-A	<1	FT-FY24-10102023-000672-B	2.7
WS-000674	5/16/2023	5/16/2024	2	Combo Fountain	In classroom 265		WF-05162023-000674	11/27/2023	FT-FY24-10102023-000674-A	<1	FT-FY24-10102023-000674-B	<1
WS-000676	5/16/2023	5/16/2024	2	Combo Fountain	In classroom 202		WF-05162023-000676	11/27/2023	FT-FY24-10102023-000676-A	<1	FT-FY24-10102023-000676-B	1.1
WS-000677	5/16/2023	5/16/2024	2	Bottle Filler	In hallway across from cafeteria entrance		WF-05162023-000677	11/27/2023	FT-FY24-10102023-000677-A	<1	FT-FY24-10102023-000677-B	<1
WS-000678	5/16/2023	5/16/2024	2	Cooler	In hallway across from cafeteria entrance	High Left	WF-05162023-000678	11/27/2023	FT-FY24-10102023-000678-A	<1	FT-FY24-10102023-000678-B	<1
WS-000679	5/16/2023	5/16/2024	2	Cooler	In hallway across from cafeteria entrance	Low Right	WF-05162023-000679	11/27/2023	FT-FY24-10102023-000679-A	<1	FT-FY24-10102023-000679-B	<1
WS-000680	5/16/2023	5/16/2024	2	Bottle Filler	In cafeteria		WF-05162023-000680	11/27/2023	FT-FY24-10102023-000680-A	<1	FT-FY24-10102023-000680-B	<1
WS-000681	5/16/2023	5/16/2024	2	Cooler	In cafeteria	High Left	WF-05162023-000681	11/27/2023	FT-FY24-10102023-000681-A	<1	FT-FY24-10102023-000681-B	1.1
WS-000682	5/16/2023	5/16/2024	2	Cooler	In cafeteria	Low Right	WF-05162023-000682	11/27/2023	FT-FY24-10102023-000682-A	<1	FT-FY24-10102023-000682-B	<1
WS-000692	5/16/2023	5/16/2024	2	Combo Fountain	In classroom 270	High Right	WF-05162023-000692	11/27/2023	FT-FY24-10102023-000692-A	<1	FT-FY24-10102023-000692-B	<1
WS-000694	5/16/2023	5/16/2024	2	Combo Fountain	In classroom 271		WF-05162023-000694	11/27/2023	FT-FY24-10102023-000694-A	<1	FT-FY24-10102023-000694-B	<1
WS-000696	5/16/2023	5/16/2024	2	Combo Fountain	In classroom 274		WF-05162023-000696	11/27/2023	FT-FY24-10102023-000696-A	<1	FT-FY24-10102023-000696-B	<1
WS-000698	5/16/2023	5/16/2024	2	Combo Fountain	In classroom 275		WF-05162023-000698	11/27/2023	FT-FY24-10102023-000698-A	<1	FT-FY24-10102023-000698-B	<1
WS-000700	5/16/2023	5/16/2024	2	Combo Fountain	In classroom 280		WF-05162023-000700	11/27/2023	FT-FY24-10102023-000700-A	<1	FT-FY24-10102023-000700-B	<1
WS-000702	5/16/2023	5/16/2024	2	Combo Fountain	In classroom 281		WF-05162023-000702	11/27/2023	FT-FY24-10102023-000702-A	<1	FT-FY24-10102023-000702-B	<1
WS-000703	5/16/2023	5/16/2024	2	Break Room	In teacher collaboration room 283		WF-05162023-000703	11/27/2023	FT-FY24-10102023-000703-A	<1	FT-FY24-10102023-000703-B	<1
WS-000705	5/16/2023	5/16/2024	2	Combo Fountain	In classroom 284		WF-05162023-000705	11/27/2023	FT-FY24-10102023-000705-A	1.3	FT-FY24-10102023-000705-B	<1
WS-000707	5/16/2023	5/16/2024	2	Combo Fountain	In classroom 285		WF-05162023-000707	11/27/2023	FT-FY24-10102023-000707-A	<1	FT-FY24-10102023-000707-B	3.0
WS-000709	5/16/2023	5/16/2024	2	Combo Fountain	In classroom 270	Low Left	WF-05162023-000709	11/27/2023	FT-FY24-10102023-000709-A	1.3	FT-FY24-10102023-000709-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000689	1/24/2023	1/24/2024	2	Food Prep Sink	In kitchen 7th clockwise from entry	WF-01242023-000689	11/27/2023	FT-FY24-10102023-000689-A	<1	FT-FY24-10102023-000689-B	<1