



John R. Thompson HS Lead in Water Test Results

FY27 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-016295	5/15/2026	5/15/2027	3	Bottle Filler	In hallway in cafeteria	WF-05152026-016295	8/18/2026	FT-FY27-08022026-016295-A	<1	FT-FY27-08022026-016295-B	<1
WS-016296	5/15/2026	5/15/2027	3	Cooler	In hallway in cafeteria	WF-05152026-016296	8/18/2026	FT-FY27-08022026-016296-A	<1	FT-FY27-08022026-016296-B	<1
WS-016297	5/15/2026	5/15/2027	3	Cooler	In hallway in cafeteria	WF-05152026-016297	8/18/2026	FT-FY27-08022026-016297-A	<1	FT-FY27-08022026-016297-B	<1
WS-016298	5/15/2026	5/15/2027	3	Bottle Filler	In cafeteria	WF-05152026-016298	8/18/2026	FT-FY27-08022026-016298-A	<1	FT-FY27-08022026-016298-B	<1
WS-016299	5/15/2026	5/15/2027	3	Cooler	In cafeteria	WF-05152026-016299	8/18/2026	FT-FY27-08022026-016299-A	<1	FT-FY27-08022026-016299-B	<1
WS-016300	5/15/2026	5/15/2027	3	Cooler	In cafeteria	WF-05152026-016300	8/18/2026	FT-FY27-08022026-016300-A	<1	FT-FY27-08022026-016300-B	<1
WS- 005187	5/15/2026	5/15/2027	1	Bottle Filler	In hallway adjacent to room 1475	WF-05152026-005187	8/18/2026	FT-FY27-08022026-005187-A	<1	FT-FY27-08022026-005187-B	<1
WS- 005188	5/15/2026	5/15/2027	1	Cooler	In hallway adjacent to room 1475 High Left	WF-05152026-005188	8/18/2026	FT-FY27-08022026-005188-A	<1	FT-FY27-08022026-005188-B	<1
WS- 005189	5/15/2026	5/15/2027	1	Cooler	In hallway adjacent to room 1475 Low Right	WF-05152026-005189	8/18/2026	FT-FY27-08022026-005189-A	<1	FT-FY27-08022026-005189-B	<1
WS- 005190	5/15/2026	5/15/2027	1	Break Room	In room 1479	WF-05152026-005190	8/18/2026	FT-FY27-08022026-005190-A	<1	FT-FY27-08022026-005190-B	<1
WS- 005191	5/15/2026	5/15/2027	3	Break Room	In room 3472	WF-05152026-005191	8/18/2026	FT-FY27-08022026-005191-A	3.4	FT-FY27-08022026-005191-B	<1
WS- 005192	5/15/2026	5/15/2027	3	Bottle Filler	In hallway adjacent to room 3363	WF-05152026-005192	8/18/2026	FT-FY27-08022026-005192-A	<1	FT-FY27-08022026-005192-B	<1
WS- 005193	5/15/2026	5/15/2027	3	Cooler	In hallway adjacent to room 3363 High Left	WF-05152026-005193	8/18/2026	FT-FY27-08022026-005193-A	<1	FT-FY27-08022026-005193-B	<1
WS- 005194	5/15/2026	5/15/2027	3	Cooler	In hallway adjacent to room 3363 Low Right	WF-05152026-005194	8/18/2026	FT-FY27-08022026-005194-A	<1	FT-FY27-08022026-005194-B	<1
WS- 005685	5/15/2026	5/15/2027	3	Bottle Filler	In hallway adjacent to room 3243	WF-05152026-005685	8/18/2026	FT-FY27-08022026-005685-A	<1	FT-FY27-08022026-005685-B	<1
WS- 005686	5/15/2026	5/15/2027	3	Cooler	In hallway adjacent to room 3243 High Left	WF-05152026-005686	8/18/2026	FT-FY27-08022026-005686-A	<1	FT-FY27-08022026-005686-B	<1
WS- 005687	5/15/2026	5/15/2027	3	Cooler	In hallway adjacent to room 3243 Low Right	WF-05152026-005687	8/18/2026	FT-FY27-08022026-005687-A	<1	FT-FY27-08022026-005687-B	<1
WS- 005726	5/15/2026	5/15/2027	3	Bottle Filler	In hallway across from room 3231	WF-05152026-005726	8/18/2026	FT-FY27-08022026-005726-A	<1	FT-FY27-08022026-005726-B	<1
WS- 005727	5/15/2026	5/15/2027	3	Cooler	In hallway across from room 3231 High Left	WF-05152026-005727	8/18/2026	FT-FY27-08022026-005727-A	<1	FT-FY27-08022026-005727-B	<1
WS- 005728	5/15/2026	5/15/2027	3	Cooler	In hallway across from room 3231 Low Right	WF-05152026-005728	8/18/2026	FT-FY27-08022026-005728-A	<1	FT-FY27-08022026-005728-B	<1
WS- 005730	5/15/2026	5/15/2027	4	Combo Fountain	In room 4224	WF-05152026-005730	8/18/2026	FT-FY27-08022026-005730-A	<1	FT-FY27-08022026-005730-B	<1
WS- 005732	5/15/2026	5/15/2027	4	Combo Fountain	In room 4236	WF-05152026-005732	8/18/2026	FT-FY27-08022026-005732-A	<1	FT-FY27-08022026-005732-B	<1
WS- 005734	5/15/2026	5/15/2027	4	Bottle Filler	In hallway adjacent to room 4242	WF-05152026-005734	8/18/2026	FT-FY27-08022026-005734-A	<1	FT-FY27-08022026-005734-B	<1
WS- 005735	5/15/2026	5/15/2027	4	Cooler	In hallway adjacent to room 4242 High Left	WF-05152026-005735	8/18/2026	FT-FY27-08022026-005735-A	<1	FT-FY27-08022026-005735-B	<1
WS- 005736	5/15/2026	5/15/2027	4	Cooler	In hallway adjacent to room 4242 Low Right	WF-05152026-005736	8/18/2026	FT-FY27-08022026-005736-A	<1	FT-FY27-08022026-005736-B	<1
WS- 005740	5/15/2026	5/15/2027	3	Bottle Filler	In hallway adjacent to room 3474 staff restroom	WF-05152026-005740	8/18/2026	FT-FY27-08022026-005740-A	<1	FT-FY27-08022026-005740-B	<1
WS- 005741	5/15/2026	5/15/2027	3	Cooler	In hallway adjacent to room 3474 staff restroom High Left	WF-05152026-005741	8/18/2026	FT-FY27-08022026-005741-A	<1	FT-FY27-08022026-005741-B	<1
WS- 005742	5/15/2026	5/15/2027	3	Cooler	In hallway adjacent to room 3474 staff restroom Low Right	WF-05152026-005742	8/18/2026	FT-FY27-08022026-005742-A	<1	FT-FY27-08022026-005742-B	<1
WS- 005743	5/15/2026	5/15/2027	3	Combo Fountain	In room 3472	WF-05152026-005743	8/18/2026	FT-FY27-08022026-005743-A	<1	FT-FY27-08022026-005743-B	<1
WS- 005745	5/15/2026	5/15/2027	3	Combo Fountain	In room 3470	WF-05152026-005745	8/18/2026	FT-FY27-08022026-005745-A	<1	FT-FY27-08022026-005745-B	<1
WS- 005820	5/15/2026	5/15/2027	2	Bottle Filler	In hallway adjacent to room 2235	WF-05152026-005820	8/18/2026	FT-FY27-08022026-005820-A	<1	FT-FY27-08022026-005820-B	<1
WS- 005821	5/15/2026	5/15/2027	2	Cooler	In hallway adjacent to room 2235 High Left	WF-05152026-005821	8/18/2026	FT-FY27-08022026-005821-A	<1	FT-FY27-08022026-005821-B	<1
WS- 005822	5/15/2026	5/15/2027	2	Cooler	In hallway adjacent to room 2235 Low Right	WF-05152026-005822	8/18/2026	FT-FY27-08022026-005822-A	<1	FT-FY27-08022026-005822-B	<1
WS- 005831	5/15/2026	5/15/2027	2	Break Room	In 2236 teacher collaboration room	WF-05152026-005831	8/18/2026	FT-FY27-08022026-005831-A	1.3	FT-FY27-08022026-005831-B	<1

WS- 005832	5/15/2026	5/15/2027	2	Break Room	In 2241 lactation room	WF-05152026-005832	8/18/2026	FT-FY27-08022026-005832-A	<1	FT-FY27-08022026-005832-B	<1
WS- 005833	5/15/2026	5/15/2027	2	Break Room	In 2238 staff lounge	WF-05152026-005833	8/18/2026	FT-FY27-08022026-005833-A	<1	FT-FY27-08022026-005833-B	<1
WS- 006000	5/15/2026	5/15/2027	2	Bottle Filler	In hallway across from 2493	WF-05152026-006000	8/18/2026	FT-FY27-08022026-006000-A	<1	FT-FY27-08022026-006000-B	<1
WS- 006001	5/15/2026	5/15/2027	2	Cooler	In hallway across from 2493 High Left	WF-05152026-006001	8/18/2026	FT-FY27-08022026-006001-A	<1	FT-FY27-08022026-006001-B	<1
WS- 006002	5/15/2026	5/15/2027	2	Cooler	In hallway across from 2493 Low Right	WF-05152026-006002	8/18/2026	FT-FY27-08022026-006002-A	<1	FT-FY27-08022026-006002-B	<1
WS- 006003	5/15/2026	5/15/2027	2	Bottle Filler	In hallway adjacent to stair F High Left	WF-05152026-006003	8/18/2026	FT-FY27-08022026-006003-A	<1	FT-FY27-08022026-006003-B	<1
WS- 006004	5/15/2026	5/15/2027	2	Cooler	In hallway adjacent to stair F Low Right	WF-05152026-006004	8/18/2026	FT-FY27-08022026-006004-A	<1	FT-FY27-08022026-006004-B	<1
WS- 006005	5/15/2026	5/15/2027	2	Cooler	In hallway adjacent to stair F	WF-05152026-006005	8/18/2026	FT-FY27-08022026-006005-A	<1	FT-FY27-08022026-006005-B	<1
WS- 006008	7/27/2026	7/27/2027	2	Cooler	In hallway adjacent to 2356 electrical closet High Left	WF-07272026-006008	8/18/2026	FT-FY27-08022026-006008-A	<1	FT-FY27-08022026-006008-B	<1
WS- 006016	7/27/2026	7/27/2027	2	Bottle Filler	In hallway adjacent to 2356 electrical closet	WF-07272026-006016	8/18/2026	FT-FY27-08022026-006016-A	<1	FT-FY27-08022026-006016-B	<1
WS- 006017	7/27/2026	7/27/2027	2	Cooler	In hallway adjacent to 2356 electrical closet Low Right	WF-07272026-006017	8/18/2026	FT-FY27-08022026-006017-A	<1	FT-FY27-08022026-006017-B	<1
WS- 006018	7/27/2026	7/27/2027	5	Bottle Filler	In hallway adjacent to room 5102	WF-07272026-006018	8/18/2026	FT-FY27-08022026-006018-A	<1	FT-FY27-08022026-006018-B	<1
WS- 006019	7/27/2026	7/27/2027	5	Cooler	In hallway adjacent to room 5102 High Left	WF-07272026-006019	8/18/2026	FT-FY27-08022026-006019-A	<1	FT-FY27-08022026-006019-B	<1
WS- 006020	7/27/2026	7/27/2027	5	Cooler	In hallway adjacent to room 5102 Low Right	WF-07272026-006020	8/18/2026	FT-FY27-08022026-006020-A	<1	FT-FY27-08022026-006020-B	<1
WS- 006021	7/27/2026	7/27/2027	5	Bottle Filler	In hallway adjacent to room 5111	WF-07272026-006021	8/18/2026	FT-FY27-08022026-006021-A	<1	FT-FY27-08022026-006021-B	<1
WS- 006022	7/27/2026	7/27/2027	5	Cooler	In hallway adjacent to room 5111 High Left	WF-07272026-006022	8/18/2026	FT-FY27-08022026-006022-A	<1	FT-FY27-08022026-006022-B	<1
WS- 006023	7/27/2026	7/27/2027	5	Cooler	In hallway adjacent to room 5111 Low Right	WF-07272026-006023	8/18/2026	FT-FY27-08022026-006023-A	<1	FT-FY27-08022026-006023-B	<1
WS- 006323	7/27/2026	7/27/2027	3	Bottle Filler	In room 3102 music	WF-07272026-006323	8/18/2026	FT-FY27-08022026-006323-A	<1	FT-FY27-08022026-006323-B	<1
WS- 006324	7/27/2026	7/27/2027	3	Cooler	In room 3102 music High Left	WF-07272026-006324	8/18/2026	FT-FY27-08022026-006324-A	<1	FT-FY27-08022026-006324-B	<1
WS- 006325	7/27/2026	7/27/2027	3	Cooler	In room 3102 music Low Right	WF-07272026-006325	8/18/2026	FT-FY27-08022026-006325-A	<1	FT-FY27-08022026-006325-B	<1
WS- 006326	7/27/2026	7/27/2027	3	Bottle Filler	In room 3103 music	WF-07272026-006326	8/18/2026	FT-FY27-08022026-006326-A	<1	FT-FY27-08022026-006326-B	<1
WS- 006327	7/27/2026	7/27/2027	3	Cooler	In room 3103 music High Left	WF-07272026-006327	8/18/2026	FT-FY27-08022026-006327-A	<1	FT-FY27-08022026-006327-B	<1
WS- 006328	7/27/2026	7/27/2027	3	Cooler	In room 3103 music Low Right	WF-07272026-006328	8/18/2026	FT-FY27-08022026-006328-A	<1	FT-FY27-08022026-006328-B	<1
WS- 006329	7/27/2026	7/27/2027	3	Bottle Filler	In hallway adjacent to 3103	WF-07272026-006329	8/18/2026	FT-FY27-08022026-006329-A	<1	FT-FY27-08022026-006329-B	<1
WS- 006330	7/27/2026	7/27/2027	3	Cooler	In hallway adjacent to 3103 High Left	WF-07272026-006330	8/18/2026	FT-FY27-08022026-006330-A	<1	FT-FY27-08022026-006330-B	<1
WS- 006331	7/27/2026	7/27/2027	3	Cooler	In hallway adjacent to 3103 Low Right	WF-07272026-006331	8/18/2026	FT-FY27-08022026-006331-A	<1	FT-FY27-08022026-006331-B	<1
WS- 006336	7/27/2026	7/27/2027	4	Bottle Filler	In hallway across from room 4112	WF-07272026-006336	8/18/2026	FT-FY27-08022026-006336-A	<1	FT-FY27-08022026-006336-B	<1
WS- 006337	7/27/2026	7/27/2027	4	Cooler	In hallway across from room 4112 High Left	WF-07272026-006337	8/18/2026	FT-FY27-08022026-006337-A	<1	FT-FY27-08022026-006337-B	<1
WS- 006338	7/27/2026	7/27/2027	4	Cooler	In hallway across from room 4112 Low Right	WF-07272026-006338	8/18/2026	FT-FY27-08022026-006338-A	<1	FT-FY27-08022026-006338-B	<1
WS- 006339	7/27/2026	7/27/2027	4	Health Suite	In room 4115A health suite	WF-07272026-006339	8/18/2026	FT-FY27-08022026-006339-A	<1	FT-FY27-08022026-006339-B	<1
WS- 006341	7/27/2026	7/27/2027	4	Combo Fountain	In room 4223	WF-07272026-006341	8/18/2026	FT-FY27-08022026-006341-A	<1	FT-FY27-08022026-006341-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005733	12/11/2025	12/11/2026	4	Food Prep Sink	In room 4239 Daily Living Kitchen	WF-12112025-005733	8/18/2026	FT-FY27-08022026-005733-A	11.8	FT-FY27-08022026-005733-B	<1
WS-016301	12/11/2025	12/11/2026	3	Food Prep Sink	In kitchen	WF-12112025-016301	8/18/2026	FT-FY27-08022026-016301-A	<1	FT-FY27-08022026-016301-B	<1

FY27 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005733	12/11/2025	12/11/2026	4	Food Prep Sink	In room 4239 Daily Living Kitchen	WF-12112025-005733	8/18/2026	FT-FY27-08022026-005733-A	11.8	FT-FY27-08022026-005733-B	<1

First RE-Test(After Plumbing Check)

FY27 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005733	8/24/2026	8/24/2027	4	Food Prep Sink	In room 4239 Daily Living Kitchen	WF-08242026-005733	8/26/2026	FT-FY27-08242026-005733-A	<1	FT-FY27-08242026-005733-B	<1