



# JOHNSON MS LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	JOHNSON MIDDLE SCHOOL	WS- 001110	8/18/2016	Ground Floor	Cooler	In cafeteria east wall	FT-82016-001110-A	< 1	FT-82016-001110-B	< 1
2	JOHNSON MIDDLE SCHOOL	WS- 002324	8/18/2016	4	Cooler	In hallway across from room 420	FT-72016-002324-A	< 1	FT-72016-002324-B	< 1
3	JOHNSON MIDDLE SCHOOL	WS- 002325	8/18/2016	4	Cooler	In hallway adjacent to room 416	FT-72016-002325-A	< 1	FT-72016-002325-B	< 1
4	JOHNSON MIDDLE SCHOOL	WS- 002329	8/18/2016	Ground Floor	Cooler	In kitchen	FT-82016-002329-A	< 1	FT-82016-002329-B	< 1
5	JOHNSON MIDDLE SCHOOL	WS- 002330	8/18/2016	Ground Floor	Cooler	In hallway adjacent to locker room (B wing)	FT-72016-002330-A	< 1	FT-72016-002330-B	< 1
6	JOHNSON MIDDLE SCHOOL	WS- 010549	8/18/2016	4	Cooler	In hallway adjacent to elevator	FT-82016-010549-A	< 1	FT-82016-010549-B	< 1
7	JOHNSON MIDDLE SCHOOL	WS- 011104	8/18/2016	Ground Floor	Kitchen	In kitchen second clockwise from entry door Right	FT-72016-011104-A	< 1	FT-72016-011104-B	< 1
8	JOHNSON MIDDLE SCHOOL	WS- 011105	8/18/2016	Ground Floor	Food Prep Sink	In kitchen third clockwise from entry door	FT-72016-011105-A	< 1	FT-72016-011105-B	< 1
9	JOHNSON MIDDLE SCHOOL	WS- 011108	8/18/2016	Ground Floor	Kitchen	In kitchen fourth clockwise from entry door	FT-82016-011108-A	< 1	FT-82016-011108-B	< 1
10	JOHNSON MIDDLE SCHOOL	WS- 011109	8/18/2016	Ground Floor	Ice Maker	In kitchen (ice maker)	FT-82016-011109-A	< 1	FT-82016-011109-B	< 1
11	JOHNSON MIDDLE SCHOOL	WS- 011110	8/18/2016	Ground Floor	Cooler	In cafeteria east wall	FT-72016-011110-A	< 1	FT-72016-011110-B	< 1
12	JOHNSON MIDDLE SCHOOL	WS- 011111	8/18/2016	Ground Floor	Cooler	In cafeteria west wall	FT-72016-011111-A	< 1	FT-72016-011111-B	< 1
13	JOHNSON MIDDLE SCHOOL	WS- 011112	8/18/2016	1	Cooler	In hallway adjacent to gym	FT-72016-011112-A	< 1	FT-72016-011112-B	< 1
14	JOHNSON MIDDLE SCHOOL	WS- 011113	8/18/2016	1	Health Suite	In treatment room 111B in health suite	FT-72016-011113-A	< 1	FT-72016-011113-B	< 1
15	JOHNSON MIDDLE SCHOOL	WS- 011116	8/18/2016	1	Cooler	In hallway adjacent to room 111	FT-72016-011116-A	< 1	FT-72016-011116-B	< 1
16	JOHNSON MIDDLE SCHOOL	WS- 011117	8/18/2016	1	Cooler	In hallway adjacent to auditorium	FT-72016-011117-A	< 1	FT-72016-011117-B	< 1
17	JOHNSON MIDDLE SCHOOL	WS- 011118	8/18/2016	1	Cooler	In girls' locker room	FT-72016-011118-A	< 1	FT-72016-011118-B	< 1
18	JOHNSON MIDDLE SCHOOL	WS- 011119	8/18/2016	2	Cooler	In hallway across from room 225A High Left	FT-72016-011119-A	< 1	FT-72016-011119-B	< 1
19	JOHNSON MIDDLE SCHOOL	WS- 011120	8/18/2016	2	Cooler	In hallway across from room 225A Low Right	FT-72016-011120-A	< 1	FT-72016-011120-B	< 1
20	JOHNSON MIDDLE SCHOOL	WS- 011121	8/18/2016	2	Cooler	In hallway adjacent to room 204	FT-72016-011121-A	< 1	FT-72016-011121-B	< 1
21	JOHNSON MIDDLE SCHOOL	WS- 011122	8/18/2016	2	Cooler	In hallway adjacent to room 220 High Left	FT-72016-011122-A	< 1	FT-72016-011122-B	< 1
22	JOHNSON MIDDLE SCHOOL	WS- 011123	8/18/2016	2	Cooler	In hallway adjacent to room 220 Low Right	FT-72016-011123-A	< 1	FT-72016-011123-B	< 1
23	JOHNSON MIDDLE SCHOOL	WS- 011133	8/18/2016 10/10/2016	3	Cooler	In hallway adjacent to room 318 High Left	FT-72016-011133-A Re-test A	< 1 < 1	FT-72016-011133-B Re-test B	1.4 < 1
24	JOHNSON MIDDLE SCHOOL	WS- 011134	8/18/2016	3	Cooler	In hallway adjacent to room 318 Low Right	FT-72016-011134-A	< 1	FT-72016-011134-B	< 1
25	JOHNSON MIDDLE SCHOOL	WS- 011138	8/18/2016	3	Classroom Faucet	In science lab room 318 sixth clockwise from entry door Left	FT-72016-011138-A	< 1	FT-72016-011138-B	< 1
26	JOHNSON MIDDLE SCHOOL	WS- 011144	8/18/2016	3	Cooler	In hallway adjacent to room 312 High Left	FT-72016-011144-A	< 1	FT-72016-011144-B	< 1
27	JOHNSON MIDDLE SCHOOL	WS- 011145	8/18/2016	3	Cooler	In hallway adjacent to room 312 Low Right	FT-82016-011145-A	< 1	FT-82016-011145-B	< 1
28	JOHNSON MIDDLE SCHOOL	WS- 011146	8/18/2016	3	Cooler	In hallway adjacent to room 302	FT-72016-011146-A	< 1	FT-72016-011146-B	< 1