



Johnson MS Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002325	3/12/2025	3/12/2026	4	Cooler	In hallway adjacent to room 416	WF-03122025-002325	12/17/2025	FT-FY26-12012025-002325-A	<2	FT-FY26-12012025-002325-B	<2	
WS- 010550	3/12/2025	3/12/2026	Ground Floor	Cooler	In rec room adjacent to cafeteria	WF-03122025-010550	12/17/2025	FT-FY26-12012025-010550-A	<2	FT-FY26-12012025-010550-B	<2	
WS- 011109	3/12/2025	3/12/2026	Ground Floor	Ice Maker	In kitchen (ice maker)	WF-03122025-011109	12/17/2025	FT-FY26-12012025-011109-A	<2	FT-FY26-12012025-011109-B	<2	
WS- 011112	3/12/2025	3/12/2026	1	Cooler	In hallway adjacent to gym	WF-03122025-011112	12/17/2025	FT-FY26-12012025-011112-A	<2	FT-FY26-12012025-011112-B	<2	
WS- 011113	3/12/2025	3/12/2026	1	Health Suite	In health suite in treatment room 111B	WF-03122025-011113	12/17/2025	FT-FY26-12012025-011113-A	<2	FT-FY26-12012025-011113-B	<2	
WS- 011115	3/12/2025	3/12/2026	1	Break Room	In break room 107	WF-03122025-011115	12/17/2025	FT-FY26-12012025-011115-A	<2	FT-FY26-12012025-011115-B	<2	
WS- 011117	3/12/2025	3/12/2026	1	Cooler	In hallway adjacent to auditorium	WF-03122025-011117	12/17/2025	FT-FY26-12012025-011117-A	<2	FT-FY26-12012025-011117-B	<2	
WS- 011118	3/12/2025	3/12/2026	1	Cooler	In girls' locker room	WF-03122025-011118	12/17/2025	FT-FY26-12012025-011118-A	<2	FT-FY26-12012025-011118-B	<2	
WS- 011119	3/12/2025	3/12/2026	2	Cooler	In hallway across from room 225A	High Left	WF-03122025-011119	12/17/2025	FT-FY26-12012025-011119-A	<2	FT-FY26-12012025-011119-B	<2
WS- 011120	3/12/2025	3/12/2026	2	Cooler	In hallway across from room 225A	Low Right	WF-03122025-011120	12/17/2025	FT-FY26-12012025-011120-A	<2	FT-FY26-12012025-011120-B	<2
WS- 011122	10/30/2025	10/30/2026	2	Cooler	In hallway adjacent to room 220	High Left	WF-10302025-011122	12/17/2025	FT-FY26-12012025-011122-A	<2	FT-FY26-12012025-011122-B	<2
WS- 011123	10/30/2025	10/30/2026	2	Cooler	In hallway adjacent to room 220	Low Right	WF-10302025-011123	12/17/2025	FT-FY26-12012025-011123-A	<2	FT-FY26-12012025-011123-B	<2
WS- 011144	3/12/2025	3/12/2026	3	Cooler	In hallway adjacent to room 312	High Left	WF-03122025-011144	12/17/2025	FT-FY26-12012025-011144-A	<2	FT-FY26-12012025-011144-B	<2
WS- 011145	3/12/2025	3/12/2026	3	Cooler	In hallway adjacent to room 312	Low Right	WF-03122025-011145	12/17/2025	FT-FY26-12012025-011145-A	<2	FT-FY26-12012025-011145-B	<2
WS- 011146	3/12/2025	3/12/2026	3	Cooler	In hallway adjacent to room 302		WF-03122025-011146	12/17/2025	FT-FY26-12012025-011146-A	<2	FT-FY26-12012025-011146-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 011104	11/25/2025	11/25/2026	Ground Floor	Food Prep Sink	In kitchen second clockwise from entry door	Right	WF-11252025-011104	12/17/2025	FT-FY26-12012025-011104-A	<2	FT-FY26-12012025-011104-B	<2
WS- 011105	11/25/2025	11/25/2026	Ground Floor	Food Prep Sink	In kitchen third clockwise from entry door		WF-11252025-011105	12/17/2025	FT-FY26-12012025-011105-A	<2	FT-FY26-12012025-011105-B	<2
WS- 011106	11/25/2025	11/25/2026	Ground Floor	Food Prep Sink	In kitchen sixth clockwise from entry door		WF-11252025-011106	12/17/2025	FT-FY26-12012025-011106-A	<2	FT-FY26-12012025-011106-B	<2
WS- 011108	11/25/2025	11/25/2026	Ground Floor	Food Prep Sink	In kitchen fourth clockwise from entry door		WF-11252025-011108	12/17/2025	FT-FY26-12012025-011108-A	<2	FT-FY26-12012025-011108-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.