



Johnson Middle School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010550	4/12/2021	4/12/2022	Ground Floor	Cooler	In rec room adjacent to cafeteria	WF-04122021-010550	5/2/2021	FT-FY21-042021-010550-A	<1	FT-FY21-042021-010550-B	<1
WS- 011109	4/12/2021	4/12/2022	Ground Floor	Ice Maker	In kitchen (ice maker)	WF-04122021-011109	5/2/2021	FT-FY21-042021-011109-A	<1	FT-FY21-042021-011109-B	<1
WS- 011110	4/12/2021	4/12/2022	Ground Floor	Cooler	In cafeteria east wall	WF-04122021-011110	5/2/2021	FT-FY21-042021-011110-A	<1	FT-FY21-042021-011110-B	<1
WS- 011111	4/12/2021	4/12/2022	Ground Floor	Cooler	In cafeteria west wall	WF-04122021-011111	5/2/2021	FT-FY21-042021-011111-A	<1	FT-FY21-042021-011111-B	<1
WS- 011113	4/12/2021	4/12/2022	1	Health Suite	In health suite in treatment room 111B	WF-04122021-011113	5/2/2021	FT-FY21-042021-011113-A	<1	FT-FY21-042021-011113-B	<1
WS- 011115	4/12/2021	4/12/2022	1	Break Room	In break room 107	WF-04122021-011115	5/2/2021	FT-FY21-042021-011115-A	<1	FT-FY21-042021-011115-B	<1
WS- 011116	4/12/2021	4/12/2022	1	Cooler	In hallway adjacent to room 111	WF-04122021-011116	5/2/2021	FT-FY21-042021-011116-A	<1	FT-FY21-042021-011116-B	<1
WS- 011117	4/12/2021	4/12/2022	1	Cooler	In hallway adjacent to auditorium	WF-04122021-011117	5/2/2021	FT-FY21-042021-011117-A	<1	FT-FY21-042021-011117-B	<1
WS- 011118	4/12/2021	4/12/2022	1	Cooler	In girls' locker room	WF-04122021-011118	5/2/2021	FT-FY21-042021-011118-A	<1	FT-FY21-042021-011118-B	<1
WS- 011119	4/12/2021	4/12/2022	2	Cooler	In hallway across from room 225A High Left	WF-04122021-011119	5/2/2021	FT-FY21-042021-011119-A	<1	FT-FY21-042021-011119-B	<1
WS- 011120	4/12/2021	4/12/2022	2	Cooler	In hallway across from room 225A Low Right	WF-04122021-011120	5/2/2021	FT-FY21-042021-011120-A	<1	FT-FY21-042021-011120-B	<1
WS- 011121	4/12/2021	4/12/2022	2	Cooler	In hallway adjacent to room 204	WF-04122021-011121	5/2/2021	FT-FY21-042021-011121-A	<1	FT-FY21-042021-011121-B	<1
WS- 011122	4/12/2021	4/12/2022	2	Cooler	In hallway adjacent to room 220 High Left	WF-04122021-011122	5/2/2021	FT-FY21-042021-011122-A	<1	FT-FY21-042021-011122-B	<1
WS- 011123	4/12/2021	4/12/2022	2	Cooler	In hallway adjacent to room 220 Low Right	WF-04122021-011123	5/2/2021	FT-FY21-042021-011123-A	<1	FT-FY21-042021-011123-B	<1
WS- 011133	4/12/2021	4/12/2022	3	Cooler	In hallway adjacent to room 318 High Left	WF-04122021-011133	5/2/2021	FT-FY21-042021-011133-A	<1	FT-FY21-042021-011133-B	<1
WS- 011134	4/12/2021	4/12/2022	3	Cooler	In hallway adjacent to room 318 Low Right	WF-04122021-011134	5/2/2021	FT-FY21-042021-011134-A	<1	FT-FY21-042021-011134-B	<1
WS- 011144	4/12/2021	4/12/2022	3	Cooler	In hallway adjacent to room 312 High Left	WF-04122021-011144	5/2/2021	FT-FY21-042021-011144-A	<1	FT-FY21-042021-011144-B	<1
WS- 011145	4/12/2021	4/12/2022	3	Cooler	In hallway adjacent to room 312 Low Right	WF-04122021-011145	5/2/2021	FT-FY21-042021-011145-A	<1	FT-FY21-042021-011145-B	<1
WS- 011146	4/12/2021	4/12/2022	3	Cooler	In hallway adjacent to room 302	WF-04122021-011146	5/2/2021	FT-FY21-042021-011146-A	<1	FT-FY21-042021-011146-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011105	1/18/2021	1/18/2022	Ground Floor	Food Prep Sink	In kitchen third clockwise from entry door	WF-01182021-011105	5/2/2021	FT-FY21-042021-011105-A	<1	FT-FY21-042021-011105-B	<1
WS- 011106	1/18/2021	1/18/2022	Ground Floor	Food Prep Sink	In kitchen sixth clockwise from entry door	WF-01182021-011106	5/2/2021	FT-FY21-042021-011106-A	<1	FT-FY21-042021-011106-B	<1
WS- 011108	1/18/2021	1/18/2022	Ground Floor	Food Prep Sink	In kitchen fourth clockwise from entry door	WF-01182021-011108	5/2/2021	FT-FY21-042021-011108-A	<1	FT-FY21-042021-011108-B	<1