



# Johnson MS Lead in Water Test Results



## FY20 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002324	5/20/2019	5/20/2020	4	Cooler	In hallway across from room 420	WF-05202019-002324	12/31/2019	FT-FY20-122019-002324-A	<1	FT-FY20-122019-002324-B	<1
WS- 002325	5/20/2019	5/20/2020	4	Cooler	In hallway adjacent to room 416	WF-05202019-002325	12/31/2019	FT-FY20-122019-002325-A	<1	FT-FY20-122019-002325-B	<1
WS- 010550	5/20/2019	5/20/2020	Ground Floor	Cooler	In rec room adjacent to cafeteria	WF-05202019-010550	12/31/2019	FT-FY20-122019-010550-A	<1	FT-FY20-122019-010550-B	<1
WS- 011109	5/20/2019	5/20/2020	Ground Floor	Ice Maker	In kitchen (ice maker)	WF-05202019-011109	12/31/2019	FT-FY20-122019-011109-A	<1	FT-FY20-122019-011109-B	<1
WS- 011110	5/20/2019	5/20/2020	Ground Floor	Cooler	In cafeteria east wall	WF-05202019-011110	12/31/2019	FT-FY20-122019-011110-A	<1	FT-FY20-122019-011110-B	<1
WS- 011111	5/20/2019	5/20/2020	Ground Floor	Cooler	In cafeteria west wall	WF-05202019-011111	12/31/2019	FT-FY20-122019-011111-A	<1	FT-FY20-122019-011111-B	<1
WS- 011112	5/20/2019	5/20/2020	1	Cooler	In hallway adjacent to gym	WF-05202019-011112	12/31/2019	FT-FY20-122019-011112-A	<1	FT-FY20-122019-011112-B	<1
WS- 011113	5/20/2019	5/20/2020	1	Health Suite	In health suite in treatment room 111B	WF-05202019-011113	12/31/2019	FT-FY20-122019-011113-A	<1	FT-FY20-122019-011113-B	<1
WS- 011115	5/20/2019	5/20/2020	1	Break Room	In break room 107	WF-05202019-011115	12/31/2019	FT-FY20-122019-011115-A	<1	FT-FY20-122019-011115-B	<1
WS- 011116	5/20/2019	5/20/2020	1	Cooler	In hallway adjacent to room 111	WF-05202019-011116	12/31/2019	FT-FY20-122019-011116-A	<1	FT-FY20-122019-011116-B	<1
WS- 011117	5/20/2019	5/20/2020	1	Cooler	In hallway adjacent to auditorium	WF-05202019-011117	12/31/2019	FT-FY20-122019-011117-A	<1	FT-FY20-122019-011117-B	<1
WS- 011121	5/20/2019	5/20/2020	2	Cooler	In hallway adjacent to room 204	WF-05202019-011121	12/31/2019	FT-FY20-122019-011121-A	<1	FT-FY20-122019-011121-B	<1
WS- 011122	5/20/2019	5/20/2020	2	Cooler	In hallway adjacent to room 220	High Left WF-05202019-011122	12/31/2019	FT-FY20-122019-011122-A	<1	FT-FY20-122019-011122-B	<1
WS- 011123	5/20/2019	5/20/2020	2	Cooler	In hallway adjacent to room 220	Low Right WF-05202019-011123	12/31/2019	FT-FY20-122019-011123-A	<1	FT-FY20-122019-011123-B	<1
WS- 011133	5/20/2019	5/20/2020	3	Cooler	In hallway adjacent to room 318	High Left WF-05202019-011133	12/31/2019	FT-FY20-122019-011133-A	<1	FT-FY20-122019-011133-B	<1
WS- 011134	5/20/2019	5/20/2020	3	Cooler	In hallway adjacent to room 318	Low Right WF-05202019-011134	12/31/2019	FT-FY20-122019-011134-A	<1	FT-FY20-122019-011134-B	<1
WS- 011144	5/20/2019	5/20/2020	3	Cooler	In hallway adjacent to room 312	High Left WF-05202019-011144	12/31/2019	FT-FY20-122019-011144-A	<1	FT-FY20-122019-011144-B	<1
WS- 011145	5/20/2019	5/20/2020	3	Cooler	In hallway adjacent to room 312	Low Right WF-05202019-011145	12/31/2019	FT-FY20-122019-011145-A	<1	FT-FY20-122019-011145-B	<1
WS- 011146	5/20/2019	5/20/2020	3	Cooler	In hallway adjacent to room 302	WF-05202019-011146	12/31/2019	FT-FY20-122019-011146-A	<1	FT-FY20-122019-011146-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011104	7/17/2019	7/17/2020	Ground Floor	Food Prep Sink	In kitchen second clockwise from entry door	Right WF-07172019-011104	12/31/2019	FT-FY20-122019-011104-A	1	FT-FY20-122019-011104-B	<1
WS- 011105	7/17/2019	7/17/2020	Ground Floor	Food Prep Sink	In kitchen third clockwise from entry door	WF-07172019-011105	12/31/2019	FT-FY20-122019-011105-A	<1	FT-FY20-122019-011105-B	<1
WS- 011106	7/31/2019	7/31/2020	Ground Floor	Food Prep Sink	In kitchen sixth clockwise from entry door	WF-07312019-011106	12/31/2019	FT-FY20-122019-011106-A	<1	FT-FY20-122019-011106-B	<1
WS- 011108	7/17/2019	7/17/2020	Ground Floor	Food Prep Sink	In kitchen fourth clockwise from entry door	WF-07172019-011108	12/31/2019	FT-FY20-122019-011108-A	<1	FT-FY20-122019-011108-B	<1