



Johnson Middle School Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002330	6/19/17	6/19/18	Ground Floor	Cooler	In hallway adjacent to locker room (B wing)	WF-62017-002330	12/7/17	FT-FY18-62017-002330-A	<1	FT-FY18-62017-002330-B	<1
WS- 010549	6/19/17	6/19/18	4	Cooler	In hallway adjacent to elevator	WF-62017-010549	12/7/17	FT-FY18-62017-010549-A	<1	FT-FY18-62017-010549-B	<1
WS- 011111	6/19/17	6/19/18	Ground Floor	Cooler	In cafeteria west wall	WF-62017-011111	12/7/17	FT-FY18-62017-011111-A	<1	FT-FY18-62017-011111-B	<1
WS- 011113	6/19/17	6/19/18	1	Health Suite	In health suite in treatment room 111B	WF-62017-011113	12/7/17	FT-FY18-62017-011113-A	<1	FT-FY18-62017-011113-B	<1
WS- 011116	6/19/17	6/19/18	1	Cooler	In hallway adjacent to room 111	WF-62017-011116	12/7/17	FT-FY18-62017-011116-A	<1	FT-FY18-62017-011116-B	<1
WS- 011121	6/19/17	6/19/18	2	Cooler	In hallway adjacent to room 204	WF-62017-011121	12/7/17	FT-FY18-62017-011121-A	<1	FT-FY18-62017-011121-B	<1
WS- 011133	6/19/17	6/19/18	3	Cooler	In hallway adjacent to room 318 Left High	WF-62017-011133	12/7/17	FT-FY18-62017-011133-A	<1	FT-FY18-62017-011133-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation									
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 011105	Ground Floor	Food Prep Sink	In kitchen third clockwise from entry door	12/7/17	FT-FY18-102017-011105-A	<1	FT-FY18-102017-011105-B	<1	