



Joseph H Cole RC Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005520	7/23/2020	7/23/2021	1	Cooler	In hallway between men's and women's restroom High Left	WF-07232020-005520	4/27/2021	FT-FY21-042021-005520-A	1.2	FT-FY21-042021-005520-B	<1
WS- 005521	7/23/2020	7/23/2021	1	Cooler	In hallway between men's and women's restroom Low Right	WF-07232020-005521	4/27/2021	FT-FY21-042021-005521-A	<1	FT-FY21-042021-005521-B	<1
WS- 005523	7/23/2020	7/23/2021	1	Break Room	In multi-purpose room G131/132	WF-07232020-005523	4/27/2021	FT-FY21-042021-005523-A	<1	FT-FY21-042021-005523-B	<1